

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014	1		1		1				
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948		6		6		6			
3	MDK	87	828	1	1	1	1	1	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>2</b>	<b>11</b>	<b>2</b>	<b>11</b>	<b>2</b>	<b>11</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 28.02.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Bollaram	Meenakshi	33KV	Sangareddy	17.25	20.35	03.10		B/D due to Jumper cut at Salgutti company	Meenakshi	-
1	HYD S	220KV Shi.Pally	Miralam	33KV	Malakpet	09.30	09.38	00.08	EL	Cable punctured by Master plan wing at Shastry Nagar X Rd	Miralam	Loads transferred onto 33KV Shi.pally -Ch.Baradari OH line

## TSSPDCL - LMRC / Corporate office

Date: 28.02.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Moosapet	11KV	Rural	09.00	12.30	03.30		11KV Wire Cut Near Sankalmaddi(V)	-
1	NLG	Athmakur(S)	Athmakur	11KV	Suryapet	13.30	15.30	02.00	E/L	Line Cut	-
2		Kalmalcheruvu	Ganganagar	11KV	Huzurnagar	05.00	09.00	04.00	EL/OL	Due 11Kv line cutted near Ganga nagar village	-
3		Mamillagudem	Mothey agl	11KV	Huzurnagar	09.15	12.00	02.45	EL	Due Squirrel fall on 11Kv line near Mothey village	-
4		Kothapally	Krisnathanda	11KV	Devarakonda	11.15	13.26	02.11	E/L	11 KV Line Cutt	-
5		Padamtipally	Kandukur	11KV	Devarakonda	08.00	11.00	03.00	E/L	11 KV Line Cutt	-
6		Mupparam	Mupparam	11KV	Miryalaguda	06.15	09.20	03.05	E/L	11KV pin insulator Failed	-
1	MDK	Minpur	Minpur	11KV	Medak	10.00	12.00	02.00		B/D due to 11KV Conductor Snapped.	-
1	RR S	NPA	Shivarampally	11KV	RJNR	03.30	05.10	01.40	B/D	No Visible fault	-
1	RR N	JDMSS-III	Back lighty Hylam	11KV	Jeedimetla	01.00	02.25	01.25	EL/OL	11kv line AB Cable failure near KK Agences Engineer Company	-
1	RR E	PEDDAMBERPET	TARAMATHIPET	11KV	SAROORNAGAR	08.10	09.10	01.00	EL	BRID FALL ON 11KV LINE AT PASUMAMALA	-