

**Status Report on Breakdowns (Urban / Rural)****Urban**

| S.No | Circle       | No.of Feeders Existing Urban |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |              | 33KV                         | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                              |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN          | 48                           | 158         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 2    | NLG          | 18                           | 406         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 3    | MDK          | 92                           | 383         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 4    | RR(S)        | 40                           | 201         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(N)        | 82                           | 407         |                                    | 3        |                         | 3        |                                     | 3        |                                |          |                   |
| 6    | RR(E)        | 38                           | 360         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 7    | Hyd          | 186                          | 1014        |                                    |          |                         |          |                                     |          |                                |          |                   |
|      | <b>Total</b> | <b>504</b>                   | <b>2929</b> | <b>0</b>                           | <b>3</b> | <b>0</b>                | <b>3</b> | <b>0</b>                            | <b>3</b> | <b>0</b>                       | <b>0</b> |                   |

**Rural**

| S.No | Circle             | No.of Feeders Existing Rurals |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                          | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                               |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN                | 110                           | 969         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 2    | NLG                | 150                           | 948         |                                    | 3        |                         | 3        |                                     | 3        |                                |          |                   |
| 3    | MDK                | 87                            | 828         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 4    | RR(S)              | 31                            | 338         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(N)              | 8                             | 48          |                                    |          |                         |          |                                     |          |                                |          |                   |
| 6    | RR(E)              | 18                            | 89          |                                    |          |                         |          |                                     |          |                                |          |                   |
|      | <b>Total</b>       | <b>404</b>                    | <b>3220</b> | <b>0</b>                           | <b>3</b> | <b>0</b>                | <b>3</b> | <b>0</b>                            | <b>3</b> | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>908</b>                    | <b>6149</b> | <b>0</b>                           | <b>6</b> | <b>0</b>                | <b>6</b> | <b>0</b>                            | <b>6</b> | <b>0</b>                       | <b>0</b> |                   |

## TSSPDCL - LMRC / Corporate office

Date: 01.01.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1    | NLG    | Penpahad           | Potlapahad           | 11KV | Suryapet             | 08.25 | 09.50 | 01.25    | E/L              | Jumper Cut  | -                         |
| 2    |        | Mukundapuram       | Somaram              | 11KV | Huzurnagar           | 05.00 | 08.00 | 03.00    | E/L              | Insulator failure   | -                         |
| 3    |        | Janapahad          | Janpahad             | 11KV | Huzurnagar           | 07.25 | 09.40 | 02.15    | E/L              | 11 KV Snapped   | -                         |
| 1    | RR N   | DPPally            | Gandimaisamma        | 11KV | Jeedimetla           | 13.05 | 14.05 | 01.00    | EL               | Tree branchesh Fallon the 11kv line Andrabank Back side,Gandimaisamma | -                         |
| 2    |        | Devarayamjal       | Kottapet             | 11KV | Medchal              | 06.30 | 07.50 | 01.20    | BD               | 11KV Pin Insulator failed at Ashoka Poultryfarm                       | -                         |
| 3    |        | ICICI              | Unique Biotech-I     | 11KV | Medchal              | 16.10 | 18.20 | 02.10    | BD               | 11KV Line cut & replacement at Nektar Company                         | -                         |

