

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | | | | | | | | |
| 5 | RR(N) | 82 | 407 | | 2 | | 2 | | 2 | | | |
| 6 | RR(E) | 38 | 360 | | | | | | | | | |
| 7 | Hyd | 186 | 1014 | | 1 | | 1 | | 1 | | | |
| | Total | 504 | 2929 | 0 | 3 | 0 | 3 | 0 | 3 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 110 | 969 | | 1 | | 1 | | 1 | | | |
| 2 | NLG | 150 | 948 | 1 | 3 | 1 | 3 | 1 | 3 | | | |
| 3 | MDK | 87 | 828 | | | | | | | | | |
| 4 | RR(S) | 31 | 338 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 89 | | | | | | | | | |
| | Total | 404 | 3220 | 1 | 4 | 1 | 4 | 1 | 4 | 0 | 0 | |
| | Grand Total | 908 | 6149 | 1 | 7 | 1 | 7 | 1 | 7 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 02.01.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---|
| 1 | MBNR | Veepur | Veepur | 11kv | Mahabubnagar | 14.00 | 15.10 | 01.10 | | 11KV Jumper cut at Ramanapally (vi) | - |
| 1 | NLG | Ghanapuram | G.B.pally | 11kv | Devarakonda | 10.15 | 13.55 | 03.40 | EL | 11KV Jumper Cut | - |
| 2 | | Repala | Repala | 11kv | Huzurnagar | 11.00 | 12.30 | 01.30 | EL | Due to tree branch fall | - |
| 3 | | Repala | Narsimhulagudem | 11kv | Huzurnagar | 15.00 | 17.30 | 02.30 | EL | Due to 11Kv line cutted | - |
| 1 | RR N | DPPally | Gandimaisamma | 11kv | Jeedimetla | 13.05 | 14.05 | 01.00 | EL | Tree branchesh Fallon the 11kv line Andrabank Back side,Gandimaisamma | - |
| 2 | | GP Pally | GP Pally | 11kv | Medchal | 16.35 | 17.10 | 00.35 | EL | Bird fallen on the 11KV Line at GP Pally Village | - |
| 1 | HYD N | Jubilee Hills | A.O.U | 11kv | Jubilee Hills | 14.35 | 16.00 | 01.25 | EL,OL-Bph | Cable fault | Arranged B/F on 11KV Benz Show Room fdr |

TSSPDCL - LMRC / Corporate office

Date: 02.01.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|-----------------------------------|-----------------------|---------------------------|
| 1 | NLG | Suryapet | Yerkaram | 33kv | Suryapet | 10.10 | 13.20 | 03.10 | E/L | 33KV Line cut at Kudakuda village | Yerkaram | - |