

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014									
	Total	504	2929	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	4	0	4	0	4	0	0	
	Grand Total	908	6149	0	5	0	5	0	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.01.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Gundepuri	Pasthala	11KV	Suryapet	12.00	14.30	02.30	E/L	11Kv Insulator failed	-
2		Yarraram	Kamepally	11KV	Devarakonda	14.59	17.05	02.06	E/L	11 KV Jumper Cutt	-
3		D.B.Pally	Thummalapally	11KV	Devarakonda	08.00	10.52	02.52	E/L	11 KV Jumper Cutt	-
4		Ghanapuram	G.B.Pally	11KV	Devarakonda	05.20	11.00	05.40	E/L	11 KV Insulater Fail	-
1	RR S	Puppalaguda	Narsing	11KV	IBGH	09.10	11.20	02.10	B/D	Bird Fallen on 11kv line at yadagiri supermarkets	-

TSSPDCL - LMRC / Corporate office

Date: 03.01.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RR S				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD				NIL							-