

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948	1	4	1	4	1	4			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 04.01.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Reddygudem	Kukkadam	11KV	Suryapet	12:30	14:05	01.35	E/L	Line cut	No
2		Puttamgandi	Gumadam	11KV	Devarakonda	01.00	02.30	01.30	E/L	Jumper cut	No
3		Madhanapur	Mall	11KV	Devarakonda	12.10	12.25	00.15	E/L	Jumper cut	No
4		Marriguda	Vattipally	11KV	Devarakonda	11.15	13.00	01.45	E/L	11KV Insulater failed	No
1	RR N	J D M -SS-IV	Bhagylaxmi	11KV	Jeedimetla	16:04	17:06	1:02	EL&OL	Bird fallen on the 11KV line at Vinayakanagar	No
1	HYD C	Toli Chowki	Paramount Hills	11KV	Mehdipatnam	13.04	14.10	01.06	EL	Foreign material fallen on lines at Jaleel PT	No

TSSPDCL - LMRC / Corporate office

Date: 04.01.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Kolanupaka	Sharajipet	33KV	Bhongir	0:00	3:40	3:40	EL	33KV Line snapped & Pole damaged near Sharajipet SS	Sharajipet	No