

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360									
7	Hyd	186	1014	2	1	2	1	2	1			
	Total	504	2929	2	4	2	4	2	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948	1		1		1				
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	1	1	1	1	1	0	0	
	Grand Total	908	6149	3	5	3	5	3	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.01.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kourampet	Kourampet (T)	11KV	Jadcherla	13.30	16.30	03.00		HT/LT near Venkateshwara Temple	No
1	RR N	JDMSS-I	Phase-II	11KV	JDM	14:55	19:40	4:45	EL	11KV Line AB cable failed near Remady Helth Product Company, Phase-I	No
2		JDMSS-I	Shapurnagar	11KV	JDM	15.20	16.35	01.15	OL	A kite fallen on the 11kv line at Ice Company, Shapur Nagar	No
3		Devarayamjal	NTG	11KV	Medchal	03.40	05.40	02.00		11KV Disc failed at Telangana Printing Press	No
1	HYD S	Kandikal Gate	Naseeb Nagar	11KV	Charminar	13.05	14.15	01.10	EL	O/G Cable end kit failed at SS	No

TSSPDCL - LMRC / Corporate office

Date: 11.01.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Suryapet	Penpahad	33KV	Suryapet	6:05	8:05	2:00	EL	Jumper cut in 132/33KV SS	Penpahad	No
1	HYD N	132KV J' Hills	Hitech	33KV	Kalyan Nagar	03.40	04.54	01.14	OL-Bph	Cable damaged	Hitech	Loads transferred onto 132KV Madhapur SS via 33KV Madhapur Ckt-I
1	HYD S	220KV Shivrampally	Miralam	33KV	Malakpet	15:50	16:05	0:15	EL,OL-Bph	Cable damaged by Water Works at Shastrypuram	Miralam	Loads transferred onto 220KV Shivrampally SS via 33KV Ch' Baradari SS