

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		3		3		3			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		2		2		2			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	3	1	3	1	3	0	0	
	Grand Total	908	6149	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.01.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Ghanpur	33KV	Mahabubnagar	11.20	12.52	01.32	O/L	for 33KV Jumper Cut near 132KV SS Line Insulator to Fast Pole	Ghanpur	-

TSSPDCL - LMRC / Corporate office

Date: 13.01.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Addakal	C.M.Ched	11kV	Jadcherla	11.21	14.01	02.40		11 Kv Wire cut Near Addakal (Vi)	-
1	NLG	Kasarabhada	Kasarabhada	11kV	Suryapet	11.00	12.30	01.30	E/L	Jumper cut	-
2		Palakaveedu	Bothalapalem	11kV	Huzurnagar	06.50	08.10	01.20	EL	Due to LT Melt near Bothalapalem village	-
1	RR E	Aushapur	Bokkenguda	11KV	Keesara	12.30	15.00	02.30		11KV Pin Insulator failed at Bokkenguda	-
1	HYD N	Sanjeevaiah Park	Kamath Lingapur	11KV	IV	14.32	15.56	01.24	EL,OL	Kite fault on lines at Water Works	-
1	HYD S	Chanchalguda	Arya Samaj	11KV	VIII	13.50	15.08	01.18	EL,OL-Rph	No Visible fault	Arranged B/F on 11KV Akbar Bagh feeder
2		Chanchalguda	Madannapet	11KV	VIII	13.50	15.13	01.23	OL-Bph	No Visible fault	Arranged B/F on 11KV Edigha feeder