

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948	1	1	1	1	1	1			
3	MDK	87	828	1	3	1	3	1	3			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	4	3	4	3	4	0	0	
	Grand Total	908	6149	3	5	3	5	3	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.01.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Phanigiri	Malipuram	11KV	Suryapet	14:50	15:50	1:00	E/L	LT Line cut	No
1	MDK	Narsapur	Reddypally	11KV	Medak	14:00	16:40	2:40		11 KV Jumper cut	No
2		Kowdipally	Mohammad Nagar	11KV	Medak	13.00	16.20	03.20		11 KV Jumper cut	No
3		Minpur	Yousufpet	11KV	Medak	01.00	08.00	07.00		11 KV Insulator failed	No
1	HYD N	Madhapur	HUDA	11KV	Jubilee Hills	18.50	21.15	02.25	EL,OL-Bph	RMU UG Cable fault at Ratnadeep Super Market	No

TSSPDCL - LMRC / Corporate office

Date: 19.01.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kalwakurthy	Vangoor	33KV	Jadcherla	05.15	07.40	02.25	E/L	Pole damaged at CBM collage in Kalwakurthy (T)	Vangoor	Alternate supply given from 33KV Polkampally at 7:40 hrs
1	NLG	Ramapuram	Mellacheruvu	33KV	Huzurnagar	0:00	10:15	10:15	E/L	33KV Line cut	Mellacheruvu	Alternate supply given from 33KV Melancheruvu feeder of 132/33KV Mattampally SS at 04:00 hrs
1	MDK	Narsapur	Reddypally	33KV	Medak	11:50	14:50	3:00		Insulator failed	Reddypally	No