

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1	1	1	1	1	1			
6	RR(E)	38	360									
7	Hyd	186	1014	1	2	1	2	1	2			
	Total	504	2929	2	3	2	3	2	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		2		2		2			
2	NLG	150	948		3		3		3			
3	MDK	87	828		1		1		1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	6	0	6	0	6	0	0	
	Grand Total	908	6149	2	9	2	9	2	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.01.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Bhoothpur	Rural	11KV	Jadcherla	11.40	13.40	02.00		DTR Failure at Sheripally	-
2		Peddarevelly	Hemajipur	11KV	Jadcherla	06.00	10.40	04.40		Tree Follen on The 11 Kv Line Near Kummari Krishnaiah DTR Side,	-
1	NLG	Dirsenpally	Miryala	11KV	Suryapet	07.40	10.50	03.10	EL	HT/LT	-
2		Raghunadhapalem	Raghunadhapalem	11KV	Huzurnagar	05.00	07.00	02.00	E/L	Jumper cut	-
3		Paladugu	Duppelly	11KV	Bhongiri	04.00	07.00	03.00	E/L	Insulator failure	-
1	MDK	Shankarampet' R	Rudraram	11KV	Medak	11.15	13.05	01.50		B/D Due to Jumper Cut	-
1	RR N	Jeedimetla-SS II	Aporoopa Colony	11KV	Jeedimetla	11.20	12.25	01.05		11KV line snapped at Moodi bulders	-
1	HYD S	Falaknuma	Ravindra Naik Nagar	11KV	Charminar	08.58	10.42	01.44	EL,OL	Cable fault at Ravindra Naik Nagar	Arranged B/F on 11KV G.M.Chowni feeder
2	HYD N	Pragatools	Raj Foods	11KV	Erragadda	16.28	17.38	01.10	EL	Cable fault at Plot No.A49, R.R.Nagar	-

TSSPDCL - LMRC / Corporate office

Date: 22.01.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Medchal	33KV Steel Mill	33KV	Medchal	03.40	05.05	01.25		No Visble Fault	132KV Medchal	-
1	HYD C	220KV Osm. University	Indira Park (PTR-3,4,5)	33KV	H' Sagar	00.24	00.46	00.22	OL	Cable fault near Risalagadda	220KV Osm. University	Loads transferred onto 132KV Chilalguda SS via 33KV Indira Park fdr