

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360									
7	Hyd	186	1014									
	Total	504	2929	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948		4		4		4			
3	MDK	87	828		1		1		1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	5	1	5	1	5	0	0	
	Grand Total	908	6149	1	6	1	6	1	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.01.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Tekumatla	Tekumatla	11KV	Suryapet	05.20	08.40	03.20	EL	Insulator faild	-
2		Gaddipaly	Gaddipally	11KV	Huzurnagar	11.00	16.20	05.20	EL	Due to 11kv line cutted near Gaddipally village	-
3		Kalmalcheruvu	Ganganagar	11KV	Huzurnagar	00.00	07.00	07.00	EL	Due to Jumper cutted near Ganganagar village	-
4		Chamapur	Chamapur	11KV	Bhongir	14.40	17.30	02.50	EL	11Kv Conductor Snapped at 11Kv Insulator failed at Chamapur	-
1	MDK	Podchanpally	Yellapur	11KV	Medak	00.00	07.40	07.40		B/ D due to 11 KV Jumper cut	-
1	RR N	Dp Pally	Bowrampet	11KV	Medchal	15.40	17.40	02.00	EL	11kv Line Cut At Ring road Bowrampet	-

TSSPDCL - LMRC / Corporate office

Date: 23.01.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Rajapur	33kv	Wanaparthi	23.25	00.45	01.20	E/L	Back Feeding Supply Taken to 33KV Kodair Feeder Supply Stud Ok	Rajapur	-