

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014	1		1		1				
	Total	504	2929	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1				1		1 No. 33KV B/D Still pending
2	NLG	150	948		3		3		3			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	3	1	3	0	3	1	0	
	Grand Total	908	6149	2	6	2	6	1	6	1	0	

TSSPDCL - LMRC / Corporate office

Date: 25.01.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cheedella	Mukundapuram	11KV	Suryapet	07.00	09.40	02.40	EL	Jumper cut	No
2		Angadipeta	Gudipally	11KV	Devarakonda	08.55	09.55	01.00	EL	11KV Line Cutt	No
3		Urlagonda	Karkayalagudem	11KV	Huzurnagar	16.30	17.30	01.00	EL	Insulator failure	No
1	RR N	Kolthur	Mallannakatta	11KV	Medchal	14:15	15:45	1:30		Tree fallen on the 11KV line at Sneha farm, Keshavaram Road	No
1	RR E	Chakripuram	SV Nagar	11KV	Keesara	8:04	9:34	1:30		11KV AB Switch sparked at SV Colony & 11KV Jumper cut at SS Yard	No
2		P&T Colony	Chengicherla	11KV	Keesara	09.10	09.55	00.45		Bird fallen on the 11KV line near GS Reddy Function Hall	No

TSSPDCL - LMRC / Corporate office

Date: 25.01.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water Grid	33KV	Mahabubnagar	22.20	24.00	01.40	E/L	Cable failed	Koilkonda Water Grid	No
1	HYD N	132KV Jublee Hills	Ravindra Society	33KV	Kalyannagar	03.14	03.24	00.10	E/L,O/L- Bph	Cable fault	Ravindra Society	Loads transferred into 132KV Madhapur SS