

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948	1	2	1	2	1	2			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	2	1	2	1	2	0	0	
	Grand Total	908	6149	1	5	1	5	1	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.01.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Jalalpuram	Siddisamudram	11KV	Suryapet	12.00	14.15	02.15	EI	Jumper cut	-
2		Thimmapuram	Thimmapuram	11KV	Miryalaguda	02.30	07.45	05.15	EL/OL	Pin Insulator failed	-
1	RR N	Kandlakoya	Kandlakoya	11KV	Medchal	05.25	06.25	01.00	BD	11KV Pole damaged by Car at Suthariguda Road	-
2		Aliabad	Jaganguda	11KV	Medchal	04.30	05.25	00.55	BD	11KV Line cut at Nicmar College, Jaganguda	-
1	HYD S	Ch' Baradari	I.T.I. Colony	11KV	Charminar	19.35	20.40	01.05	EL	Breaker fault at SS	-

TSSPDCL - LMRC / Corporate office

Date: 28.01.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Haliya	Rajavaram	33KV	Miryalaguda	13.15	18.55	05.40	EL/OL	33 KV Disk Failed	Haliya	-