

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948		4		4		4			
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	5	1	5	1	5	0	0	
	Grand Total	908	6149	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 29.01.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karkonda	Khanapur	11KV	Jadcherla	04.54	09.17	04.23		11kv jumper cut near Khanapur	-
1	NLG	Pallerla	Siddapuram	11KV	Bhongir	06.15	09.00	02.45	EL	Insulator failure	-
2		N.Annaram	Dosapahad	11KV	Suryapet	04.30	08.00	03.30	E/L	Jumper cut	-
3		Alingapuram	Raghavapuram	11KV	Huzurnagar	05.00	07.00	02.00	E/L	11 KV Line snapped	-
4		Yacharam	Marepally	11KV	Miryalaguda	05.00	07.30	02.30	E/L	Insulator failure	-
1	RR S	Kokapet	Kokapet	11KV	IBGH	06.36	07.24	00.48		Pin Baining fail at NCC Apartment	-
1	RR N	Dp Pally	Bowrampet	11KV	Jeedimetla	16.05	19.15	03.10	EL	11kv Line Cut At TaTa Motors	-
1	RR E	BAIRAMULAGUDA	DURGA NAGAR	11KV	SAROORNAGAR	10.06	11.00	00.54	EL/OL	11KV CABLU FAIL TO BACK FEEDING TO SAGAR ENCLAVE	-
1	HYD S	Jiyaguda	Nalla Pochamma Temple	11KV	Begumbazar	16.13	18.00	01.47	EL,OL	Cable damaged by Water Works Wing	Arranged B/F on 11KV Tallagadda OH feeder
2	HYD C	Asif Nagar	Mehdipatnam Cable	11KV	Mehdipatanam	23.35	01.09	01.34	EL,OL-Rph	Cable fault at Mehdipatnam	Arranged B/F on 11KV Humayun Nagar feeder

TSSPDCL - LMRC / Corporate office

Date: 29.01.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Narayankhed	Wasar	33KV	Jogipet	03.45	08.30	04.45		B/D due to Insulator failure.	Narayankhed	-