

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014	1	1	1	1	1	1			
	Total	504	2929	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828		5		5		5			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	9	0	9	0	9	0	0	
	Grand Total	908	6149	1	12	1	12	1	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.01.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Koppole(K)	Kopolu	11kv	Nalgonda	06.00	07.00	01.00	EL	Jumper cut	-
2		Chinthapally	Varakala	11kv	Devarakonda	13.30	15.00	01.30	EL	11KV Inuslater Fail	-
3		Ghanapuram	G.B.Pally	11kv	Devarakonda	09.20	10.30	01.10	EL	11KV Inuslater Fail	-
4		Marrigudam	Vattipally	11kv	Devarakonda	11.10	12.15	01.05	EL	AB Switch Fail	-
1	MDK	Avancha	Ramchandrapuram	11kv	Medak	12.30	16.00	03.30		B/D Due to tree branches on 11 KV wires	-
2		Reddypally	Khajipet	11kv	Medak	12.20	13.30	01.10		B/D Due to conductor snapped	-
3		Yenigandla	Rangampet	11kv	Medak	06.00	15.00	09.00		B/D Due to 11 KV wire cut.	-
4		Alladurg	Rampur	11kv	Medak	10.40	11.33	00.53		B/D Due to Insulator 11 KV line cut.	-
5		B.B.Pur	Muthaipally	11kv	Medak	07.40	08.35	00.55		B/D Due to jumper Cut	-
1	RR S	Kokapet	Babukhan	11kv	IBGH	10.18	12.50	02.32	B/D	Tree Branches fallen on 11KV line at Babukhan club	-
1	RR E	Chekripuram	Ayyappa	11kv	Keesara	13.45	14.50	01.05		11KV jumper cut at in ss yard	-
1	HYD S	Malakpet	Farhath Nagar	11kv	Asmangadh	10.30	13.02	02.32	EL,OL-Bph	Cable fault at Farhath Nagar	Arranged B/D on 11KV Dist. Ka Alwa fdr (added loads 2 times partial) & Bada Bazar etc.

TSSPDCL - LMRC / Corporate office

Date: 30.01.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD C	132KV Asif Nagar	Gudi Malkapur	33kv	Mehdipatnam	01.50	02.02	00.12	EL,OL-Bph	Tripped on EL & OL	Gudi Malkapur	Loads transeferred onto 220KV Shivrampally SS