

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		1		1				<b>1-Still</b>
2	NLG	144	988		3		3		3			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 02.07.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water grid	33KV	Narayanpet	12.35	16.15	03.40		LA Blast at Marikal SS	Koilkonda Water grid	Allternate supply arranged from 33KV Kondapur feeder at 16:15Hrs
2		Achampet	Amrabad	33KV	Nagarkurnool	22.35	00.00	01.25	EL	DP Structure Failed	Amrabad	-

## TSSPDCL - LMRC / Corporate office

Date: 02.07.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nadigudem	Karvirala	11KV	Huzurnagar	05.30	09.00	03.30	EL	Due to jumper cutted	-
2		Akaram	Vallala	11KV	Nalgonda	10.05	13.55	03.50	E/L	11KV line cut at Village	-
3		Koppole(K)	Koppole	11KV	Nalgonda	08.00	10.00	02.00	E/L	11KV insulator failed	-
1	MDK	Thogita	Aurangabad	11KV	Medak	02.00	05.30	03.30		BD due to 11 KV Insulator Failed	-
1	RR E	Kushaiguda	Neredmet	11KV	Sainikpuri	01.20	02.00	00.40		11Kv line cut at Chennai Shopping Mall AS Rao Nagar. (AE/OP).	-
2		Moula-Ali	HCL	11KV	Sainikpuri	14.50	15.50	01.00		11Kv line Twisting at Krishna Road No 1 (AE/OP)	-
1	HYD S	Jiyaguda	Samastha Narayana	11KV	IX	04.05	05.20	01.15	Master Relay	Cable fault & Tree branches fallen on lines at Hanuman Temple	-