

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No. of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 2 | | 2 | | 2 | | | |
| 7 | RR(E) | 168 | 403 | | 1 | | 1 | | 1 | | | |
| 8 | Hyd | 194 | 1044 | 1 | 1 | 1 | 1 | 1 | 1 | | | |
| | Total | 606 | 3055 | 1 | 4 | 1 | 4 | 1 | 4 | 0 | 0 | |

Rural

| S.No | Circle | No. of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|--------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | | | | | | | | |
| 2 | NLG | 144 | 988 | 1 | 7 | 1 | 7 | 1 | 7 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | 1 | | 1 | | 1 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 1 | 8 | 1 | 8 | 1 | 8 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 2 | 12 | 2 | 12 | 2 | 12 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 03.07.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---|
| 1 | NLG | Thungathurty | Phanigiri | 33KV | Suryapet | 09.50 | 13.10 | 03.20 | E/L | 33Kv Disk Flashover | Thungathurty | No |
| 1 | HYD C | 132KV Hussain Sagar | A.C.Guards | 33KV | Asif Ngr | 17.40 | 17.50 | 00.10 | EL,OL-R,Y&Bph | Cable damaged by HMWS Wing near Bada Masjid | 132KV Hussain Sagar | Loads transferred onto 132KV Imlibun SS via 33KV Exhibition fdr |

TSSPDCL - LMRC / Corporate office

Date: 03.07.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|--|
| 1 | NLG | Bibigudem | Chivemla Agl | 11KV | Suryapet | 05.30 | 08.00 | 02.30 | E/L | 11Kv Conductor snapped | - |
| 2 | | Palakeedu | G G Palem | 11KV | Huzurnagar | 09.00 | 10.40 | 01.40 | E/L | 11kv conductor snapped at G G Palem (v) | - |
| 3 | | Palakeedu | Palakeedu | 11KV | Huzurnagar | 04.00 | 07.20 | 03.20 | E/L | 11kv conductor snapped at palakeedu (v) | - |
| 4 | | Alingapuram | Alingapuram | 11KV | Huzurnagar | 03.00 | 06.00 | 03.00 | E/L | 11kv line snapped at Alingapuram (v) | - |
| 5 | | Narkatpally SS | Mandra | 11KV | Nalgonda | 10.00 | 13.00 | 03.00 | E/L | 11 KV Insulator Failed | - |
| 6 | | Thurkapally | M.Gouraram | 11KV | Nalgonda | 04.30 | 08.40 | 04.10 | E/L | 11 KV Jumper Cut | - |
| 7 | | Kopple (K) | Bheemaram | 11KV | Nalgonda | 01.15 | 05.30 | 04.15 | E/L | HT/LT Lines Melt | - |
| 1 | MDK | GUGGILAA | GUGGILLA | 11KV | Siddipet | 01.00 | 06.00 | 05.00 | | INSULATOR BREAK SAME RECTIFAIED | - |
| 1 | RR N | Athiwelly | Somaram | 11KV | Medchal | 10.05 | 12.05 | 02.00 | BD | 11KV Jumper Replaced at Rose Garden, Somaram Village | - |
| 2 | | Medchal | Checkpoint | 11KV | Medchal | 14.20 | 15.10 | 00.50 | BD | Tree Branches Touched on the 11KV Line at Goyal Petrol Bunk, Suthariguda | - |
| 1 | RR E | Peerzathiguda | Peerzathiguda | 11KV | Keesara | 04.30 | 05.30 | 01.00 | | Copper patti cut at Rayancha colony | - |
| 1 | HYD N | Road No.13 | Gowri Shankar Nagar | 11KV | Banjarahills | 01.30 | 03.35 | 02.05 | EL,OL | Cable fault | Arranged B/F on 11KV Babukhan Chambers fdr |