

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT			2	3	2	3	2	3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	2	6	2	6	0	0	
	Grand Total	1082	6468	2	11	2	11	2	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.07.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mattapally	Mattapally	11kv	Huzurnagar	09.40	11.11	01.31	EL	Due to Jumper cutted	-
2		Gudimalkapuram	Pulicinthla	11kv	Huzurnagar	05.00	07.30	02.30	EL	Due to Insulator failure	-
3		Kodur	Kommala	11kv	Suryapet	12.40	14.30	01.50	E/L	Insulator flashover	-
1	SDPT	Muastyala	Sunchanakota + Cherial Agl +Gadikota	11kv	SDPT	14.30	19.30	05.00		Breaker Wire Blasting	-
2		Dhoolmitta	Arjunpatla	11kv	SDPT	14.00	18.10	04.10		Break down	-
3		Mirdoddy	Mirdoddy	11kv	SDPT	14.30	18.15	03.45		Disk fail	-
1	RR N	Ushamullapudi	Mahadevpuram	11kv	Medchal	19.55	20.10	00.15		Line AB switch opened	-
2		Laxmapur	IDA-I	11kv	Medchal	11.15	13.25	02.10		11KV Line cut	-
1	RR E	Yadgarpally	Yadgarpally	11kv	Keesara	12.30	13.45	01.15		11KV Belt patti cut and touched to Kasaram at Yadgarpally	-
1	HYD N	Film Nagar	Padmalaya Studio	11KV	X	07.25	08.54	01.29	All Indication	Sectioniser Rph cut at Road No.9, Film Nagar	Arranged B/F on 11KV Rama Naidu Studio fdr
2	HYD S	Miralam	Water Works	11KV	III	18.10	20.35	02.25	All Indication	CT PT fault at Water Works	-----

TSSPDCL - LMRC / Corporate office

Date: 04.07.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Gajwel	BV PUR	33KV	Gajwel	18.55	20.40	01.45		OL TRIP	BV PUR	-
2		Chandlapur	kammarlapally	33KV	Siddipet	15.41	16.50	01.09		EL TRIP	kammarlapally	-