

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		8		8		8			
3	MDK	107	933	2	3	2	3	2	3			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	11	3	11	3	11	0	0	
	Grand Total	1082	6468	3	19	3	19	3	19	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.07.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Oil Seeds	33KV	Gadwal	16.15	19.35	03.20	E/L	33KV Line Phase to Phase	Oil Seeds	-
1	MDK	Sadasivpet	Koheer	33KV	Sangareddy	19.30	20.30	01.00		Jumper cut	Koheer	Alternate supply arranged from 33KV Chota Hyderabad feeder from 132KV Zaheerabad
2		Pashamailaram	Manjeera	33KV	Sangareddy	00.38	03.20	02.42		B/D Due to Insulator Failure	Manjeera	-

TSSPDCL - LMRC / Corporate office

Date: 05.07.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Edulur	Garlabaigudam	11KV	Nalgonda	13.40	15.40	02.00	E/L	11 Kv line cut	-
2		Gattuppal	Lachammagudem	11KV	Nalgonda	06.30	08.00	01.30	E/L	11 KV insulator failed	-
3		Chandur	Angadi peta	11KV	Nalgonda	10.00	11.50	01.50	E/L	Jumper cut	-
4		Solepat	Solepat	11KV	Bhongir	06.00	10.15	04.15	E/L	11kv Insulator failed	-
5		Kudakuda	Aailapuram	11KV	Suryapet	15.30	17.15	01.45	E/L	Conductor snapped	-
6		Kandibanda	Gandinagar thanda	11KV	Huzurnagar	10.30	12.30	02.00	E/L	11 kv line snapped at Gandi nagar thanda village	-
7		Gondiryala	Kothagudem	11KV	Huzurnagar	06.25	07.40	01.15	E/L	11 kv jumper cut at Kothagudem village	-
8		Gondiryala	Gondiryala-01	11KV	Huzurnagar	09.05	11.32	02.27	E/L	11 kv inslater failed at Gondiryala village	-
1	MDK	Bollaram-II	Rupa	11KV	Sangareddy	18.10	20.30	02.20		B/D Due to Conductor Snapped	-
2		Nallavelly	Industrial	11KV	Sangareddy	17.50	18.40	00.50		B/D Due to Jumper Cut	-
3		Shalipet	Shalipet	11KV	Medak	07.45	08.30	00.45		B/D Due to Conductor Snapped	-
1	RR S	Gachibowli	Kothaguda	11KV	Kondapur	12.15	13.45	01.30	BD	11kv Line cut at Maseed banda, Kothaguda	-
1	RR N	Suraram	Rajiv Gandhi Nagar	11KV	JDM	17.25	18.50	01.25	EL	11kv Jumper cut in sub-Station	-
1	RR E	Techpark	Srikrishna	11KV	Habsiguda	14.12	15.54	01.42		Tree fallen on LT line and Insulator failed and Jumper cut near Dual Ring Company	-
2		Vasanthapuri	Ragavendra	11KV	SKP	11.09	12.08	00.59		Tree branches touching on 11Kv line at Narshima Reddy Nagar (LM Badri)	-
3		Saketh	Dammaiguda	11KV	Keesar	00.10	01.30	01.20		100KVA T/F Brass patti at VRR Colony Dammaiguda	-
4		Saketh	Dammaiguda	11KV	Keesar	03.20	06.20	03.00		100KVA T/F Copper patti cut at Green Park Colony	-
1	HYD N	H.P.S	R.B.I Quarters	11KV	IV	01.15	03.00	01.45	All Indication	No Visible Fault	02:25 Hrs partial fdr charged
1	HYD S	Sulthan Bazar	Sulthan Bazar	11KV	IX	10.35	12.12	01.37	EL	RMU Cable fault at Sulthan Bazar X Roads	-