

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		21		21		21			
7	RR(E)	168	403		12		12		12			
8	Hyd	194	1044		12		12		12			
	Total	606	3055	0	45	0	45	0	45	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	7		6		6		1		1 No 33KV fdr still
2	NLG	144	988	2	11	2	11	2	11			
3	MDK	107	933	1	11	1	11	1	11			
4	SDPT				21		21		21			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	10	43	9	43	9	43	1	0	
	Grand Total	1082	6468	10	88	9	88	9	88	1	0	

TSSPDCL - LMRC / Corporate office

Date: 06.07.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Machanpally	33KV	Mahabubnagar	07.05	08.56	01.51	E/L	Jumper cut at Machanpally	Mahabubnagar	-
2		Kothur	Thimmapur	33KV	Shadnagar	03.00	06.00	03.00	E/L	Insulator Failed near at Kothur	Kothur	-
3		Balanagar	G.R Cable	33KV	Rajapur	21.15	23.05	01.50	E/L&O/L	Due to B Phase LA Blast	Balanagar	-
4		Gadwal	RWS	33KV	Gadwal	22.20	07.05 (07.07.18)	08.45	E/L	Due to Rain	Gadwal	-
5		Chinnamaroor	Velgonda	33KV	Wanaparthi	20.55	21.25	00.30		Due to Rain	Chinnamaroor	-
6		Amarchinta	Chandra Gattu Lift	33KV	Wanaparthi	22.40	00.00	01.20		Due to Rain Not Rectified	Amarchinta	Alternate supply arranged from 33KV Mustipur SS
7		Nagarkurnool	lthole	33KV	Nagarkurnool	21.10	09.15 (07.07.18)	12.05	E/L	Due to Rain	Nagarkurnool	-
1	NLG	Kolanpak	Peddakandukur	33KV	Bhongir	21.00	22.00	01.00	E/L	Alternate supply tekan by Yadagiri Gutta	Kolanpak	-
2		Choutuppal	Choutuppal Indl.	33KV	Choutuppal	09.15	10.45	01.30	E/L	33kv line cut near ramgiri spinning mill	Choutuppal	-
1	MDK	Zaheerabad	Chota Hyderabad	33KV	Zaheerabad	00.00	06.10	06.10		BD due to Insulator failed		-

TSSPDCL - LMRC / Corporate office

Date: 06.07.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Huzurnagar-2	Lakkvaram 02	11KV	Huzurnagar	03.00	05.30	02.30	E/L	11Kv line cut	-
2		Mattampally	Choutupally	11KV	Huzurnagar	18.00	20.30	02.30	O/L	11Kv line snapped	-
3		Urulugonda	Karkayalagudem	11KV	Huzurnagar	02.00	05.00	03.00	EL/OL	11Kv Insulator failure	-
4		Eduloor	Gadibaigudem	11KV	Nalgonda	06.00	09.30	03.30	E/L	11KV Jumper cut	-
5		Eduloor	Parada	11KV	Nalgonda	03.15	07.50	04.35	E/L	11KV Jumper cut at SS-3	-
6		Koppole(K)	Koppole	11KV	Nalgonda	06.58	09.45	02.47	E/L	11KV insulator failed	-
7		Koppole(K)	Bheemaram	11KV	Nalgonda	02.00	06.00	04.00	O/L	Tree branches fallen on line at Chelgagudem	-
8		Indugula	Malapurajugudem	11KV	Nalgonda	03.30	09.00	05.30	E/L	6Nos. 11KV insulators failed	-
9		Mr gudem	Basavapuram	11KV	Bhongir	06.00	08.25	02.25	E/L	IN Line AB Switch post of insulator failed Datharpally (v) & Tree Branches fallen in line in Basvapur (v)	-
10		Y gutta	Mallapur	11KV	Bhongir	06.00	09.00	03.00	E/L	11Kv 2 insulator failed In Mallapur (v) ss	-
11		Chedella	Thungagudem	11KV	Suryapet	12.40	15.30	02.50	E/L	11Kv Insulator flashover	-
1	MDK	Cheryal	kalivemula	11KV	Sangareddy	05.10	09.20	04.10		B/d due to tree fallain on 11kv line near rudraram road (3ph only)	-
2		Kollur	NagulapallyAgl	11KV	Sangareddy	02.30	08.30	06.00		B/d due to 11kv Line cut near Elimela thanda	-
3		Kollur	Tellpaur Agl	11KV	Sangareddy	02.40	08.50	06.10		B/d due to tree fallain on 11kv line near Tellapur vg	-
4		EPIP-II	Padma	11KV	Sangareddy	03.20	06.00	02.40		B/d due to tree branch fallain on 11kv line near MSN co. back side	-
5		Patancheru	MIA I	11KV	Patancheru	00.30	03.30	03.00		B/d due to AB switch failed	-
6		Thogita	Aurangabad	11KV	Medak	00.00	07.30	07.30		B/D DUE TO DISC FAILURE	-
7		Thogita	Thogita	11KV	Medak	00.00	08.22	08.22		B/D DUE TO INSULATOR FAILURE	-
8		Gavvalapally	Shankarampet R	11KV	Medak	12.00	14.15	02.15		B/D DUE TO 11KV JUMPER CUT	-
9		Narsapur	Avancha	11KV	Medak	07.00	13.00	06.00		B/D DUE TO JUMPER CUT	-
10		Kowdipally	Mohd Nagar	11KV	Medak	00.00	10.00	10.00		B/D DUE TO DISC FAILURE	-
11		Narsingi	Narsingi	11KV	Medak	01.00	07.00	06.00		B/D DUE TO RAIN AND WIND PROBLEM	-
1	SDP	Machapur	Gangapur	11KV	Siddipet	00.00	13.00	13.00		Disk Fail	-
2		Ramancha	Gangapur	11KV	Siddipet	00.20	10.00	09.40		Insuletar Fail	-
3		Jankkapur	Shanigakunta	11KV	Siddipet	08.00	12.00	04.00		Disk Fail	-
4		Vittalapur	Rangaiapally	11KV	Siddipet	00.00	10.00	10.00		11 KV Wire Phase to Phase	-
5		Chandlapur	Gangapur	11KV	Siddipet	08.30	09.30	01.00		Disk Fail	-
6		Pedda Gudavally	Pedda Gudavally	11KV	Siddipet	03.30	10.40	07.10		Insuletar Fail	-
7		Pedda Cheekode	Pedda Cheekode	11KV	Siddipet	09.40	11.00	01.20		Insuletar Fail	-
8		Ramakkapet	Ramakkapet	11KV	Siddipet	00.00	04.40	04.40		Insuletar Fail	-
9		Thimmapur	Thimmapur	11KV	Siddipet	06.20	06.40	00.20		Disk Fail	-
10		Ragothampally	Gosanpally	11KV	Siddipet	00.00	07.40	07.40		Insuletar Fail	-
11		Pothareddypet	Pothareddypet	11KV	Siddipet	00.00	13.05	13.05		11 KV Poles Damage	-
12		Mittapally	Mittapally	11KV	Siddipet	00.20	07.00	06.40		Disk Fail	-
13		Raghavapur	Bachipally	11KV	Siddipet	08.10	14.30	06.20		Disk Fail	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
14		Thadapakally	Venkatapur	11KV	Siddipet	01.00	11.00	10.00		11 KV wire cutting	-
15		POTHARAM	Keshawapoor	11KV	Siddipet	06.00	08.35	02.35		snake killed on pole	-
16		THOTAPALLY	ANTHAKKAPET	11KV	Siddipet	00.00	09.00	09.00		insulator failure	-
17		THOTAPALLY	KONDAPUR	11KV	Siddipet	01.00	05.55	04.55		insulator failure	-
18		SAMUDRALA	SAMUDRALA (R)	11KV	Siddipet	00.00	07.30	07.30		LINE FAULT	-
19		Cherial Town	Rollabanda Agl	11KV	Siddipet	05.30	05.40	00.10		cable cut	-
20		Mustyal	Mustyal	11KV	Siddipet	00.00	13.00	13.00		insulator failure	-
21		Mustyal	Gadithota	11KV	Siddipet	00.00	13.00	13.00		insulator failure	-
1		RR N	Madinaguda	HM T	11KV	KKP	03.24	04.14	00.50	EL/OL	11kv Disk failure At Tulsi Nagar
2	H M T Hills		Adda Gutta	11KV	KKP	00.05	03.05	03.00	EL/OL	11kv Pin Insultor Failure At Little flower school	-
3	H M T Hills		Sri ram Nagar	11KV	KKP	01.15	03.30	02.15	EL/OL	Tree Branches Fallen On the 11kv Line At sri ram nagar	-
4	Mayurinagar		Mayurinagar	11KV	KKP	00.45	01.50	01.05	EL/OL	Due Heavy Rain	-
5	J D M SS-I		Phase-V	11KV	JDM	00.30	04.10	03.40	EL	11kv Pin insultor Failure at J LS pharma	-
6	J D M SS-I		C S Wire	11KV	JDM	01.40	04.45	03.05	EL/OL	11kv Jumper Cut In sub station	-
7	J D M SS-I		Apiic	11KV	JDM	00.40	01.45	01.05	EL/OL	Due To Rain	-
8	J D M SS-I		Triumala	11KV	JDM	01.20	09.00	07.40	EL/OL	11kv AB Cable Kit & Pin insultor Failure At Vinayak Nagar	-
9	J D M SS-III		Ram Reddy nagar	11KV	JDM	00.30	02.40	02.10	EL/OL	Due Heavy Rain	-
10	J D M SS-III		Andhrapolymer	11KV	JDM	00.45	02.20	01.35	EL/OL	Due Heavy Rain	-
11	Aleap		Pragathinagar	11KV	JDM	02.40	03.40	01.00	EL/OL	Tree branches Fallen On The 11kv Line at Pt No 1011 Pragathi nagar	-
12	Aleap		Punchavati	11KV	JDM	02.00	04.00	02.00	EL/OL	Tree branches Fallen On The 11kv Line at Pt No 911 Pragathi nagar	-
13	Kompally		Kompally	11KV	Medchal	01.00	01.40	00.40	BD	Tree Fallen on 11KV Line at near by SS	-
14	Thurkapally		Thurkapally	11KV	Medchal	00.30	03.00	02.30	BD	Lizard Fallen on 11KV Line at Kanuka Reddy Thota,Thurkapally	-
15	Medicity		Rajabollaram	11KV	Medchal	00.00	02.35	02.35	BD	11KV Jumper cut and replaced at Rajabollaram Thanda	-
16	Devarayamjal		Pothaipally	11KV	Medchal	01.20	04.35	03.15	BD	Tree Fallen on the 11KV Line at DMC	-
17	Kandlakoya		KV Reddy Nagar	11KV	Medchal	00.10	02.35	02.25	BD	11KV Pin Insulator Failed at Godrej Company	-
18	Shameerpet		Nalsar	11KV	Medchal	02.10	03.25	01.15	BD	11KV Brass pati cut and replaced at NTRO	-
19	Yellampet		Yellampet Agl	11KV	Medchal	07.37	10.30	02.53	BD	Tree fallen on the 11KV Line at Yellampet Chowrasta	-
20	Nuthankal		Bharathi	11KV	Medchal	07.50	10.30	02.40	BD	2Nos. 11KV Disc failed at Time Cold Storage	-
21	Shameerpet		Thumkunta	11KV	Medchal	22.35	23.20	00.45	BD	Tree fallen on the 11KV Line at Thumkunta Village	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Mallapur 2	Narshima nagar	11KV	Habsiguda	03.55	04.55	01.00		11kv Disk fail at MS biriyani point	-
2		Ramanthapur	Ganesh nagar	11KV	Habsiguda	01.15	02.30	01.15		Line petroling done cut no visiable falt found	-
3		Cherelapally-I	Krupp	11KV	Sainikpuri	01.00	05.30	04.30		Tree fallen on 11Kv line and 3HG fuses cut at Indus Genic Company (FOC Bhaskar)	-
4		Cherelapally-IV	RGK	11KV	Sainikpuri	00.50	04.50	04.00		11Kv Disk failed and Heavy Rain at Chinna Cherelapally (FOC Bhaskar)	-
5		Cherelapally-II	Januram	11KV	Sainikpuri	00.43	04.30	03.47		11Kv line AB switch opened at Ruchi Oil Compant Due to line Patrolling (FOC Bhaskar)	-
6		Yapral	Tulasi garden	11KV	Sainikpuri	01.30	02.20	00.50		Tree fallen on 11Kv line at Jupally Homes (AE)	-
7		Yapral	Kowkooor	11KV	Sainikpuri	01.30	02.30	01.00		Tree fallen on 11Kv line at Swarna Andhra Phase-I (AE)	-
8		Sainikpuri	Ramalayam	11KV	Sainikpuri	15.42	16.20	00.38		Water work on UG Cable Dammege at Defence Colony (AE/OP)	-
9		VP Nagar	Brundahavan Colony	11KV	Sainikpuri	01.10	01.50	00.40		11KV Disk failed at GK Colony (L.Insp Koteswar Rao)	-
10		Vasthapuri	Old Mirzalguda	11KV	Sainikpuri	22.39	23.54	01.15		11KV Pin Insulator Manasa Apartments	-
11		Narapally	Narapally	11KV	Keesara	04.25	06.15	01.50		insulator fail at narapally main Road	-
12		Chekripuram	Ayyappa	11KV	Keesara	04.50	05.20	00.30		insulator fail at Thirmalaguda	-
1	HYD N	James Street	S.D Road	11KV	Sec-Bad	00.15	01.40	01.25	EL	No Visible Fault	-
2		Bansilalpet	Botany School	11KV	Sec-Bad	02.05	03.50	01.45	All Indication	No Visible Fault	Arranged B/F on 11KV Old Jaikhana fdr
3		Bowenpally	Ferozguda	11KV	Bowenpally	02.15	05.00	02.45	EL,OL-Rph	Pin Insulator flash over at Ferozguda	-
4		H.P.S	R.B.I Quarters	11KV	Erragadda	02.46	04.05	01.19	EL	Cable fault	Arranged B/F on 11KV Begumpet Nala feeder
1	HYD S	Laxmi Nagar	Dhobighat	11KV	Asmangadh	01.20	03.19	01.59	EL,OL	Pin Insulator flash over at Dhobighat	-
2		Laxmi Nagar	Laxmi Nagar	11KV	Asmangadh	01.22	02.50	01.28	EL,OL	No Visible Fault	-
3		Moosarambagh	Moosarambagh	11KV	Asmangadh	01.25	02.30	01.05	EL,OL	No Visible Fault	-
4		Panjasha	Bibi Bazar	11KV	Charminar	01.30	02.50	01.20	EL,OL	No Visible Fault	-
5		Falaknuma	Guntal Shah Darga	11KV	Charminar	01.40	03.10	01.30	EL,OL-Bph	Kite Sticks fallen on lines at Guntal Shah Darga	-
6		Kandikalgate	Kandikalgate	11KV	Charminar	01.45	04.10	02.25	EL,OL	Tree branches fallen on lines & Disc Insulator at Narki Phool Bagh	-
7		Asmangadh	Saidabad Colony	11KV	Asmangadh	01.46	02.55	01.09	EL,OL-Bph	No Visible Fault	-
8		Sultan Bazar	Sultan Bazar	11KV	Begumbazar	03.45	05.56	02.11	EL	No Visible Fault	Arranged B/F on 11KV E.N.T feeder