

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	0	15	0	15	0	15	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		12		12		12			
2	NLG	144	988		12		12		12			
3	MDK	107	933	3	4	3	4	3	4			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	28	3	28	3	28	0	0	
	Grand Total	1082	6468	3	43	3	43	3	43	0	0	

TSSPDCL - LMRC / Corporate office

Date: 07.07.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Gummadidala	Bonthapally	33KV	Patancheru	19:25	20:55	1:30		Jumper cut near Bonthapally Village.	Bonthapally	No
2		Kowdipally	Ch.Ganapur	33KV	Medak	16.40	18.25	01.45		Tree branches fallen on the line	Ch.Ganapur	No
3		Medak	Nagapur	33KV	Medak	16.40	18.55	02.15		Tree branches fallen on the line	Nagapur	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mamidimada	Salkapur	11KV	Wanaparthy	19.50	09.00	13.10		No visible fault	No
2		Mamidimada	Thanda Feeder	11KV	Wanaparthy	19.50	09.00	13.10		No visible fault	No
3		Nachanally	Pedda Gudem	11KV	Wanaparthy	23.00	07.10	08.10		Jumper cut at Kistagiri(V)	No
4		Pangal	Bahadur Gudem	11KV	Wanaparthy	21:45	9:45	12:00		Disc failed at Jammapur (V)	No
5		Shahpur	Shahpur	11KV	Wanaparthy	20:10	11:45	15:35		Tree fallen on the 11KV Line	No
6		Mandhapur	Mandhapur	11KV	Wanaparthy	22:00	7:00	9:00		Insultor failed at Mandhapur (V)	No
7		Amarchinta	Paspula	11KV	Wanaparthy	21:00	8:40	11:40		Disc failed at Paspula (V)	No
8		Amarchinta	Undiyala	11KV	Wanaparthy	21:10	7:10	10:00		Insulator failed at Pamreddy Pally(V)	No
9		Chennaram	Chennaram	11KV	Wanaparthy	23:00	8:35	9:35		Jumper opend at Cheerkapally(V)	No
10		Kanaipally	Amadabakula	11KV	Wanaparthy	0:30	9:00	8:30		No visible fault	No
11		Wanaparthy (T)	Gopalpet	11KV	Wanaparthy	20:10	12:20	16:10		No visible fault	No
12		Veltoor	Mojerla	11KV	Wanaparthy	23.00	06.45	07.45		Disc failed at Veltoor (V)	No
1	NLG	Kandagatla	Gattikal	11KV	Suryapeta	12.50	16.30	03.40	E/L	Insulator flash over	No
2		G.Thirumalagiri	Namavaram	11KV	Suryapeta	11.30	13.10	01.40	E/L	Insulator failed	No
3		Rajupeta	Jonnalagaddagudem	11KV	Nalgonda	05.30	08.30	03.00	E/L	11KV Jumper cut	No
4		Cheruvupally	Cheruvupally	11KV	Nalgonda	7:30	9:35	2:05	E/L	Insulator failed	No
5		Pallakeedu	Sajjapuram	11KV	Huzurnagar	10:00	12:30	2:30	E/L	11KV Jumper cut	No
6		Garidepally	Kalmalacheruvu	11KV	Huzurnagar	4:00	7:30	3:30	E/L	Insulator failed	No
7		Mattampally	Chotupal	11KV	Huzurnagar	5:00	8:00	3:00	E/L	11KV Line snapped	No
8		Bollepally	Surepally	11KV	Bhongiri	6:00	9:00	3:00	E/L	Insulator failed	No
9		Madhanapuram	Teededu	11KV	Devarakonda	5:00	9:00	4:00	E/L	Insulator failed	No
10		Yararam	T.P.Gouraram	11KV	Devarakonda	6:00	8:20	2:20	E/L	Conductor snapped	No
11		Miryalaguda FCI	Hanumanpeta	11KV	Miryalaguda	12:05	13:30	1:25	E/L	11KV Jumper Cut	No
12		Nunavath thanad	Kondrapole	11KV	Miryalaguda	06.30	08.00	01.30	E/L	Insulator failed	No
1	MDK	Isnapur	IDA-Isnapur	11KV	Sangareddy	19:20	21:40	2:20		11KV Disc failed near Shivalayam Road.	No
2		Kondapur	Gangaram	11KV	Sangareddy	13.40	16.55	03.15		11KV Conductor snapped at Gangaram Village.	No
3		Narsapur	Avancha	11KV	Medak	06.00	13.00	07.00		Tree branches fallen on the line	No
4		Narsapur	Chippalthurthy	11KV	Medak	01.00	07.00	06.00		Insulator failed	No
1	RR S	Kismathpur	Kismathpur	11KV	Rajendranagar	19:55	21:45	1:50		No visible fault	No
2		Nanakramguda	Church	11KV	Gachibowli	13.12	14.52	01.40		Due to heavy wind and rain, 100kva T/F AB-Cable end-kit failed at Govt School ,SC basti, Nanakramguda	No
1	RR N	Vijaynagar Colony	Yellammabanda	11KV	Kukatpally	19:15	20:45	1:30		Due to heavy rain	No
2		Vijaynagar Colony	Aruna	11KV	Kukatpally	18.55	20.00	01.05		Due to heavy rain	No
3		Suraram	Matrix	11KV	Jeedimetla	18.40	19.45	01.05		End kit failed	No
4		Jeedimetla SS - IV	Tagore	11KV	Jeedimetla	19.00	20.15	01.15		Due to heavy rain	No
1	RR E	Nacharam	Nile	11KV	Habsiguda	13:12	14:55	1:43		Tree fallen on 11kv line at Road No.07 IDA Nacharam and 11KV Disc failed at Nacharam Main Road	No
2		IDA Uppal	Ram Reddy Nagar	11KV	Habsiguda	20.00	21.15	01.15		11KV Disc failed near Happy Restaurant and Bar	No
3		VP Nagar	Brundhavan Colony	11KV	Sainikpuri	09.40	11.10	01.30		11KV Jumper Cut	No
4		Aushapur	Edulabad AGL	11KV	Keesara	13.00	15.40	02.40		11KV Disc failed at Mula Kancha	No
1	HYD N	H.A.L	Samrat	11KV	Bowenpally	13.10	14.40	01.30	EL,OL-Bph	No Visible Fault	No
2		Clock Tower	Minerva	11KV	Sec'bad	19:00	20:20	1:20	EL,OL-R&Bph	No Visible Fault	No
3		S.P.R Hills	Peddamma Nagar	11KV	Erragadda	19:35	21:40	2:05	EL	Pin Insulator flash over at Peddamma Nagar	No
1	HYD S	Malakpet B-Block	L.I.C Colony	11KV	Asmangadh	20.09	21.10	01.01	All Indication	Jumper Cut at Children Jail	No
1	HYD C	Industrial Area	Shankermutt	11KV	Azamabad	11.35	12.54	01.19	EL	No Visible Fault	Arranged B/F on 11KV Nallakunta fdr