

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		11		11		11			
3	MDK	107	933	2	2	2	2	2	2			
4	SDPT				9		9		9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	24	3	24	3	24	0	0	
	Grand Total	1082	6468	3	32	3	32	3	32	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.07.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Thirumalaipally	Willamkonda	33KV	Wanaparthy	14.52	17.45	02.53	E/L	Due to Breaker Prablem	Thirumalaipally	Alternate Supply Arranged from 33KV Pebbair feeder at 17:45Hrs.
1	MDK	Bollaram	ITC	33KV	Patancheru	13.40	15.25	01.45		BD due to Lighting Arrester blast at 132KV Bollaram SS	Bollaram	-
2		Kowdipally	CH Ghanpur	33KV	Medak	00.00	08.20	08.20		BD due to Pin binding failed	Kowdipally	-

TSSPDCL - LMRC / Corporate office

Date: 10.07.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kodgal	Kodgal(T)	11KV	Jadcherla	03.30	08.00	04.30		11 KV Disc Failure Near Shivalayam DTR Side Kodgal (Vi).	-
2		Udithyal	Macharam	11KV	Jadcherla	04.10	08.30	04.20		11 Kv Wire Cut Near Bandapally(Vi).	-
1	NLG	Dirsincherla	Yellapuram	11KV	Huzurnagar	05.00	08.00	03.00	EL	Due to 11Kv Disk failure	-
2		Raghunadapalem	Gundlapally	11KV	Huzurnagar	04.30	07.15	02.45	EL	Due to tree branch fall on 11kv line	-
3		Repala	Repala	11KV	Huzurnagar	11.10	14.00	02.50	EL	Due to 11KV insulator failure	-
4		Thungathurty	Banda ramaram	11KV	Suryapet	04.20	07.40	03.20	E/L	Insulator failed	-
5		Chinthapally	Vinjamoor	11KV	Devarakonda	05.30	12.30	07.00	E/L	Tree Follan	-
6		Nampally	M.R.Pally	11KV	Devarakonda	02.00	02.30	00.30	E/L	Jumper Cutt	-
7		Neredugomma	Neredugomma	11KV	Devarakonda	10.00	15.00	05.00	E/L	1 No Disc Failed	-
8		K.M.Pally	Palvai	11KV	Devarakonda	03.00	11.00	08.00	E/L	11 KV Insulator Failed & Jumper Cutt	-
9		K.M.Pally	Doniyala	11KV	Devarakonda	08.00	11.00	03.00	E/L	2 Nos 11KV Insulator Failed & 1No Disc Failed	-
10		Angadipeta	Chilkamarri	11KV	Devarakonda	09.20	12.00	02.40	E/L	Tree Follan	-
11		Nalgonda	Koppole(K)	11KV	Bheemaram	22.20	06.30	08.40	E/L	11KV Insulators failed	-
1	MDK	Patancheru	Shanthinagar	11KV	Sangareddy	01.40	07.20	05.40		BD due to Disk failed	-
2		Burugupally	Yelupugonda	11KV	Medak	00.00	11.20	11.20		B/d Due to Jumper cut.	-
1	SDP	Katkur	Ramavaram & Mallaram	11KV	Siddipet	06.30	12.30	06.00		Conductor snapped	-
2		Regulapally	Cheelapur	11KV	Siddipet	05.30	23.30	18.00		Conductor snapped	-
3		Koheda	Theegalakuntapally	11KV	Siddipet	04.05	07.40	03.35		Insulator failed	-
4		Shanigaram	Gundareddypally	11KV	Siddipet	05.30	07.30	02.00		Jumpercut	-
5		Shanigaram	Gundareddypally	11KV	Siddipet	11.34	14.20	02.46		BD EL	-
6		Mittapally	Yellupally	11KV	Siddipet	09.20	10.30	01.10		11 KV Wire Cut	-
7		Thornal	Appanapally	11KV	Siddipet	08.10	10.20	02.10		Disk fail	-
8		Raghothampally	Gosanpally	11KV	Siddipet	04.30	08.30	04.00		Tree branches fall on the 11 kv line	-
9		Raghothampally	Akaram	11KV	Siddipet	23.00	08.00	09.00		Jumper cut	-
1	RR S	Ibrahimbagh	Peddamangalram (IBGH)	11KV	RJNR	04.11	06.20	02.09		11KV Insulator failed at Harsha apartment Madavinagar	-
1	RR N	Dulapally	Karteekavanam	11KV	Medchal	16.40	18.20	01.40	BD	No Fault	-
2		Chintal	Dwaraka nagar	11KV	Medchal	21.25	22.40	01.15	BD	11KV Disc failed at Dwaraka nagar	-
3		Shameerpet	Anthaipally	11KV	Medchal	06.20	09.30	03.10	BD	11KV Pin Insulator failed at Upparapally Village	-
1	RR E	Polytechnice	Sri nagar	11KV	Habsiguda	16.56	17.55	00.59		GI Wire fallen on 11kv line at KCR colony	-
2		Keesara	Vardhana	11KV	Keesara	12.20	14.05	01.45		11kv line cut at Godhumakutta	-
1	HYD N	Film Nagar	Apollo	11KV	Banjarahills	18.30	20.15	01.45	EL	Jumper cut at Bommarillu & Lizard fallen on AB Switch at Bus Stop	-
1	HYD C	Toli Chowki	Hakimsha	11KV	Mehdipatanam	09.20	11.15	01.55	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Paramount Hills & 11KV Brindavan Colony feeders