

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		13		13		13			
7	RR(E)	168	403		13		13		13			
8	Hyd	194	1044		17		17		17			
	Total	606	3055	0	43	0	43	0	43	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	2	2	2	2	2			
2	NLG	144	988	2	42	2	42	2	42			
3	MDK	107	933		7		7		7			
4	SDPT				5		5		5			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	56	4	56	4	56	0	0	
	Grand Total	1082	6468	4	99	4	99	4	99	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.07.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Narayanpet	Narayanpet	33kv	Narayanpet	05.40	07.55	02.15	E/L	No Visible Fault	Narayanpet	-
2		Kothur	Aryam Steel	33kv	Shadnagar	07.30	12.30	05.00	E/L	conductor snapped at Vinayaka company	Aryam Steel	-
1	NLG	Suryapeta	Thirumalagiri	33kv	Suryapeta	03.30	09.30	06.00	E/L	Insulator Flashover	Thirumalagiri	-
2		Shaligouraram	Nakrekal	33kv	Nalgonda	14.20	17.15	02.55	E/L	33KV Insulator failure	Nakrekal	-

TSSPDCL - LMRC / Corporate office

Date: 12.07.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Pomal	Ammapur	11KV	Jadcherla	10.00	13.00	03.00		11KV Phase to Phase Near Ammapur(V)	-
2		Polepally	Vallur	11KV	Jadcherla	07.00	10.00	03.00		Disc Failed at Vallur(V)	-
1	NLG	Penpahad	Dubbathanda	11KV	Suryapet	07.00	11.30	04.30	E/L	Disk flashover	-
2		N.Annaram	Dosapahad	11KV	Suryapet	08.10	11.10	03.00	E/L	Insulator flashover	-
3		Yerkaram	Rajnaik thanda	11KV	Suryapet	03.30	08.30	05.00	E/L	Conductor snapped	
4		Kasarabada	Express Feeder	11KV	Suryapet	03.00	07.55	04.55	E/L	Insulator flashover	
5		Nuthankal	Yerrapahad	11KV	Suryapet	02.30	07.40	05.10	E/L	Conductor snapped	
6		Mukundapuram	Chandupatla	11KV	Suryapet	01.50	07.30	05.40	E/L	Conductor snapped	
7		Koduru	Kommala	11KV	Suryapet	05.10	10.20	05.10	E/L	Insulator flashover	
8		Bopparam	Midthanapally	11KV	Suryapet	05.30	11.10	05.40	E/L	Insulator flashover	
9		Athmakur(S)	Dacharam	11KV	Suryapet	06.50	10.50	04.00	E/L	Insulator flashover	
10		Indugula	Malaparaju Gudem	11KV	Nalgonda	06.00	09.00	03.00	E/L	11 KV Line Insulator Failed	
11		Pamangundla	Pittampally	11KV	Nalgonda	04.00	10.00	06.00	E/L	Insulator Fialure	
12		Nakrekal	Chanduptla	11KV	Nalgonda	07.00	13.00	06.00	E/L	Conductor snapped	
13		Nakrekal	Kadaparthi	11KV	Nalgonda	03.00	07.00	04.00	E/L	Jumper Cut	
14		Nakrekal	Inpamula Ind	11KV	Nalgonda	05.10	06.15	01.05	E/L	Insulator Fialure	
15		Nakrekal	Market	11KV	Nalgonda	05.00	07.10	02.10	E/L	Conductor snapped	
16		Aitipamula	Gangadevi Gudem	11KV	Nalgonda	06.30	11.30	05.00	E/L	11KV line Jumper Cut	
17		Thoragal	Thangallavari Gudem	11KV	Nalgonda	06.00	09.10	03.10	E/L	Insulator Fialure	
18		Thoragal	Madaram	11KV	Nalgonda	06.00	12.00	06.00	E/L	Conductor snapped	
19		Thoragal	Thoragal	11KV	Nalgonda	06.00	10.15	04.15	E/L	11KV line Jumper Cut	
20		Thoragal	Gajendrai Gudem	11KV	Nalgonda	06.00	09.45	03.45	E/L	11KV line Jumper Cut	
21		Veliminedu	Gundrampally	11KV	Nalgonda	02.00	09.00	07.00	E/L	Insulator Fialure	
22		Pazzur	Kaziramram	11KV	Nalgonda	13.30	14.40	01.10	E/L	Insulator Fialure	
23		Palem	Bodangiparthi	11KV	Nalgonda	07.10	10.00	02.50	E/L	Conductor snapped	
24		Palem	Ogudu	11KV	Nalgonda	09.20	11.30	02.10	E/L	11KV line Jumper Cut	
25		D.B.Pally	Lenkalapally	11KV	Devarakonda	06.00	09.00	03.00	E/L	11KV line Jumper Cut	
26		Nampally	Vaddepally	11KV	Devarakonda	06.00	11.15	05.15	E/L	Conductor snapped	
27		Nampally	Peddapuram	11KV	Devarakonda	06.00	10.00	04.00	E/L	Insulator Fialure	
28		Nampally	M.R.Pally	11KV	Devarakonda	08.00	09.10	01.10	E/L	Insulator Fialure	
29		Kothapally	Peruvula	11KV	Devarakonda	02.00	08.00	06.00	E/L	11 KV 1No Insulator Failed	
30		Devarakonda	Mynampally	11KV	Devarakonda	03.25	09.45	06.20	E/L	Jumper Cutt	
31		Yarraram	Yarraram	11KV	Devarakonda	06.30	08.00	01.30	E/L	Conductor snapped	
32		Angadipeta	P.A.Pally Rural	11KV	Devarakonda	07.00	11.45	04.45	E/L	Insulator Fialure	
33		Azmapuram	Chenamanenipally	11KV	Devarakonda	05.30	13.10	07.40	E/L	Conductor snapped	
34		TeldevaraPally	BOLLARAM	11KV	Devarakonda	07.00	09.30	02.30	E/L	Insulator Fialure	
35		Marrigudam	Vattipally	11KV	Devarakonda	02.17	06.00	03.43	E/L	Jumper Cutt	
36		Chamapoor	Chamapoor	11KV	Bhongiri	06.00	08.00	02.00	E/L	11KV Insulator failure	
37		Chada	Industrial	11KV	Bhongiri	05.00	07.00	02.00	E/L	11KV Insulator failure	
38		Palakeedu	Bonthalapalem	11KV	Huzurnagar	02.30	06.30	04.00	E/L	11KV Line Snapped	
39		Gaddipally	Gaddipally	11KV	Huzurnagar	02.40	07.00	04.20	E/L	11KV Line Snapped	
40	Kalmalacheruvu	Kalmalacheruvu	11KV	Huzurnagar	05.00	08.00	03.00	E/L	11KV Line Snapped		

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
41		Mattampally	Ramachandrapuram	11KV	Huzurnagar	04.30	09.00	04.30	E/L	Jumper cut	
42		Amaravaram	Srinivasapuram	11KV	Huzurnagar	05.30	09.30	04.00	E/L	11KV Insulator failure	
1	MDK	Bollaram-I	Arabindio	11KV	Patancheru	10.23	11.53	01.30		B/D due to Jumper cut	-
2		Gummadidala	Gummadidala AGL	11KV	Patancheru	10.00	13.30	03.30		B/D due to Jumper cut	-
3		Inole	Indresham	11KV	Patancheru	10.43	12.58	02.15		B/D due to Disc failure.	-
4		EPIP-II	Export	11KV	Sangareddy	18.00	19.17	01.17		B/D due to Disc failure.	-
5		EPIP-II	Padma power	11KV	Sangareddy	10.20	12.00	01.40		B/D due to Tree branches fallen on the line	-
6		Wadi	Kothapally	11KV	Medak	05.00	07.45	02.45		B/D due to 11Kv insulator failure	-
7		Rajpally	Balanagar	11KV	Medak	08.36	11.00	02.24		B/D due to 11KV Conductor Snapped	-
1	SDPT	Nangunoor	Nagarajupally	11KV	SDPT	12.30	13.45	01.15		B/D Fall on tree brance at 11 KV wire	-
2		Nangunoor	Akkanapally	11KV	SDPT	01.55	05.00	03.05		B/D Fall on tree brance at 11 KV wire	-
3		Gurralongondi	Ramancha IND	11KV	SDPT	15.00	18.15	03.15		B/D 11KV wire cutting	-
4		Chittapur	Tallapally	11KV	SDPT	09.12	09.34	00.22		B/D 11KV wire cutting	-
5		Chittapur	Dharmajipet	11KV	SDPT	04.37	16.00	11.23		B/D Cable nutral wire attach 11KV wire	-
1	RR N	Mayurinagar	Prashanthnagar	11KV	Kukatpally	07.05	08.25	01.20	EL/OL	Tree Branchesh Fallon the 11kv line at Brundavan Colony	-
2		Mayurinagar	Prashanthnagar	11KV	Kukatpally	00.01	02.00	01.59	EL/OL	11kv line UG cable failure at Brundavan Colony	
3		Jeedimetla-IV	Tagoure	11KV	Jeedimetla	03.20	06.15	02.55	EL/OL	Due to rain & pole damaged opp: Tagourecompany	
4		Jeedimetla-IV	Axies	11KV	Jeedimetla	03.20	04.45	01.25	EL/OL	11kv line AB Cable failure at Axies	
5		Jeedimetla-II	KJR Pholymars	11KV	Jeedimetla	02.42	05.25	02.43	EL/OL	Incoming Jumper at Cut at KJR pholymars	
6		Suraram	Rajiv gandhinagar	11KV	Jeedimetla	01.40	05.00	03.20	EL	11kv line pin Insulater failure at Rajivgandhinagar	
7		Jeedimetla-III	Foxsagar	11KV	Jeedimetla	07.05	08.25	01.20	EL/OL	11kv line pin Insulater failure at Fox sagar	-
8		Jagathgirigutta	Jagathgirigutta	11KV	Medchal	01.40	03.20	01.40	BD	11KV Disc Failed and Cable Kit Failed at Anjaiah Nagar	-
9		DPPally	Bowrampet	11KV	Jeedimetla	03.06	05.00	01.54	EL	{ Due to rain}	-
10		DPPally	Bowrampet	11KV	Jeedimetla	08.20	11.40	03.20	EL	11kv line Jumper cut at SS	-
11		GP Pally	GP Pally	11KV	Medchal	01.30	04.20	02.50	BD	Tree Fallen on the 11KV Line near SS	-
12		Medchal	Navadurga	11KV	Medchal	06.50	09.22	02.32	BD	Tree Fallen on the 11KV Line and Pin Insulators Failed at Victory Thota	-
13		Laxmapur	Narayanpur	11KV	Medchal	13.20	15.20	02.00	BD	11KV Pin Insulator failed at Gururaja Company Opposite, Narayanpur	-
1		Chertlapally-II	Gajanana Thamara	11KV	Sainikpuri	02.55	04.55	02.00		11Kv Insulator failed at Opposite RK Cable Phase-I (Foc Srinivas)	-
2		Yapral	Pradhamapuri	11KV	Sainikpuri	02.35	03.20	00.45		Tree branches fallen on 11Kv line at Kapra Lekue (LM Venkatesham)	-
3		Kushaiguda	Sriram Nagar	11KV	Sainikpuri	03.20	04.10	00.50		11Kv Pin Insulator failure at Goudapuri Colony (AE/SKP)	
4		Sainikpuri	Eshwarpuri	11KV	Sainikpuri	01.30	03.05	01.35		11Kv Pin Insulator failure at Eshwarpuri (AE/SKP)	
5		Sainikpuri	Saipuri	11KV	Sainikpuri	03.10	04.05	00.55		11Kv line AB Switch opened at Saipuri and Load added on Eshwarpuri (AE)	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
6	RR E	Vasanthapuri	Ganesh Temple	11KV	Sainikpuri	04.20	06.30	02.10		11Kv line cut at CMR Complex (AE/Goutham Nagar)		
7		Mallapur	Noma	11KV	Habsiguda	00.35	02.00	01.25		11KV Pin Insulator failed near Jinuarm Colony 12th Block		
8		Mallapur	IDA	11KV	Habsiguda	06.15	07.10	00.55		11KV 2Nos Polymer Disc failed near Charminar Company and Near Ice Factory Opposite	-	
9		IDA Uppal	Metro	11KV	Habsiguda	07.10	08.19	01.09		Tree branches fallen on 11kv line near Vodafone Company and Breaker fault at SS Yard and Back feeding supply taken from 11KV Srikrishna Feeder	-	
10		Sai nagar	Saraswathi nagar	11KV	Habsiguda	09.20	10.20	01.00		Pin insulator failat Mansulony colony	-	
11		Aushapur	Edulabad	11KV	Keesara	03.00	06.00	03.00		11Kv line cut at Edulabad	-	
12		Nagaram	Bandlaguda	11KV	Keesara	13.03	13.51	00.48		Coconut tree fallen on 11kv line Bharath rathna school	-	
13		CRPF	Chenapur	11KV	Keesara	11.10	12.10	01.00		Line AB swithc open at dumping yard due to Brashpatti cut	-	
1		HYD N	Srinagar Colony	Srinagar Colony	11KV	X	01.14	02.43	01.29	EL,OL-Rph	No Visible Fault	-----
2			Srinagar Colony	Yellareddyguda	11KV	X	01.51	03.08	01.17	All Indication	No Visible Fault	-----
3			Srinagar Colony	Nagarjuna Nagar	11KV	X	01.51	03.22	01.31	All Indication	No Visible Fault	-----
4			Hakimpet	Bollarum PS	11KV	VI	02.00	03.05	01.05	EL	Kite Stick on lines at Kolla Temple	-----
5			Road No. 13	Road No. 1	11KV	X	02.25	04.00	01.35	EL,OL	3wa RMU fault at Road No.1	-----
6	Toli Chowki		Hanuman Temple	11KV	X	02.00	03.30	01.30	EL,OL	Tree branches on lines, Pin Insulator falsh over, HG fuse B/O & AB Switchfault at Suresh Reddy's House	-----	
7	Road No. 13		Sriram Nagar	11KV	X	06.05	07.25	01.20	EL,OL	Pin Insulator flashover at Masjid PT	-----	
8	E.S.I		B.K.Guda	11KV	IV	06.26	07.30	01.04	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Yellamma Temple fdr	
9	I.I.C.T		Solex	11KV	V	07.30	08.40	01.10	EL	Tree branches fallen on lines at Street No.1	-----	
10	Prashanth Nagar		Time Tek	11KV	VI	08.05	09.40	01.35	EL,OL	Pin Insulator flashover at Prashanth Nagar	-----	
11	Addagutta		Tagore Homes	11KV	V	08.35	10.05	01.30	EL,OL-Rph	Tree fallen on lines at Jagruthi Apts	9:00Hrs partial loads arranged B/F on 11KV Nehru Nagar fdr	
12	Raheja		Gafoor Nagar	11KV	X	08.55	10.00	01.05	EL	Pin Insulator flash over at Mohan Babu's House	-----	
13	I.I.C.T		Dall Mill	11KV	V	09.20	10.40	01.20	EL,OL	Post type Insulator flash over at Dall Mill	Arranged B/F on 11KV Nagarjuna Nagar fdr	
14	MLA Colony		Kalinga	11KV	X	10.30	11.35	01.05	All Indication	Tree fallen on lines at More Medical Hall	-----	
1	HYD C	Asif Nagar	Alapati Nagar	11KV	VII	05.25	06.40	01.15	EL,OL-Rph	Tree branches on lines at Alapati Nagar		
1	HYD S	Panjasha	Darjalng School	11KV	III	05.50	07.20	01.30	All Indication	No Visible Fault		
2		Malakpet	Komatiwadi	11KV	VIII	06.55	08.05	01.10	EL,OL-Yph	Foreign Material fallen on lines at Goal Kabra		