

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		8		8		8			
8	Hyd	194	1044	1	6	1	6	1	6			
	Total	606	3055	1	18	1	18	1	18	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		6		6		6			
3	MDK	107	933	2	5	2	5	2	5			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	11	3	11	3	11	0	0	
	Grand Total	1082	6468	4	29	4	29	4	29	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.07.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Nawabpet	33KV	Mahabubnagar	20.20	23.44	03.24	EL	33KV Leaned Pole work near Railway Track	Nawabpet	No
1	MDK	Zaheerabad	Machanoor	33KV	Zaheerabad	17:45	22:30	4:45		Insulator flashover	Machanoor	No
2		Medak	B.B pur	33KV	Medak	10.35	16.05	05.30		Pin binding failed	B.B pur	No
1	HYD N	132KV Erragadda	Mothi Nagar	33KV	Allwyn	11.35	11.40	00.05	EL,OL	Cable puncture by TRANSCO Wing	Mothi Nagar	Loads transferred onto 132KV Erragadda - IDPL

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Arvapally	Arvapally Agl	11KV	Suryapet	11:10	13:30	2:20	E/L	Disc flashover	No
2		Phanigiri	Malipuram	11KV	Suryapet	04.30	07.10	02.40	E/L	Insulator flashover	No
3		Eduloor	Gadibaigudem	11KV	Nalgonda	14.00	16.00	02.00	E/L	11KV Jumper cut at SS-5	No
4		Urumadla	Thallavellemla	11KV	Nalgonda	12.00	14.20	02.20	E/L	11KV Insulator failed	No
5		Urumadla	Elikate	11KV	Nalgonda	14.06	15.40	01.34	E/L	11KV Insulator failed	No
6		Addagudur	Addagudur	11KV	Bhongiri	8:35	11-00	3:35	EL	11KV Insulator failed	No
1	MDK	SOL	IDA-II	11KV	Sangareddy	7:20	8:25	1:05		Disc failed	No
2		Gaddapotharam - I	Vishnu	11KV	Patancheru	02.35	10.30	07.55		Jumper cut	No
3		Gummadidala	Gummadidala	11KV	Patancheru	09.50	12.30	02.40		Disc failed	No
4		Bujarampet	Kukatlapally	11KV	Medak	08.00	09.05	01.05		Insulator failed	No
5		Gadipeddapur	Akasalpur	11KV	Medak	9:30	20:30	11:00		Insulator failed	No
1	RR S	IIIT	GPRA	11KV	Gachibowli	0:22	4:45	4:23		11KV Pin insulator failed at Good governance, 11KV Jumper snapped at Indra nagar and Lighting arrester at GPRA Quarters	No
2		Gachibowli	Nallagandala	11KV	Gachibowli	10.25	11.50	01.25		Nallagandala feeder incoming panther cut in Sub-station	No
3		Gachibowli	Telephone Exchange	11KV	Gachibowli	20.25	21.40	01.15		163kv T/F Failed in Telephone Exchange	No
1	RR N	Shameerpet	Leo Meridian	11KV	Medchal	16:00	17:45	1:45		11KV Line Cut and replacement at Outer ring road	No
1	RR E	Ramanthapur	Gokhale Nagar	11KV	Habsiguda	0:48	3:40	2:52		11KV 2Nos Disc Insulator failed	No
2		Cherlapally-IV	BN Reddy Nagar	11KV	Sainikpuri	5:32	6:47	1:15		11Kv Pin Insulator failed	No
3		Kushaiguda	Kushaiguda	11KV	Sainikpuri	2:45	3:30	0:45		11Kv Pin Insulator failed at Narayana School	No
4		Kushaiguda	Neredmet	11KV	Sainikpuri	4:55	5:50	0:55		11Kv AB Cable failed at Seven Hills Appartment Gokul Nagar	No
5		Moula-Ali	Moula-Ali	11KV	Sainikpuri	16.30	17.30	01.00		Post of Insulator failed	No
6		Chakripuram	Ayyappa	11KV	Keesar	23.45	01.37	01.52		No visible fault	No
7		Chengicherla	My Villas	11KV	Keesar	01.30	02.30	01.00		11KV Polymer Disc failed at Kanakadurga Nagar	No
8		Chengicherla	My Villas	11KV	Keesar	3:30	4:45	1:15		11KV 2Nos Pin insulators failed at Cherlapally Indl Area	No
1	HYD N	Madhapur	Patrika Nagar	11KV	Jublee Hills	00.35	02.30	01.55	OL-R&Bph	Sparkings on Auto Reclosure at Milan Tower	At 01.25 hrs. Partial feeder charged (10 Amps)
2		Pragatools	Pragathi Pack	11KV	Bowenpally	0:45	2:35	1:50	EL,OL-Rph	Snapped 11KV Nagarjuna Singode fdr line fallen on 11KV Lines & 3No. HG fuses blown off at IDA Kukatpally	No
3		Jubilee Hills	Art Gallery	11KV	Jublee Hills	3:55	5:20	1:25	EL	Breaker problem at SS	At 04:30 hrs. Partial fdr charged arranged B/F on 11KV Benz Show Room fdr
1	HYD S	Exhibition	Seetharampet	11KV	Begumbazar	06.04	07.05	01.01	EL	AB Cable fault at Fatafat Gally	No
2		C.R.P.F	Maisaram	11KV	Charminar	23:30	0:30	1:00	EL,OL-Rph	Cable fault at Akhil Khetan	No
1	HYD C	Chilkaiguda	Bholakpur	11KV	Saifabad	02.40	04.17	01.37	EL,OL	No Visible fault	Arranged B/F on 11KV Kawadiguda fdr