

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		5		5		5			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	10	0	10	0	10	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	1	3	1	3	1			
2	NLG	144	988		11		11		11			
3	MDK	107	933		3		3		3			
4	SDPT			1	10	1	10	1	10			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	25	4	25	4	25	0	0	
	Grand Total	1082	6468	4	35	4	35	4	35	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.07.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Gadwal	33KV	Gadwal	01.45	08.30	06.45	E/L	feeder bus isolator to breaker linmb connected jumper female contact replaced	Gadwal	No
2		Chinnamarror	Weepangandla	33KV	Wanaparthi	11.00	11.25	00.25		Weepangandla Feeder loads tag on to 33KV Kalwarala Feeder	Chinnamarror	Weepangandla Feeder loads tag on to 33KV Kalwarala Feeder at 11:25Hrs
3		Wanaparthi	Kodair	33KV	Wanaparthi	20.05	20.40	00.35	O/L	for AB Switch open at Rajapur SS	Wanaparthi	No
1	MDK	Thunkibollaram	Chilasagar	33KV	Siddipet	03.32	05.55	02.25		Feeder tripped on heavy OL falt during heavy Rain fall dip accord at the sometime		-

TSSPDCL - LMRC / Corporate office

Date: 17.07.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karvena	Kothur	11KV	Jadcherla	08.38	12.13	03.35		BD due to 11 kv wire cut near Tatiparthi (v)	-
1	NLG	Dirsenapally	Chinnanemila	11KV	Suryapet	03.30	07.00	03.30	E/L	Conductor snapped	-
2		Velugupally	Velugupally	11KV	Suryapet	07.00	08.40	01.40	E/L	Insulator flashover	-
3		Palakeedu	Janpahad indl	11KV	Huzurnagar	03.00	05.30	02.30	EL	11 kv jumper cut	-
4		Palakeedu	G G Palem	11KV	Huzurnagar	14.30	15.10	00.40	EL	11 kv jumper open	-
5		Ponugodu	Kothagudem	11KV	Huzurnagar	14.09	16.09	02.00	EL	11 kv inslater failed	-
6		Kalmalcheruvu	Kalmalcheruvu	11KV	Huzurnagar	18.51	20.30	01.39	EL	11 kv line snapped	-
7		Koppole K	Koppole	11KV	Nalgonda	07.00	09.00	02.00	E/L	11 KV line cut	-
8		Arlagaddagudem	Mangalapally	11KV	Nalgonda	06.20	07.30	01.10	E/L	11 KV Insulator failed	-
9		Nakrekal	Nomula	11KV	Nalgonda	14.20	15.45	01.25	E/L	Ht/LT line milting	-
10		Mamidala	Aregudem	11KV	Nalgonda	08.40	10.55	02.15	E/L	Tree fallen on line	-
11		Nandam	Anajipur	11KV	Bhongiri	15.00	17.00	02.00	E/L	insulator Faield	-
1	MDK	Bollaram - II	Rupa	11KV	Patancheru	13.07	15.59	02.52		B/D Due to tree branches fallen on the line	-
2		Pati	Pati	11KV	Patancheru	14.40	15.45	01.05		B/D Due to Jumper Cut	-
3		Narsapur	Reddypally	11KV	Medak	06.35	10.50	04.15		B/D Due to Insulator Failure	-
1	Siddipet	Husnabad	Regulapally	11KV	Siddipet	18.32	23.20	04.48		Due to Rain	-
2		Shanigaram	Gundareddypally	11KV	Siddipet	18.30	23.00	04.30		Due to Rain	-
3		Koheda	Kurella	11KV	Siddipet	15.50	17.40	01.50		Due to Rain	-
4		Musthyal	Cherial Agl	11KV	Siddipet	16.10	17.10	01.00		Due to Rain	-
5		Gurjakunta	Vecharni	11KV	Siddipet	16.50	20.30	03.40		Due to Rain	-
6		Komuravelly	Posanpally	11KV	Siddipet	18.30	22.10	03.40		Due to Rain	-
7		Bekkal	Kutigal	11KV	Siddipet	18.00	23.40	05.40		Due to Rain	-
8		Dhulimitta	Arjunpatla	11KV	Siddipet	14.45	23.20	08.35		Due to Rain	-
9		Regulapally	Seelapur	11KV	Siddipet	18.32	23.50	05.18		Due to Rain	-
10		Koheda	Theegalakuntapally	11KV	Siddipet	17.40	18.10	00.30		Due to Rain	-
1	RR N	Jagathgirigutta	Maqdoom Nagar	11KV	Medchal	01.05	03.35	02.30	BD	Tree Branches fallon on the 11KV Line at Maqdoom nagar	-
2		Athiwelly	Athiwelly	11KV	Medchal	17.20	18.55	01.35	BD	11KV Line cut & replacement at Athiwelly Village	-
3		Jeedimetla-II	Apuroopa Colony	11KV	Jeedimetla	10.55	12.05	01.10	OL	Lizahard Fallen On The 11kv Line at Apuroopa Colony	-
4		Jeedimetla-II	Apuroopa Colony	11KV	Jeedimetla	14.50	16.05	01.15	EL/OL	Saree fallen On the 11kv Line At Modi builder	-
5		Suraram	Matrix	11KV	Jeedimetla	05.10	06.48	01.38	EL/OL	11kv Conductor snapped at Myloon Company	-
1	RR E	Uppal	Bank Colony	11KV	Habiguda	15.05	16.05	01.00		11KV Disc failed near Uppal Municipality Office	-
2		Keesara	Anki Reddy Pally	11KV	Keesara	14.55	16.45	01.50		11KV line cut at Keesara Gutta Chourastha	-
1	HYD N	Addagutta	Tukaram Gate	11KV	Sec-Bad	04.15	05.40	01.25	EL,OL-Rph	Cable fault at Tukaram Gate (1No. DTR kept Off)	-
2		Kalyan Nagar	A.G Colony	11KV	Banjarahills	20.06	21.45	01.39	EL,OL-R&Bph	CT Problem at SS	Arranged B/F on 11KV Vengalrao Nagar feeder
1	HYD S	Malakpet B-Block	Ekalavya Nagar	11KV	Asmangadh	15.50	17.15	01.25	EL	No Visible Fault	-