

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044	0	5	0	5	0	5			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	1	5	1	5	1	5			
3	MDK	107	933	2		2		2				
4	SDPT			1	7	1	7	1	7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>4</b>	<b>13</b>	<b>4</b>	<b>13</b>	<b>4</b>	<b>13</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>4</b>	<b>21</b>	<b>4</b>	<b>21</b>	<b>4</b>	<b>21</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 20.07.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Mothkur	Kapraipally	33KV	Bhongiri	06.30	09.15	03.15	E/L	Insulator Failed	Mothkur	-
1	MDK	Pashamailaram	APL IV	33KV	Sangareddy	00.58	14.50	13.52		BD due to Bus Jumper snapped	Pashamailaram	-
2		Kowdipally	Ch.Ghanpur	33KV	Medak	01.55	06.25	04.30		BD due to Insulator failed	Kowdipally	-
1	SDP	Siddipet	Raghavapur	33KV	Siddipet	17.25	23.50	06.25		tree branches fall in line	Siddipet	

## TSSPDCL - LMRC / Corporate office

Date: 20.07.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gangapur	Gangapur	11KV	Jadcheral	11.00	12.00	01.00		Single phase DTR fault near Gangapur	-
1	NLG	Thirumalagiri	Thatipamula	11KV	Suryapet	07.15	11.00	03.45	E/L	Insulator flashover	-
2		Reddygudem	Gorentla	11KV	Suryapet	12.30	15.20	02.50	E/L	Insulator flashover	-
3		G.T Giri	Gunjalooru	11KV	Suryapet	13.10	16.10	03.00	E/L	Conductor snapped	-
4		Velminedu	Perepally	11KV	Nalgonda	07.30	11.00	03.30	E/L	11KV Line Jumper Cut	-
5		Koppole K	Bheemaram	11KV	Nalgonda	08.35	11.40	03.05	E/L	11KV Line Insualtor Fail	-
1	Siddipet	Husnabad	Town II	11KV	Husnabad	07.25	08.00	00.35		Disk failure	-
2		Begumpet	Begumpet express	11KV	Husnabad	00.00	05.30	05.30		Heavy gale and wind	-
3		Begumpet	Begumpet express	11KV	Husnabad	09.45	11.00	01.15		11 KV Line cutting	-
4		Bejjanki	Kallepally	11KV	Gajwel	21.30	23.50	02.20		Break down	-
5		Mustyala	Mustyala	11KV	Husnabad	00.20	04.00	03.40		11 KV Line cutting(3Ph)	-
6		Mustyala	Mustyala	11KV	Husnabad	04.10	13.45	06.35		11 KV Line cutting(3Ph)	-
7		Gagillapur	Vallampatla	11KV	Husnabad	09.10	14.00	04.50		Heavy gale and wind(3Ph)	-
1	RR S	Gachibowli	Aparna	11KV	Gachibowli	17.25	18.40	01.15		11kv UG-Cable failed at Nallagandla Bridge	-
1	RR E	Sainikpuri	Ramalyam	11KV	Sainikpuri	15.30	18.00	02.30		11kv PIN Insulator failed at Defence Colony (AE)	-
2		Moula Ali	Meerpet	11KV	Sainikpuri	19.30	20.00	00.30		11Kv Pin Insulator failed at Tirumala Nagar (AE)	-
1	HYD N	Road No.13	Road No.1	11KV	Banjrahills	14.10	15.55	01.45	EL,OL	2No. Jumpers cut at Sarvy Hotel & 3Way R.M.U fault at City Center (As per SS Log Book)	-
1	HYD S	E.N.T	Jam Bagh	11KV	Begumbazar	09.55	11.00	01.05	EL,OL	Cable fault at Traffic P.S	-
2		Aliabad	Sather Bagh	11KV	Charminar	21.23	22.45	01.22	EL	HT Jumper touching to Pole & Pin Insulator flash over at Gazi Banda Kabrasthan DTR	-
1	HYD C	Toli Chowki	Paramount Hills	11KV	Mehdipatanam	02.07	03.50	01.43	EL,OL-Bph	AB Switch fault at Gate No.2	-
2		Amberpet	6 No.Road	11KV	Azamabad	21.45	22.50	01.05	EL	AB Switch fault at 6No. Cross Road	-