

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 2 | | 2 | | 2 | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | | | | | | | | |
| | Total | 606 | 3055 | 0 | 2 | 0 | 2 | 0 | 2 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 1 | | 1 | | 1 | | | | |
| 2 | NLG | 144 | 988 | 3 | 2 | 3 | 2 | 3 | 2 | | | |
| 3 | MDK | 107 | 933 | | 5 | | 5 | | 5 | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 4 | 7 | 4 | 7 | 4 | 7 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 4 | 9 | 4 | 9 | 4 | 9 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 26.07.18

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--------------------------|-----------------------|---|
| 1 | MBNR | Marikal | Gunmukla | 33KV | Makthal | 09.29 | 09.49 | 00.20 | E/L&O/L | Due to Cable Problem | Gunmukla | Alternate Supply Arranged from 33KV Jaklair Feeder at 9:49Hrs |
| 1 | NLG | Kolapaka | Bondugula | 33KV | Bhongir | 12:30 | 1:20 | 0:50 | E/L | No visible fault | Bondugula | Alternate supply taken from 33 KV Rajapet feeder |
| 2 | | Magudulapaly | Buggabaigudem | 33KV | Miryalaguda | 14.25 | 15.40 | 01.15 | E/L | HT/LT Line touched | Buggabaigudem | No |
| 3 | | Mothkur | Mothkur | 33KV | Bhongir | 14.30 | 16.30 | 02:00 | O/L | 3PH Out going Jumper Cut | Mothkur | No |

TSSPDCL - LMRC / Corporate office

Date: 26.07.18

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1 | NLG | N.G.Bandal | Konapur | 11KV | Bhongir | 14:00 | 14:40 | 16:00 | E/L | Insulator failed near Konapur Village | No |
| 2 | | Miryalaguda | Nakkalapally | 11KV | Nalgonda | 13.10 | 18.30 | 5:20 | E/L | 33KV Insulator failed | No |
| 1 | MDK | Sangareddy-II | Kalpagur | 11KV | Sangareddy | 12:00 | 14:15 | 2:15 | | Conductor snapped | No |
| 2 | | Sangareddy-II | Kandi | 11KV | Sangareddy | 10.10 | 10.20 | 00.10 | | Jumper cut | No |
| 3 | | Sangareddy-II | Kosla | 11KV | Sangareddy | 16.50 | 17.20 | 00.30 | | Jumper cut | No |
| 4 | | Cheryal | DVR | 11KV | Sangareddy | 14.00 | 16.00 | 02.00 | | Tree fallen on the 11KV line | No |
| 5 | | Patancheru town | Allwyn | 11KV | Sangareddy | 10:50 | 11:15 | 0:25 | | Jumper cut | No |
| 1 | RR N | Medchal | Ravalkole | 11KV | Medchal | 5:35 | 7:40 | 2:05 | | 11KV Jumper cut | No |
| 2 | | Medchal | Dulapally | 11KV | Medchal | 13.15 | 13.40 | 00.25 | | 100KVA T/F AB Switch opened at St Martins college | No |