

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>0</b>	



TSSPDCL - LMRC / Corporate office

Date: 31.07.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Jalalpuram	Maktha kothagudem	11KV	Suryapet	05.00	08.30	03.30	E/L	11Kv Conductor snapped	-
2		Pamanagundla	Pittampally	11KV	Nalgonda	04.20	09.50	05.30	E/L	11Kv Line Insulator Failed Under SS-3 at Pittampally (V)	-
3		Damarchrla	T.V.Gudem	11KV	Miryalaguda	13.30	17.30	04.00	E/L	Tree Fallen on the line	-
1	Siddipet	Reberthy	Reberthy	11KV	Siddipet	09.20	10.00	00.40		BD No visible fault	-
2		Dubbak	Dubbak MHQ	11KV	Siddipet	21.30	23.20	01.50		B/D (11 KV cable cutting)	-
1	RR E	VP Nagar	Ambedkar Nagar	11KV	SKP	11.02	12.10	01.08		11Kv AB Cable failed at Saibaba Temple Shiva Nagar (LM Chandra Shekar)	-
2		IDAuppai	Jersey	11KV	HBG	07.59	09.26	01.27		Tree fallen on 11kv line at IDAuppai	-
1	HYD N	R.P Nilayam	Sarawathi Nagar	11KV	VI	23.40	01.15	01.35	EL	UG Cable fault at Railway Station (1No. DTR Kept off)	-
1	HYD S	Moosarambagh	Shalivahana Nagar	11KV	VIII	18.20	19.25	01.05	EL,OL-Yph	Jumper cut at Shalivahana Nagar	-