

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988	8	28	8	28	8	28			
3	MDK	107	933	18	33	18	33	18	33			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	26	65	26	65	26	65	0	0	
	Grand Total	1082	6468	26	70	26	70	26	70	0	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kodangal	Hamsanpally	11KV	Mahabubnagar	05.10	06.35	01.25	E/L	Tree branches fallen on the line	No
2		Chinnamaroor	Velgonda	11KV	Wanaparthi	10.30	13.15	02.45	EL	Tree branches fallen on the line	No
3		Alampur	Undavelly	11KV	Gadwal	09.45	11.10	01.25	EL	Flash over disc replaced near 132KV SS	No
4		Kalwakurthy	Polkampally	11KV	Nagarkurnool	9:22	11:40	2:18	E/L	R Phase Lightening arrester Blast	No
1	NLG	Gaddipally	Medaram	11KV	Huzurnagar	6:45	11:25	4:40	E/L	11KV Line Snapped	No
2		Amaravaram	Srinivasapuram	11KV	Huzurnagar	10.00	14.10	04.10	E/L	11KV Line Snapped	No
3		Chilukur	Kondapuram	11KV	Huzurnagar	08.40	10.55	02.15	E/L	11KV Insulator failure	No
4		Jammigadda	Ambedkar	11KV	Suryapet	10.30	12.10	01.40	E/L	Tree branch fallen on the line	No
5		T Giri	Indi feeder	11KV	Suryapet	12.00	13.20	01.20	E/L	Jumper cut	No
6		Annaram	Dosapahad	11KV	Suryapet	12.00	15.30	03.30	E/L	Insulator failed	No
7		Arlagaddagudem	Arlagaddagudem	11KV	Nalgonda	05.44	08.20	02.36	E/L	11KV Disc failed	No
8		Beemaram	Koppole (K)	11KV	Nalgonda	07.00	09.56	02.56	E/L	11KV Line cut	No
9		Indugula	Mallaparaju Gudem	11KV	Nalgonda	10.40	13.20	02.40	E/L	11KV Jumper cut	No
10		Edulur	G.B Gudem	11KV	Nalgonda	13.30	15.20	01.50	E/L	11KV Line cut	No
11		Edulur	Naregudem	11KV	Nalgonda	13.30	15.00	01.30	E/L	Tree fallen on the Line	No
12		Pamanagundla	Esmail pally	11KV	Nalgonda	11.00	14.00	03.00	E/L	HT/LT line Insulator failed	No
13		Barovani Banda	N.G. Kotha Pally	11KV	Nalgonda	08.00	11.00	03.00	E/L	11KV insulators failed	No
14		Akkaram	Vaddipamula	11KV	Nalgonda	05.30	08.30	03.00	E/L	HT/LT line melting	No
15		Avanthipuram	Industrial-I	11KV	Miryalaguda	06.00	10.00	04.00	E/L	Tree banches fallen on the line	No
16		Damercherla	Damercherla Agl	11KV	Miryalaguda	06.00	15.00	09.00	E/L	Insulater failed	No
17		Damercherla	T V Gudem	11KV	Miryalaguda	07.00	15.30	08.30	E/L	Tree banches fallen on the line	No
18		Peddavoora	Thungaturthy	11KV	Miryalaguda	09.00	13.30	04.30	E/L	Conductor snapped	No
19		Peddavoora	Nayanavani kunta	11KV	Miryalaguda	08.30	13.40	05.10	E/L	Tree banches fallen on the line	No
20		Chinthapally	Chinthapally	11KV	Devarakonda	07.30	09.30	02.00	E/L	11KV Insulator failed	No
21		Chinthapally	H.M.pally	11KV	Devarakonda	07.30	09.30	02.00	E/L	11KV Insulator failed	No
22		Chinthapally	Varakala	11KV	Devarakonda	07.40	11.10	03.30	E/L	11Kv Disc failed	No
23		Chinthapally	Rayanigudam	11KV	Devarakonda	07.40	12.40	05.00	E/L	Conductor sanpped	No
24		Madhanapuram	Madhanapuram	11KV	Devarakonda	09.10	11.40	02.30	E/L	Conductor sanpped	No
25		Teeded	Gasiram Thanda	11KV	Devarakonda	12.20	13.20	01.00	E/L	Earth Fault	No
26		Bollepally	Indriyala	11KV	Bhongiri	08.00	23.00	03.00	E/L	11KV Insulator failed	No
27		Nandanam	Nandanam Indus	11KV	Bhongiri	11.55	14.50	02.50	E/L	11KV Insulator failed	No
28		Paladugu	Palakabanda	11KV	Bhongiri	3:00	4:30	1:30	E/L	11KV Insulator failed	No

1	MDK	Gaddapotharam	Matrix	11KV	Patancheru	2:25	5:25	3:00		B/D due to Tree branches fallen on the line	No
2		Gummadidala	Agrobell	11KV	Patancheru	02.40	09.30	06.50		B/d due to Pole fallen on the line	No
3		Gummadidala	Gummadidala	11KV	Patancheru	02.25	10.10	07.45		B/d due to Jumper cut	No
4		Patancheru	Santhinagar	11KV	Patancheru	02.00	06.40	04.40		B/d due to Disc failure	No
5		Pati	Shalimar	11KV	Patancheru	03.00	08.00	05.00		B/d due to Jumper cut	No
6		SOL	Markwell	11KV	Patancheru	10.55	11.35	00.40		B/D due to Tree branches fallen on the line	No
7		EPIP-I	KIRBY	11KV	Sangareddy	12.53	19.30	06.37		B/D due to Conductor snapped & Insulator fail at SUPREME STEELS	No
8		EPIP-I	Chitanya	11KV	Sangareddy	05.35	18.45	13.10		Conductor snapped	No
9		EPIP-I	MSN	11KV	Sangareddy	05.50	12.08	06.18		B/D due to Jumper cut & Insulator failure	No
10		EPIP-II	Export	11KV	Sangareddy	03.20	10.56	07.36		B/D due to Tree branches fallen on the line	No
11		EPIP-II	Padma	11KV	Sangareddy	03.20	11.45	08.25		B/D due to Tree branches fallen on the line	No
12		EPIP-III	Tyche Die Cast	11KV	Sangareddy	03.20	07.40	04.20		Conductor snapped	No
13		EPIP-III	U Form	11KV	Sangareddy	15.45	18.05	02.20		Conductor snapped	No
14		Cheryal	MYK	11KV	Sangareddy	10.45	17.50	07.05		B/D due to Insulator failure	No
15		Cheryal	Kalivemula	11KV	Sangareddy	03.25	16.10	12.45		B/D due to Insulator failure	No
16		Cheryal	Julkal	11KV	Sangareddy	03.25	17.50	14.25		Insulator failed	No
17		Kondapur	Marepally	11KV	Sangareddy	16.30	18.45	02.15		Disc failed	No
18		Kondapur	Gangaram	11KV	Sangareddy	17.05	19.05	02.00		Jumper cut	No
19		Kondapur	Terepole	11KV	Sangareddy	08.45	09.25	00.40		Jumper cut	No
20		New Collectorate	P.R.Pally	11KV	Sangareddy	03.01	03.35	00.34		Disc failed	No
21		SRD-T-I	New Post Office	11KV	Sangareddy	12.15	13.30	01.15		Tree branches fallen on the line	No
22		B.B.Pur	Burugupally	11KV	Medak	07.45	09.30	01.45		Insulator failed	No
23		M. Bhupathipur	M. Bhupathipur	11KV	Medak	01.00	09.05	08.05		Insulator failed	No
24		Suraram	S. Kondapur	11KV	Medak	00.40	10.40	10.00		Insulator failed	No
25		Reddy pally	Chippalthurthy	11KV	Medak	14.00	16.20	02.20		Insulator failed	No
26		Reddy pally	Mohd Nagar	11KV	Medak	01.00	12.30	11.30		Conductor snapped	No
27		Reddy pally	Kukatlapally	11KV	Medak	01.13	08.02	06.49		Insulator failed	No
28		Rajpet	Thimmapur	11KV	Medak	00.00	12.07	15.45		Conductor snapped	No
29		Kulcharam	Kulcharam	11KV	Medak	12.05	15.00	02.55		Tree branches fallen on the line	No
30		Kulcharam	Wariguntham	11KV	Medak	06.00	10.00	04.00		Jumper cut	No
31		Amsanpally	Amsanpally	11KV	Medak	00.32	10.50	10.18		Conductor snapped	No
32		Amsanpally	Kongode	11KV	Medak	00.32	10.30	09.58		Insulator failed	No
33		Amsanpally	Rangampet	11KV	Medak	3:10	14:00	10:50		Tree branches fallen on the line	No
1	RR S	Papireddy colony	Prem Nagar	11KV	Gachibowli	1:50	3:00	1:10		Tree branches fallen on the line	No
2		IJM	9th Phase	11KV	Kondapur	02.35	06.08	03.33		Cable End Kit failed at HIG-79	No
1	RR N	Kandlakoya	KV Reddy Nagar	11KV	Medchal	2:00	3:30	1:30		Tree branches fallen on the line	No
2		Gowdavelly	Ayodhya	11KV	Medchal	11.20	13.00	01.40		11KV Pin insulator failed at Saketh Venture	No
1	RR E	IDA Uppal	Metro	11KV	Habsiguda	22:51	0:25	1:34		11KV Cable damaged near Dumping Yard side	No

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Marriguda	Chandur	33KV	Nalgonda	7:10	11:00	3:50	E/L	33KV Line insulator failed	Chandur	No
2		Suryapet	GT Giri	33KV	Suryapet	11.00	14.55	03.55	E/L	Insulator flashover	GT Giri	No
3		Thungathurty	HPCL	33KV	Suryapet	09.15	12.45	03.30	E/L	Insulator failed	HPCL	No
4		Miryalaguda	Avanthipuram	33KV	Miryalaguda	06.30	08.30	02.00	E/L	momentary Fault	Avanthipuram	No
5		Wadapally	A.D.Pally	33KV	Miryalaguda	05.50	10.35	04.45	E/L	33KV Pin binding cut and fallen on Cross arm	A.D.Pally	No
6		Madgulapally	Thadakamalla	33KV	Miryalaguda	08.00	09.30	01.30	E/L	33KV Insulator failed	Thadakamalla	No
7		Madgulapally	B.B.Gudem	33KV	Miryalaguda	09.30	16.00	06.30	E/L	3 Nos insulator failed in same pole & Post type insulator failed on AB switch	B.B.Gudem	No
8		K.M.Pally	Nampally	33KV	Devarakonda	05.45	10.40	4:55	E/L	33KV Insulators failed	Nampally	No
1	MDK	Kandi	BDL	33KV	Sangareddy	2:55	16:30	13:35		B/D Conductor snapped in 2 & 3 Locations also 20Nos Insulator flash over	BDL	No
2		Kandi	ITW Signode	33KV	Sangareddy	02.45	10.15	07.30		B/D Insulator failed in 4 locations.	ITW Signode	No
3		Sadasivpet	Kondapur	33KV	Sangareddy	03.30	08.20	04.50		B/D due to Breaker problem	Kondapur	No
4		Sadasivpet	Jogipet	33KV	Sangareddy	01.45	04.45	03.00		B/D Insulator failed	Jogipet	No
5		Sadasivpet	Munipally	33KV	Sangareddy	02.45	06.45	04.00		B/D due to Pin Insulator failed	Munipally	No
6		Zaheerabad	Machanoor	33KV	Sangareddy	04.05	12.55	08.50		Jumper cut & CT Clamp changed	Machanoor	No
7		Jogipet	Chitkul	33KV	Sangareddy	00.50	06.15	05.25		B/D due to Insulator failed	Chitkul	No
8		Jogipet	Laxmi sagar	33KV	Sangareddy	01.20	06.25	05.05		Insulator failed & AB switch probleam	Laxmi sagar	No
9		Singoor	Muddaipet	33KV	Sangareddy	06.30	07.35	01.05		Tree branches fallen on the line near Kodur (V)	Muddaipet	No
10		Singoor	Jackwel	33KV	Sangareddy	06.40	09.55	03.15		Tree branches fallen on the line near Fish market	Jackwel	No
11		Pashamailaram	APL IV	33KV	Sangareddy	03.30	07.50	04.20		Jumper cut	APL IV	No
12		Pashamailaram	Nandigama	33KV	Sangareddy	03.06	07.40	04.34		Disc failed	Nandigama	No
13		Minpur	Podchanpally	33KV	Medak	03.30	03.55	00.25		B/D due to Tree fallen on the line	Podchanpally	No
14		Chegunta	Yeludurthy	33KV	Toopran	02.05	06.45	04.40		B/D due to Tree fallen on the line	Yeludurthy	No
15		Ramayanpet	Laxmi sagar	33KV	Toopran	01.00	05.00	04.00		Jumper cut	Laxmi sagar	No
16		Kowdipally	Salabathpur	33KV	Medak	00.38	06.15	05.37		B/D due to Tree fallen on the line	Salabathpur	No
17		Kowdipally	Venkatraopet	33KV	Medak	00.43	07.15	06.32		B/D due to Tree fallen on the line	Venkatraopet	No
18		Kowdiapally	Amsanpally	33KV	Medak	0:25	7:20	6:55		B/D due to Tree fallen on the line	Amsanpally	No