

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		11		11		11			
6	RR(N)	54	550	1	24	1	24	1	24			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	1	42	1	42	1	42	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5		5		1		4		4 no.s. 33kv still
2	NLG	144	988		4		4		4			
3	MDK	107	933	10		10		7		3		3 no.s. 33kv still
4	SDPT			3	5	3	5	2	5	1		1 no. 33kv still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	18	9	18	9	10	9	8	0	
	Grand Total	1082	6468	19	51	19	51	11	51	8	0	

TSSPDCL - LMRC / Corporate office

Date: 03.06.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Akaram	Vaddipamula	11KV	Nalgonda	10.00	11.30	01.30	EL	Tree Follow on the Line	-
2		Reddygudem	Reddygudem	11KV	Suryapet	14.20	15.30	01.10	EL	Insulator failed	-
3		Ponugodu	Ponugodu	11KV	Huzurnagar	12.10	15.30	02.20	EL	11 kv line snapped at Ponugodu village	-
4		Huzurnagar	Singaram	11KV	Huzurnagar	15.00	17.00	02.00	EL	11 kv Jumper cut at Singaram village	-
1	SDPT	33/11KV SS DHARMARAM	Potharam(J)	11KV	SDPT	00.00	10.00	10.00		B/D LINE SNAPPED	-
2		33/11KV SS BEJJANKI	KALLLEPALLY	11KV		10.00	12.00	02.00		B/D TREE BRANCH FALLEN	-
3		33/11KV SS GUGGILLA	GUGGILLA	11KV		11.25	14.44	03.19		B/D TREE BRANCH FALLEN	-
4		33/11KV SS Guruvannapet	Tapaspally	11KV		17.20	17.50	00.30		B/D GAIL AND WIND	-
5				11KV		18.55	19.25	00.30		B/D GAIL AND WIND	-
1	RR S	Manikonda	Friends colony	11KV	IBGH	19.05	20.00	00.55		11kv Jumpers opened at Huda colony 70%charged ok	-
2		Gachibowli	Aparna	11KV	Gachibowli	01.40	03.30	01.50		11KV UG Cable failed at Allind Company.	-
3		Chandanagar	Taranagar	11KV	Gachibowli	16.30	17.30	01.00		11KV Line Snapped at Indra Nagar Water Tank.	-
4		Papireddy Colony	Dubey Colony	11KV	Gachibowli	18.20	19.30	01.10		Due to Heavy Rain and Wind.	-
5		Papireddy Colony	Prem Nagar	11KV	Gachibowli	18.45	19.45	01.00		Due to Heavy Rain and Wind.	-
6		KPHB	6th Phase	11KV	Gachibowli	20.30	22.09	01.39		Due to Heavy Rain and Wind.(11KV Line Patrolling. No Visible Fault)	-
7		IIIT	APHB Colony	11KV	Gachibowli	18.55	21.22	02.27		11KV Pin Insulator Failed at DLF Gate No - 3 at APHB Colony.	-
8		IIIT	Jayabheri	11KV	Gachibowli	19.42	20.53	01.11		Cloth Fallen on the 11KV Line at Road No 3, Gachibowli.	-
9		Nanakramguda	Manjeera	11KV	Gachibowli	18.34	20.10	01.36		Due to heavy Rain and Wind. Tree Branches Fallen on the 11Kv Line near Cyber County Gopanpally	-
10		Nanakramguda	Gowlidoddi	11KV	Gachibowli	18.44	19.53	01.09		Due to heavy Rain and Wind. Tree Branches Fallen on the 11Kv Line near Jayabheri Gowlidoddi.	-
11		Nanakramguda	Church	11KV	Gachibowli	18.45	20.28	01.43		Due to heavy Rain and Wind. 11KV Pin Insulator Failure near Microsoft.	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	K P H B	Gowthami Nagar	11KV	Kukatpally	18.52	20.12	01.20	E/L	11kv Pin Insultor Failure At Srinivasa Colony Kamman	-
2		Vemana Colony	Bhavanipuram	11KV	Kukatpally	18.35	20.15	01.40	EL/OL	Due Heavy Rain	-
3		Vemana Colony	Surksha enclave	11KV	Kukatpally	18.55	20.25	01.30	EL&OL	Due Heavy Rain	-
4		J T P L	P J R enclave	11KV	Kukatpally	20.00	21.05	01.05	EL&OL	Tree Fallen On The 11kv PJR Enclave	-
5		J D M -SS-I	J E T E L	11KV	Jeedimetla	18.00	23.05	05.05	EL/OL	11kv Jumper Cut touched To Channel At Annpurana polymer Phase-I	-
6		J D M -SS-I	H M T Society	11KV	Jeedimetla	20.05	23.00	02.55	EL/OL	11kv Jumper Cut touched To Andhara bank	-
7		J D M -SS-I	Cs Wire	11KV	Jeedimetla	20.20	23.15	02.55	EL/OL	11kv AB cable Spark At Deepak Nitrates	-
8		R G K Suraram	R G K	11KV	Jeedimetla	19.30	23.15	03.45	EL/OL	Tree Fallen On The 11kv Line Block 7	-
9		R G K Suraram	Suraram Village	11KV	Jeedimetla	18.47	21.44	02.57	EL/OL	11kv UG Cable Failure At Mutaiah Basti	-
10		J D M SS-4	A A I Matha	11KV	Jeedimetla	18.34	20.32	01.58	EL/OL	11kv Line Cut At Liittle High school BhagyLaxmi colony	-
11		J D M SS-III	Ram reddy Nagar	11KV	Jeedimetla	18.15	19.30	01.15	EL/OL	11kv Jumper Cut Ram reddy Nagar	-
12		J D M SS-I	ShapuraNagar	11KV	Jeedimetla	19.55	21.40	01.45	EL/OL	11kv Jumper Cut Shapuraganagar	-
13		Subash Nagar	Jairam Nagar	11KV	Medchal	18.15	19.05	00.50		11KV Conductor Snapped at Jairam Nagar	-
14		Subash Nagar	Ramaraj nagar	11KV	Medchal	18.15	19.50	01.35		Tree fallen on the 11KV Line at OM Book	-
15		HMT	Venkanna Hills	11KV	Medchal	18.10	18.50	00.40		Tree fallen on the 11KV Line at Dattatreya Nagar	-
16		UMCC	Crusher	11KV	Medchal	20.30	21.20	00.50		11KV Conductor Snapped at lalsabguda	-
17		Kandlakoya	KV Reddy Nagar	11KV	Medchal	18.40	21.05	02.25		11KV Pin Insulator Failed at GP Pally	-
18		Aliabad	Jaganguda	11KV	Medchal	18.45	20.20	01.35		Tree fallen on the 11KV Line at Jaganguda Village	-
19		Bommarajpet	Ponnal	11KV	Medchal	19.10	20.40	01.30		11KV Conductor Snapped at Sneha farm	-
20		Medchal	Navadurga	11KV	Medchal	18.30	19.12	00.42		11KV Disc Failed at Victory Thota	-
21		Medchal	CMR	11KV	Medchal	18.56	20.20	01.24		Tree Fallen on 11KV Line at Sandeep Petrol Bunk	-
22		Ravalkole	Cheruvukatta	11KV	Medchal	18.23	20.56	02.33		Tree Fallen on 11KV Line at Madhava reddy House,Ravalkole	-
23		Shameerpet	Thumkunta	11KV	Medchal	18.20	20.50	02.30		11KV Disc Failed at Dongala Maisamma	-
24		Devarayamjal	DMC	11KV	Medchal	19.35	21.15	01.40		11KV Pole Damaged at Jhonny Poultry farm,Arkalagudda	-
1	RR E	AUTO NAGAR	LB NAGAR	11KV	SAROORNAGAR	18.25	19.40	01.15	EL	11KV LINE PERLLING NO FALT	-
2		PEDDAMBERPET	KUNTLOOR	11KV	SAROORNAGAR	12.40	14.40	02.00	EL	11KV JUMPER CUT AT KUNTLOOR	-
3		Chakripuram	Shilpa Nagar	11KV	Keesara	18.05	19.55	01.50		HT/LT line twisted at Annapurna Colony	-
4		Nagaram	PS Rao Nagar	11KV	Keesara	18.08	19.40	01.32		Tree fallen on 11kv line near RC Enclave at P.S Rao Nagar	-
1	HYD N	Prashanth Nagar	Sony Complex	11KV	VI	07.25	10.50	03.25	OL-Rph	Snapped 33KV Line fallen on 11KV Lines at Bala Nagar	-
2		Bhudevi Nagar	Yadamma Nagar	11KV	VI	18.20	19.50	01.30	EL	No Visible Fault	-
3		H.A.L	I.A.L	11KV	VI	18.20	19.20	01.00	EL,OL	No Visible Fault	Arranged B/F on 11KV Ferozeguda fdr

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water Grid	33kv	Mahabubnagar	22.56	00.00	01.04		Not Rectified	Koilkonda Water Grid	-
2		Maddur	Damargidda	33kv	Narayanapet	22.30	00.00	01.30	EL	Not Rectified	Damargidda	-
3		Wanaparthy	Kodair	33kv	Wanaparthy	06.30	07.40	01.10	E/L & O/L	Bird Fallen on the Line at Chennaram(V)	Kodair	-
4		Gadwal	Nandinne	33kv	Gadwal	23.58	00.00	01.02	E/L & O/L	Not Rectified	Nandinne	-
5		Alampur	Shanthinagar 1	33kv	Gadwal	23.50	00.00	01.10	EL	Not Rectified	Shanthinagar 1	-
1	MDK	Bollaram	Agarwal Globle steel	33kv	Sangareddy	18.55	19.55	01.00		B/D due to heavy gail & wind	Agarwal Globle steel	-
2		Bollaram	Coca cola	33kv	Sangareddy	20.05	21.25	01.20		B/D due to heavy gail & wind	Coca cola	-
3		Bollaram	Shathavahana	33kv	Sangareddy	21.00	22.20	01.20		B/D due to jumper cut heavy gail & wind	Shathavahana	-
4		Pashamailaram	BOC	33kv	Sangareddy	19.15	00.00	04.45		Still under B/D	BOC	-
5		Gummadidala	Gummadidala	33kv	Patancheru	17.35	22.05	04.30		B/D due to tree branches fallen on the line	Gummadidala	-
6		Zaheerabad	Chota Hyderabad	33kv	Zaheerabad	12.45	13.30	00.45		B/D due to jumper cut heavy gail & wind	Chota Hyderabad	-
7		Kandi	Sangareddy- I	33kv	Sangareddy	17.00	00.00	08.00		Still under B/D	Sangareddy- I	-
8		Kandi	Sangareddy - II	33kv	Sangareddy	17.00	00.00	08.00		Still under B/D	Sangareddy - II	-
9		Sadasivapet	Jogipet	33kv	Sangareddy	18.40	21.45	03.05		B/D due to heavy gail & wind	Jogipet	-
10		Kowdipally	Venktraopet	33kv	Medak	18.20	21.20	03.00		B/D due to conductor snapped	Venktraopet	-
1	SDPT	Chandlapur	Jakkapur	33kv	SDPT	16.23	16.48	00.25		Heavy Air	Jakkapur	-
2		Gajwel	Jagadev pur	33kv	SDPT	20.05	00.00	03.55		Due to Jumper cut, still under B/D	Jagadev pur	-
3		Thunki Bollaram	Vantimamidi	33kv	SDPT	19.35	20.45	01.10		OL	Vantimamidi	-
1	RR N	132KV Medchal	33KV Keshavaram	33kv	Medchal	17.50	22.08	04.18	BD	33KV Pin Insulator Failed at SC Colony,Pudur	33KV Keshavaram	-