

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		8		8		8			
8	Hyd	194	1044									
	Total	606	3055	0	10	0	10	0	10	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	2	5	2	4	2	1		1 No. 33kv still
2	NLG	144	988	1	2	1	2	1	2			
3	MDK	107	933	3	17	3	17	3	17			
4	SDPT			1	12	1	12	1	12			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	10	33	10	33	9	33	1	0	
	Grand Total	1082	6468	10	43	10	43	9	43	1	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kotha Mogara	Kotha Mogara	11kv	Jadcherla	11.00	13.10	02.10		11KV Jumper cut near Kotha Molgara	-
2		Kaverammamet	Bandamidipally	11kv	Jadcherla	07.30	10.00	02.30		11KV Jumper cut near Jayaprakash	-
1	NLG	Gondriyala	Gondriyala	11kv	Huzurnagar	05.00	08.00	03.00	E/L	Jumper cut	-
2		Cheedella	G.M.Puram	11kv	Suryapeta	14.30	17.05	02.35	E/L	Disk failed	-
1	MDK	EPIP-III	JEEVAN PALYMOR	11kv	Sangareddy	12.20	18.28	06.08		B/D DUE TO LINE SNAPED AT LNT & SIGWIL	-
2		ISNAPUR	IDEA-RUDRARAM	11kv	Sangareddy	05.20	10.44	05.24		B/D DUE TO JUMPERS CUT,LINE CUT & DISK FAIL AT ISNAPUR CHERUVU CATT	-
3		ISNAPUR	WEDIA	11kv	Sangareddy	13.05	14.05	01.00		B/D DUE TO 11KV JUMPER CUT AT ISNAPUR SS	
4		ISMALIKHANPET	IDUSTRIAL	11kv	Sangareddy	07.40	08.40	01.00		B/D DUE TO NO FAULT FOUND	
5		RUDRARAM	LAKDARAM & MYK	11kv	Sangareddy	13.40	15.10	01.30		B/D DUE TO PARA GREEN COMPANY AB SWITCH PROBLEM & POLE BREAK	
6		ISNAPUR	KOLLUR	11kv	Sangareddy	00.00	16.30	16.30		B/D DUE TO 11KV DISK FAIL AT NANDIGAMA ROAD,INDIRAMMA COLONY ISNAPUR FROM 03.06.2018 TO 04.06.2018 CONTINUE B/D	
7		Gaddapotharam	Matrix	11kv	Patancheru	07.20	08.55	01.35		BD DUE TO CONDUCTOR SNAPPED	
8		Jinnaram	Vupla	11kv	Patancheru	13.10	17.20	04.10		BD DUE TO CONDUCTOR SNAPPED	
9		Medak	Ausulapally	11kv	Medak	12.55	18.00	05.05		B/D DUE TO TREE FALL ON 11KV WIRE AT AVUSULAPALLY	
10		Dharipally	Bhagirathpally	11kv	Medak	00.00	18.00	18.00		B/D DUE TO POLE BROKEN	
11		Narsapur	Narayanpur	11kv	Medak	00.00	12.00	12.00		B/D DUE TO 11KV DISC FAILURE & TREE FELL ON 11KV WIRE	
12		Chippalthurthy	Jakkapally	11kv	Medak	02.40	05.15	02.35		B/D DUE TO TREE FALL ON 11KV WIRE AT IBRAHIMBAD	
13		Lingapur	Lingapur	11kv	Medak	13.40	18.00	04.20		B/D DUE TO JUMPER CUT	
14		Moosapet	Kokya thanda	11kv	Medak	00.00	13.00	13.00		B/D DUE TO 11KV JUMPER CUT	
15		Ch Ghanpur	Wariguntham	11kv	Medak	06.20	08.20	02.00		B/D DUE TO 11 KV PHASE TO PHASE AT THUKKARAM THANDA	
16		Gadipeddapur	Gadipeddapur	11kv	Medak	02.00	07.00	05.00		B/D DUE TO 11 KV JUMPER CUT	
17		H.Ghanpur	Aurangabad	11kv	Medak	13.40	17.50	04.10		B/D DUE TO TREE FALL ON 33KV LINE	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	Pedda Cheekode	Pedda Cheekode	11kv	SDPT	08.00	18.00	10.00		Jampar Cutting at 11 KV & Boad earthing	
2		Jangapally	Jangapally	11kv		00.00	06.00	06.00		Due to gale and wind PMI Rectified	
3		Jangapally	Veera Reddypally	11kv		00.00	11.00	11.00		Pole Damage at Veera Reddypally Village	
4		Pedda Chepyal	Pedda Chepyal	11kv		09.00	14.00	05.00		Fall on tree at 11KV wire at Chinna Thadapakally Village	
5		Nangunoor	Nagarajupally	11kv		11.05	12.20	01.15		Fall on tree breanches at 11 KV wire	
6		Kondamrajupally	Gattlamalyal	11kv		20.05	20.55	00.50		LT line wire cutting	
7		Ponnal	Ponnal	11kv		00.00	10.30	10.30		Trasfarmar fail	
8		Ponnal	Rangadamapally	11kv		00.00	15.15	15.15		Fall on tree at 11KV wire	
9		33/11Akkannapet	Pakeernai Thanda	11kv		09.00	14.50	05.50		SS-25 DTR Line snapped (cut)	
10		33/11KV Katkur	Mallaram	11kv		04.40	08.50	04.10		Due to gale and wind	
11		33/11KV Komuravelly	Inapur&Posanpally	11kv		03.15	08.50	05.35		Due to gale and wind PMI Rectified	
12		33/11KV Guruvannapet	Thapasally	11kv		00.00	06.00	06.00		Due to gale and wind PMI Rectified	
1	RR N	Aleap	Madhuranagar	11kv	Kukatpally	04.00	05.00	01.00	EL/OL	11kv line Disk Failure at Madhuranagar	-
2		Shameerpet	Anthaipally	11kv	Medchal	16.15	18.25	02.10		11KV Disc failed at Upparpally Village	-
1	RR E	HAYATH NAGAR	HAYATH NAGAR	11kv	SAROORNAGAR	17.30	18.40	01.10		11KV LINE PERLLING NO FALT	-
2		MOTHER DAIRY	GANESH NAGAR	11kv	SAROORNAGAR	11.48	14.40	02.52		11KV LINE CUT AT VENKATSHWER COLONY ROAD NO 7	-
3		MOTHER DAIRY	GANESH NAGAR	11kv	SAROORNAGAR	17.25	20.20	02.55		11KV LINE PERLLING NO FALT	-
4		Keesara	Vardhana	11kv	Keesara	18.40	19.30	00.50		Line patrolling but no visible fault	-
5		Aushapur	NFC Nagar	11kv	Keesara	17.00	18.20	01.20		11KV line cut at NFC Nagar Committee Hall	-
6		Aushapur	Sandupatlaguda	11kv	Keesara	17.00	20.00	03.00		Line patrolling but no visible fault and AB switch opened and 2 T/F Off	-
7		Aushapur	Aushapur	11kv	Keesara	17.00	20.10	03.10		Line patrolling but no visible fault and AB switch opened and 2 T/F Off	-
8		Aushapur	Madharam	11kv	Keesara	17.00	21.20	04.20		11KV Pin Insilatour Failed at Madharam	-

TSSPDCL - LMRC / Corporate office

Date: 04.06.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220KV Palkonda	Bhoothpur	33kv	Mahabubnagar	23.36	00.00	00.24	E/L&O/L	Not Rectified Due to Heavy Rain	Bhoothpur	-
2		Maddur	Mogalmadka	33kv	Narayanpet	22.10	23.00	00.50	E/L	Due to Heavy Rain & Wind	Mogalmadka	-
3		Chinnamaroor	Velgonda	33kv	Wanaparthi	23.05	23.25	00.20	E/L	Due to Heavy Rain & Wind	Velgonda	-
4		Nagarkurnool	Rakonda	33kv	Nagarkurnool	22.22	00.40	02.18	E/L	Due to Heavy Rain & Alternate Supply From Telkapally At 00:40Hrs	Rakonda	-
5		Nagarkurnool	Telkapally	33kv	Nagarkurnool	21.30	23.27	01.57	E/L	Due to Heavy Rain & Wind Tallpally AB Switch Opened	Telkapally	-
1	NLG	Bibinagar	Kondamadugu	33kv	Bhongiri	16.33	17.40	01.07	EL/OL	R Phase jumper cut in Bibinagr 132 SS	Kondamadugu	-
1	MDK	R.C.Puram	ANNAPURNAFOILS	33kv	Patancheru	06.50	13.55	07.05		BD due to Conductor snapped at railway gate	ANNAPURNAFOILS	-
2		Narayankhed	Sirgapur	33kv	Jogipet	08.15	09.30	01.15		BD due to tree fallen on line	Sirgapur	-
3		Medak	Ramayampet	33kv	Medak	12.56	20.38	07.42		BD due to tree fallen on line	Ramayampet	-
4	SDPT	132KV DUDEEDA	Kondapaka	33KV	SDPT	10.40	11.20	00.40		No visible fault	Kondapaka	-