

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		11		11		11			
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>17</b>	<b>0</b>	<b>17</b>	<b>0</b>	<b>17</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	10	9	9	9	9	9			1-33KV Still
2	NLG	144	988	1	9	1	9	1	9			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>11</b>	<b>20</b>	<b>10</b>	<b>20</b>	<b>10</b>	<b>20</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>11</b>	<b>37</b>	<b>10</b>	<b>37</b>	<b>10</b>	<b>37</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 05.04.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Surya Jyothi	33KV	Rajapur	16.05	00.30	08.25		1No Disc Insulator Failed & Removing of Tree Near Srinath Rotappa Company	Surya Jyothi	-
2		Marikal	Eklaspur	33KV	Narayanpet	02.20	08.50	06.30		5Nos Insulators Damaged Near 33KV Eklaspur SS.	Eklaspur	-
3		Gadwal	Nandinne	33KV	Gadwal	22.35	07.30	08.55		Due to Rain	Gadwal	-
							06.05.18					
4		Wanaparthy	Solipur	33KV	Wanaparthy	00.30	05.45	05.15		Due to Wind & Rain	Solipur	-
5		Wanaparthy	Rajapur	33KV	Wanaparthy	00.05	00.15	00.10		Due to Wind & Rain	Rajapur	Alternate Supply Arranged From Kodair at 00:15Hrs
6		Wanaparthy	Revally	33KV	Wanaparthy	00.15	02.25	02.10		Due to Wind & Rain	Revally	-
7		Chinnamaroor	Jetprole	33KV	Wanaparthy	02.30	07.45	05.15		Due to LA Failed	Jetprole	-
8		Amarchinta	Atmakur	33KV	Wanaparthy	02.05	06.40	04.35		Due to Insulators Damaged at Amarchinta Petrol Pump	Atmakur	-
9		Amarchinta	Chandra Gattu LIFT	33KV	Wanaparthy	02.06	06.37	04.31		for Damaged insulator Replacement at Atmakur Starting Point	Chandra Gattu LIFT	-
10	Achampet	Inole	33KV	Nagarkurnool	04.40	06.55	02.15		for B Phase LA Blast	Inole	-	
1	NLG	Madgulapally	Buggabaigudem	33KV	Miryalaguda	16.30	21.40	05.10	E/L	33KV Insulator failed near Seethya Thanda (v)	Buggabaigudem	-

## TSSPDCL - LMRC / Corporate office

Date: 05.04.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Thirumalapur	Tirumalapur	11KV	Jadcherla	08.30	12.30	04.00		11KV wire Cut Near Bodagutta Tanda	-
2		Thirumalapur	Donlapally	11KV	Jadcherla	09.00	14.30	05.30		11KV Insulator Failure Near Dondlapally(V)	-
3		KothaMolgara	Elikicherla	11KV	Jadcherla	05.30	09.00	03.30		11KV Phase to Phase Near Elikicherla( V)	-
4		KothaMolgara	KothaMolgara	11KV	Jadcherla	06.00	11.30	05.30		Tree Fallen On The 11KV Line Near Chinna Kappeta (V)	-
5		Boothpur	Boothpur@	11KV	Jadcherla	04.00	09.45	05.45		11KV Phase to Phase Near Hasnapur( V)	-
6		Gangapur	Alwanpally	11KV	Jadcherla	04.30	09.00	04.30		11KV Disc failure Near cotton Market Side	-
7		Gangapur	industrial	11KV	Jadcherla	02.00	06.00	04.00		11KV Wire Cut Near Cottonmarket Side	-
8		Janampet	Polkampally	11KV	Jadcherla	11.20	14.20	03.00		11KV Disc failure Near Polkampally( V)	-
9		Balanagar	Nerellapally	11KV	Jadcherla	10.00	12.50	02.50		Bird Fallen on The 11 KV Line Near bavoji Tanda	-
1	NLG	Marriguda	P.M.pally	11KV	Devarakonda	05.00	09.00	04.00	E/L	11Kv 2No. Insulator failed	-
2		Chandampet	Jajlapuram	11KV	Devarakonda	09.30	11.00	01.30	E/L	HT/HT Line Melt	-
3		Devarakonda	KB.Pally	11KV	Devarakonda	07.15	09.20	02.05	E/L	1ph- DTR Prblam	-
4		Padamatipally	Thurppally	11KV	Devarakonda	07.00	08.30	01.30	E/L	11Kv Jemper Cut	-
5		Muddikonda	Muddikonda	11KV	Devarakonda	06.20	09.00	02.40	E/L	11Kv Conductor Snaped	-
6		Yerkaram	Ramannagudem	11KV	Suryapet	13.00	14.30	01.30	E/L	11Kv Disk failed	-
7		Eduloor	G.B.Gudem	11KV	Nalgonda	05.00	09.00	04.00	E/L	11 KV Jumper Cut	-
8		Narketpally	M.Yedavally	11KV	Nalgonda	10.20	13.05	02.45	E/L	11 KV Disc Insulator Failed	-
9		Arlagaddagudem	Suraram	11KV	Nalgonda	04.30	06.50	02.20	E/L	11KV Insulator Failed	-
1	MDK	Isnapur	IDA Rudraram	11KV	Sangareddy	16.20	18.20	02.00		B/D Due to Jumper cut	-
2		Kulcharam	Appojipally	11KV	Medak	08.05	10.20	02.15		B/d due to 11 KV jumper cut.	-
1	RR S	Gachibowli	Gopanpally	11KV	Gachibowli	14.25	15.25	01.00		11kv Jumper touched to Iron pole at Nursary, LABS Opened at Nallagandla Huda	-
2		Ibrahimbagh	Military-I	11KV	Ibrahimbagh	17.33	18.38	01.05		Tree branches fallen on 11KV line at Taramathi	-
1	RR N	Mayurinagar	Ram Nareshnagar	11KV	KKP	07.12	08.20	01.08	EL/OL	line petrolling No Visible falt	-
2		Jagathgirigutta	Shiridi Hills	11KV	Medchal	15.05	17.25	02.20	BD	11KV Cable kit Failed (11KV Line AB Switch Opened at RGK Block-V)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Nacharam	Chandamama	11KV	Keesara	18.00	18.46	00.46		Tree branches fallen on 11kv line near Road No.10 at IDA Nacharam	-
2		Kushaiguda	Rukminipuri	11KV	Sainikpuri	06.30	07.20	00.50		11Kv UG cable failure at Srinivasa Nagar (AE/SKP)	-
3		VP Nagar	Ambedkar Nagar	11KV	Sainikpuri	08.07	08.45	00.38		UG Cable failure at AN Colony (AE/OP)	-
4		HAYATH NAGAR	RAGAVENDRA COLONY	11KV	SAROOR NAGAR	17.30	18.30	01.00	EL/OL	11KV DISK FAIL AT RAGAVENDRA COLONY	-
5		MOTHER DAIRY	GANESH NAGAR	11KV	SAROOR NAGAR	17.25	19.25	02.00	EL	11KV LINE PERLLING NO FALT	-
6		MARUTHI NAGAR	ALKAPURI	11KV	SAROOR NAGAR	16.04	18.20	02.16	OL	BRID FALL ON 11KV LINE & 11KV BAKER PRABLUM & REPLSED AT SS	-
7		MARUTHI NAGAR	YADAV NAGAR	11KV	SAROOR NAGAR	17.17	19.07	01.50	EL/OL	11KV LINE PERLLING NO FALT	-
8		RR COURT	SIRI NAGAR	11KV	SAROOR NAGAR	17.37	18.51	01.14	EL/OL	11KV LINE AB SWITCH OPEN AT RTC COLONY	-
9		PEDDAMBERPET	KOHEDA	11KV	SAROOR NAGAR	00.00	03.00	03.00	EL	TREE BRACHANS FALL ON 11KV LINE AT MUNAGANOUR	-
10		PEDDAMBERPET	INDUSTRIAL	11KV	SAROOR NAGAR	17.45	19.45	02.00	EL/OL	11KV INSULATER FAIL AT PEDDAMBERPET	-
11		MARUTHI NAGAR	YADAV NAGAR	11KV	SAROOR NAGAR	19.25	20.34	01.09	EL	TREE BRACHANS FALL ON DTR AB SWITCH AT ALKAPURI ROAD NO 3	-
1	HYD S	Kandikalgate	Patel Nagar	11KV	III	19.55	21.12	01.17	EL	Cable fault	Arranged B/F on 11KV Gowlipura fdr
1	HYD C	Golnaka	Moulana Azad Nagar	11KV	II	02.02	03.30	01.28	EL,OL	Cable fault at Tourist Hotel	Arranged B/F on 11KV Harazpenta & 11KV Tourist Hotel feeders