

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	15	3	15	3	15			
2	NLG	144	988		7		7		7			
3	MDK	107	933	1								1-33KV Still
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	22	3	22	3	22	0	0	
	Grand Total	1082	6468	4	24	3	24	3	24	0	0	

TSSPDCL - LMRC / Corporate office

Date: 06.06.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amangal	Talakondapally	33KV	Jadcherla	07.50	09.40	01.50	E/L	Break Down No Visibule Fault	Talakondapally	-
2		Alampur	Shanthinagar -1	33KV	Gadwal	07.12	08.12	01.00	O/L	for Insulator Replacment near kalkuntla (vi)	Shanthinagar -1	-
3		Wanaparthy	Solipur	33KV	Wanaparthy	07.15	08.15	01.00	E/L	for Jumpers Open at Kandur SS ,33KV Insulator & AB Switch Replacement Wadepally Village	Solipur	-
1	MDK	Zaheerabad	Mannapur	33KV	Zaheerabad	19.50	00.00	04.10		B/D Still Continue due to insulators failure	Mannapur	-

TSSPDCL - LMRC / Corporate office

Date: 06.06.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kaverammamet	Bandamidipally	11KV	Jadcherla	06.50	09.40	02.50		11kv Disk fail near Macharam	-
2		Kaverammamet	Industrial	11KV	Jadcherla	02.20	07.00	04.40		11 KV jumper cut near Macharam	-
3		Polepally	Vallur	11KV	Jadcherla	02.00	08.00	06.00		Phase to Phase near Chinnapally	-
4		Konded	Chinna Adirala	11KV	Jadcherla	01.45	02.45	01.00		11 KV jumper cut near Chinna Adirala	-
5		Gnagapur	Gnagapur	11KV	Jadcherla	01.45	07.00	05.15		11 KV jumper cut near Gollapally	-
6		Gnagapur	Industrial	11KV	Jadcherla	01.45	07.00	05.15		Tree fallen the line near Sneha Company	-
7		Balanagar	Mothiganapur	11KV	Jadcherla	01.05	08.00	06.55		Tree fallen the line Navadurga Company	-
8		Balanagar	Kethireddypally	11KV	Jadcherla	01.15	08.00	06.45		Pin Binding fail near Ekavaipally	-
9		Gundlapotlapally	Kallepally	11KV	Jadcherla	09.00	11.00	02.00		11 KV jumper cut near Galigudem	-
10		Rajapur	Mallepally	11KV	Jadcherla	04.00	11:30	07.30		11 KV jumper cut near Rajapur	-
11		Thirumalapur	Dondlapally	11KV	Jadcherla	02.30	10.00	07.30		11kv Disk fail near Ragapur	-
12		Thirumalapur	Khanapur	11KV	Jadcherla	02.30	11.30	09.00		11 KV jumper cut near Khanapur	-
13		Pedda Revally	Chinna Revally	11KV	Jadcherla	08.40	12.40	06.00		Insulator fail near Cinna revally & Wire cut near Pochammagaddathanda	-
14		Kollur	Depally	11KV	Jadcherla	02.00	08.30	06.30		Wire cut near Depally	-
15		Boothpur	Boothpur®	11KV	Jadcherla	06.00	09.00	03.00		11 KV jumper cut near Dikya thanda	-
1	NLG	Tekumatla	Rayinigudem	11KV	Suryapet	12.40	14.35	01.55	EL	Conductor snapped	-
2		Akupamula	Kodandaram Puram	11KV	Huzurnagar	15.30	20.30	05.00	EL	Due to 11Kv Disk Failure	-
3		Bethavolu	chennarigudem	11KV	Huzurnagar	16.00	21.00	05.00	EL	Due to Pole damges occurred	-
4		Eduloor	G.B.Gudem	11KV	Nalgonda	12.26	15.30	03.04	EL	11 KV Jumper Cut	-
5		Nakrekal	Mandra	11KV	Nalgonda	06.00	11.00	05.00	EL	11 KV Insulator Failed	-
6		Endugula	Endugula	11KV	Nalgonda	05.40	08.26	02.46	EL	11 KV Jumper Cut	-
7		Urumadla	Thalla Vellamla	11KV	Nalgonda	03.00	09.00	06.00	EL	11KV Line Cut	-
1	RRN	Subash Nagar	Suchitra	11KV	Medchal	23.55	00.35	00.40		11KV Cable end kit failed at Green park (Back feeding Arranged)	-
2		GP Pally	Dulapally	11KV	Medchal	03.30	04.40	01.10		Tree fallen on the 11KV Line at DRS School Back side	-