

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	5	5	5	4	5	1		1 No. 33kv still
2	NLG	144	988		8		8		8			
3	MDK	107	933	2	3	2	3	2	3			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>7</b>	<b>16</b>	<b>7</b>	<b>16</b>	<b>6</b>	<b>16</b>	<b>1</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>7</b>	<b>24</b>	<b>7</b>	<b>24</b>	<b>6</b>	<b>24</b>	<b>1</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 08.06.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Machanpally	33KV	Mahabubnagar	13.40	14.10	00.30	EL	Isolator Opened Bandameedipally Towards Machanapally	Mahabubnagar	-
2		Maddur	Mogalmadka	33KV	Mahabubnagar	06.40	12.15	05.35	EL	Pin Insulator Replaced at Asanpally(V)	Maddur	-
3		Makthal	Gudeballore	33KV	Narayanpet	19.40		04.20		Not Rectified 33KV Wire cut	Makthal	-
4		Wnaparthy	Thirmalaipally	33KV	Veltoor	13.28	15.14	01.46		Alternate Supply Arranged from 132KV Wanaparthy	Wnaparthy	-
5		Wnaparthy	Singotam	33KV	Narsaipally	16.27	22.20	05.53		Insulator Failed and 33KV Brekar Problem Brekar Locked	Wnaparthy	-
1	MDK	Zaheerabad	Buchinelly	33KV	Zaheerabad	03.30	16.10	12.40		B/D due to Insulator failed & alternate supply arranged from 11KV MG Auto feeder	Zaheerabad	-
2		Kowdipally	Amsanpally	33KV	Medak	05.35	08.45	03.10		BD due to Bird fallen on line & Insulators failed	Kowdipally	-

## TSSPDCL - LMRC / Corporate office

Date: 08.06.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karkonda	Rudraram	11KV	Jadcherla	13.00	15.00	02.00		11Kv Insulator fail near Rudraram	-
2		Boothpur	Boothpur®	11KV	Jadcherla	10.15	11.25	01.10		11kv Jumper cut near Boothpur	-
3		Midjil	Veljal	11KV	Jadcherla	04.00	08.00	04.00		Phase to Phase near Midjil	-
4		Kotha Molgara	L & T	11KV	Jadcherla	13.00	15.40	02.40		Tree follon the line near Kotha Molgara	-
5		Udithyal	Macharam	11KV	Jadcherla	08.00	12.00	04.00		Phase to Phase near Macharam	-
1	NLG	Nagaram	Wardhamanukota	11KV	Suryapet	09.30	11.15	01.45	EL	Jumper cut	-
2		Mattampally	Pedaveedu	11KV	Huzurnagar	05.00	10.00	05.00	EL	Due to 11Kv line cutted	-
3		Munagala	Bharakath Gudem	11KV	Huzurnagar	06.35	10.00	03.25	EL/OL	Due to jumper cutted	-
4		Mattampally	Allipuram	11KV	Huzurnagar	03.50	09.30	05.40	EL	Due to 3Phase DTR has problem	-
5		Baironibanda	Baironibanda	11KV	Nalgonda	09.06	14.15	05.09	E/L	11KV Insulator failed	-
6		Koppole	Bheemaram	11KV	Nalgonda	08.30	11.40	03.10	E/L	11KV Jumper cut	-
7		Anatharam	Anatharam	11KV	Bhongir	07.30	12.15	05.45	EL	11Kv Disk Failed at Saileala Estate near Iron Shot And Died 1 No Sheep	-
8	Anatharam	Hanmapur	11KV	Bhongir	07.40	10.50	03.10	EL	11Kv Disk Failed at Ushanvada near ragadi gadda AB Switch Problem	-	
1	MDK	Ismailkhanpet	Arutla	11KV	Sangareddy	11.51	17.03	05.12		B/d due to Insulators failed	-
2		Bollaram I	Sugutty	11KV	Patancheru	06.40	09.05	02.25		BD due to Conductor snapped	-
3		Medak	Komtur	11KV	Medak	01.40	08.26	06.46		BD due to 11 KV Insulator Failed	-
1	RR N	Madinaguda	Miyapur	11KV	Kukatpally	03.05	05.08	02.03	EL	11kv line AB Cable Failure at SMR Metro pall, Miyapur	-
2		Nizampet	Nizampet	11KV	Kukatpally	00.50	02.35	01.45	EL	11kv line UG Cable Failure at Balaji West Kounty Apt	-
3		Aliabad	LGM Pet	11KV	Medchal	07.15	10.35	03.20	BD	11KV Post of Insulator failed at Kolthur Road	-
4		Bommarajpet	Karkalamma	11KV	Medchal	18.20	21.30	03.10	BD	11KV Line cut and replaced at Ramu Thota, Karkalamma	-
1	HYD N	LV Prasad Marg	LV Prasad Film Lab	11KV	Banjarahills	17.15	18.48	01.33	EL,OL-Rph	Cable fault at backside SS	Arranged B/F on 11KV Gymkhana Club feeder
2		MLA Colony	Shopping Complex	11KV	Banjarahills	20.15	21.30	01.15	All Indication	Sectionalizer Jumper cut at Plot No.67/A, MLA Colony	20:38 (feeder Charged but Bph loads not Shown)
1	HYD S	Arundhathi Colony	Neelam Centre	11KV	Charminar	09.20	10.58	01.38	EL,OL-Rph	Insulator flash over & Jumper cut at Saibaba Nagar	-
1	HYD C	Industrial Area	Vidya Nagar	11KV	Azamabad	04.15	06.00	01.45	EL,OL-Rph	Cable fault (3No.DTR's kept off at Adikmet Muncipal Park)	-