

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	21	1	21	1	21			
7	RR(E)	168	403		8		8		8			
8	Hyd	194	1044	1	8	1	8	1	8			
	Total	606	3055	2	37	2	37	2	37	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4	3	4	3	4	3			
2	NLG	144	988	1	11	1	11	1	11			
3	MDK	107	933	1	13	1	13	1	13			
4	SDPT			1	17		17		17			1No. 33KV feeder Still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	7	44	6	44	6	44	0	0	
	Grand Total	1082	6468	9	81	8	81	8	81	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.06.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Peddandandigama	33KV	Mahabubnagar	09.40	11.45	02.05	E/L	Pole Damaged at Kodangal Town	Kodangal	-
2		Wanaparthy	Revally	33KV	Wanaparthy	16.41	17.30	00.49	E/L	Due to Heavy Wind	Wanaparthy	-
3		Singotam	Narsaipally	33KV	Nagarkurnool	16.20	17.50	01.30	O/L	No Visible Fault	Singotam	-
4		Nagarkurnool	Bijnapally	33KV	Nagarkurnool	16.55	21.20	04.25	E/L	Due to Heavy Wind	Nagarkurnool	-
1	NLG	Miryalaguda	Matoor	33KV	Miryalaguda	17.30	21.30	04.00	EL	Jumper cut	Miryalaguda	-
1	MDK	Bollaram	Coca Cola	33KV	Patancheru	18.30	20.10	01.40		BD due to Treec baranches fallen on line	Bollaram	-
	SDPT	Habsipur	Pothareddypet	33KV	Siddipet	17.20	00.00	06.40		Jumper spark (under Breakdown)	Habsipur	-
1	RR N	132KV Medchal	33KV Kompally	33KV	Medchal	18.40	19.56	01.16	Bd	Tree Fallen on the 33KV Line at Ashok Leyland Godown,Dulapally	132KV Medchal	-
1	HYD C	132KV Imlibun	Koti Womens College	33KV	Asif Nagar	16.08	16.16	00.08	EL,OL-Bph	Cable End Kit failed in 132KV Imlibun SS	132KV Imlibun	Loads transferred onto 132KV Fever Hospital SS via 33KV Sulthan Bazar SS

TSSPDCL - LMRC / Corporate office

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown
1	MBNR	Gangapur	Industrial	11KV	Jadcherla	08.30	09.00	00.30		Tree fallen the line near Gangapur
2		Polepally	Udandapur	11KV	Jadcherla	12.20	14.20	02.00		Phase to Phase near Udandapur
3		Udithyal	Udithyal	11KV	Jadcherla	10.00	12.30	02.30		11 KV Jumper cut near Udithyal
1	NLG	Bibigudem	Munyanai Thanda	11KV	Suryapet	04.30	07.00	02.30	EL	Jumper cut
2		RC Puram	Solipeta	11KV	Suryapet	07.30	10.35	03.05	EL	Jumper cut
3		Kodur	Kodur	11KV	Suryapet	10.30	13.20	02.50	EL	Insulator failed
4		Kethepally	Cheekatigudem	11KV	Nalgonda	03.00	11.30	08.30	E/L	11KV Disc failed at SS-2
5		Koppole	Koppole	11KV	Nalgonda	05.00	10.40	05.40	E/L	HT/LT melting
6		Kethepally	Kasanagode	11KV	Nalgonda	02.00	10.00	08.00	E/L	11KV line cut and Insulator failed at SS-16
7		Katangur	Bollepally	11KV	Nalgonda	13.00	15.00	02.00	E/L	11KV Jumper cut
8		Rajupeta	Rajupeta	11KV	Nalgonda	14.00	16.00	02.00	E/L	11KV Jumper cut
9		Bilnayak thanda	Vardhapuram	11KV	Huzurnagar	00.00	04.00	04.00	E/L	11KV Disk Faild
10		Sirikonda	Namavaram	11KV	Huzurnagar	11.00	04.00	05.00	E/L	Tree Fallen the Line
11		Akupamula	Akupamula AGL	11KV	Huzurnagar	02.30	06.30	04.00	EL/OL	11KV Insuletore Failed
1	MDK	ISNAPUR	IDA I	11KV	Sangareddy	01.25	09.40	08.15		B/D Due to CT failed AB switch open at AR Pharma
2		Dundigal	Annaram	11KV	Patancheru	00.00	12.05	12.05		B/d due to 11KV Jumper cut.
3		Pillikotyal	Pillikotyal	11KV	Medak	00.00	17.30	17.30		B/d due to 11KV Jumper cut.
4		Pillikotyal	Nawabpet	11KV	Medak	00.00	17.30	17.30		B/d due to 11KV Jumper cut.
5		B.B.Pur	B.B.Pur	11KV	Medak	07.00	08.50	01.50		B/d due to 11KV line cut & 2 Insulater failed
6		Dharipally	Achampet	11KV	Medak	08.30	12.10	03.40		B/D due to Tree branches fallen on 11 KV wires
7		Narsapur	Reddypally	11KV	Medak	00.45	13.30	12.45		B/d due to 11 KV Disc failed & Conductor wire cut.
8		Avancha	Avancha	11KV	Medak	10.00	15.30	05.30		B/d due to 11 KV Insulater failed
9		Reddypally	Khajipet	11KV	Medak	00.00	11.40	11.40		B/d due to 11 KV Conductor snapped
10		Reddypally	Reddy pally	11KV	Medak	00.00	08.20	08.20		B/d due to 11 KV Conductor snapped
11		Kowdipally	Dharmasagar	11KV	Medak	08.30	15.10	06.40		B/D due to 2 No.s Insulater failed ,11 KV line cut and disc failed
12		Ch Ghanpur	Ch Ghanpur	11KV	Medak	00.00	06.40	06.40		B/d due to tree fallen on 11KV line
13		H.Ghanpur	H.Ghanpur	11KV	Medak	11.50	13.20	01.30		B/d due to 11 KV insulater failed
1		Husnabad	Pandilla	11KV	Siddipet	20.15	20.45	00.30		Due to rain
2		Potharam	Keshawpur	11KV	Siddipet	16.20	17.50	01.30		Due to rain
3		Gandiaply	Gandipally	11KV	Siddipet	09.05	11.05	02.00		Due to rain
4		Bekkal	Ladnoor	11KV	Siddipet	11.45	00.00	12.15		Due to wind
5		Nangnoor	Nagarajpally	11KV	Siddipet	22.30	11.00	12.30		Tree Branches fall on the 11 KV line
6		Nangnoor	Nangnoor Town	11KV	Siddipet	17.50	19.20	01.30		11 Kv Wire Cut

7	Siddipet	Kondamrajpally	Gatlamalyala	11KV	Siddipet	09.50	11.55	02.05		11 Kv Wire Cut	
8		Kondamrajpally	Kondamrajpally	11KV	Siddipet	10.45	12.15	01.30		Tree Branches fall on the 11 KV line	
9		Kondamrajpally	Ghanpur	11KV	Siddipet	10.45	12.10	01.25		11 KV Wire Netting	
10		Kondamrajpally	Ghanpur	11KV	Siddipet	13.40	15.40	02.00		11 Kv Wire Cut	
11		Thornal	Appanapally	11KV	Siddipet	05.00	07.50	02.50		Insulator fail	
12		Raghavapur	Bachaipally	11KV	Siddipet	11.00	16.00	05.00		11 KV Wire Netting	
13		Gonepally	Ramunipatla	11KV	Siddipet	01.05	06.30	05.25		11 KV Wire Netting	
14		Pothareddypeta	Rameshwarampally	11KV	Siddipet	21.30	05.00	07.30		11 KV Wire Netting	
15		Kondapur	Govardanagiri	11KV	Siddipet	17.20	18.05	00.45		Tree Branches fall on the 11 KV line	
16		Mustabad X road	Gadicherlapally	11KV	Siddipet	16.50	17.40	00.50		11 KV Wire Netting	
17		Mustabad X road	Kotilingalu	11KV	Siddipet	16.50	17.40	00.50		Insulator fail	
1		RR N	Mayurinagar	Prashanthnagar	11KV	Kukatpally	14.45	16.15	01.30	EL/OL	11kv line PinInsulator failure at prashanthnagar
2			Mayurinagar	Mayurinagar	11KV	Kukatpally	14.45	16.30	01.45	EL/OL	11kv line PinInsulator failure at Duplex House, Mayurinagar
3			JDMSS-II	Phase - V	11KV	Jeedimetla	18.39	20.05	01.26	EL&OL	11kv End Kit failure at Deepak Polymer's Phase V
4			JDMSS-I	Subash nagar	11KV	Jeedimetla	18.30	20.00	01.30	EL	11KV Jumper Cut at Sub-Station (Due to heavy Rain)
5			BahadurPally	Indramma Colony	11KV	Jeedimetla	14.58	16.14	01.16	EL	Tree Branches Fallen on the 11KV Line at Bahadurpally X Roads.
6			JDMSS - V	Wing Tools	11KV	Jeedimetla	00.10	01.10	01.00	EL&OL	11KV Line Disc Failure at nagarjuna Plastic Company Shahpur
7	JDMSS-I		Phase - I	11KV	Jeedimetla	20.40	21.45	01.05	EL	11KV Line AB Cable Failure at Thermo plastic Company at Phase- I Line.	
8	Suraram		Matrix	11KV	Jeedimetla	18.25	19.25	01.00	EL	Tree Branches Fallen on the 11KV Line at Mylon Company Beside Phase IV.	
9	Bowrampet		Coca-Cola	11KV	Jeedimetla	04.21	05.41	01.20	EL&OL	A Cat Fallen On the 11KV Line at Indian Petrol pump.A Cat Fallen On the 11KV Line at Indian Petrol pump.A Cat Fallen On the 11KV Line at Indian Petrol pump.	
10	JDMSS - IV		AXIS	11KV	Jeedimetla	03.40	04.45	01.05	EL&OL	HG Fuse Failure and Jumper cut at Bajranga Polymer;s company.HG Fuse Failure and Jumper cut at Bajranga Polymer;s company.HG Fuse Failure and Jumper cut at Bajranga Polymer;s company.	
11	UMCC		Gajularamaram	11KV	Medchal	09.10	09.40	00.30	BD	Tree fallen on the 11KV Line at Modi Builders Opposite	
12	Dulapally		KK Society	11KV	Medchal	02.50	04.05	01.15	BD	11KV Disc failed at Renuka Industry (Jumper opened)	
13	Dulapally		Karthikavanam	11KV	Medchal	19.11	19.43	00.32	BD	11KV Disc failed at Karthikavanam	

14		Subash Nagar	Jeedimetla	11KV	Medchal	18.44	19.24	00.40	BD	Tree Fallen on the 11KV Line at Dandamudi Enclave
15		Subash Nagar	Jairam Nagar	11KV	Medchal	18.50	19.25	00.35	BD	11KV Brass Patti cut and replaced at Hanuman Temple
16		Subash Nagar	Saibaba Nagar	11KV	Medchal	02.50	03.55	01.05	BD	No Fault
17		Athiwelly	Gubba	11KV	Medchal	00.45	04.35	03.50	BD	Tree fallen on the 11KV Line at Gubba Company
18		Bandamadaram	Barmajiguda	11KV	Medchal	06.30	09.25	02.55	BD	11KV Disc failed & Bird fallen on the 11KV Line at Rainbow City Venture
19		Bommarajpet	Ponnal	11KV	Medchal	09.50	11.15	01.25	BD	11KV Jumper Cut and replaced at Saibaba Temple, Ponnal Village
20		Devarayamjal	Kottapet	11KV	Medchal	15.15	16.40	01.25	BD	LT Cable Problem & HG fuses Removed at Chocolate Company
21		GP Pally	Maisammaguda	11KV	Medchal	05.50	06.50	01.00	BD	11KV Pin Insulator failed at Hanuman Temple
1	RR E	Mallapur-2	Ashok Nagar	11KV	Habsiguda	02.20	03.10	00.50		11KV polymer disc failed at Ashok Nagar Getla T/F
2		TATTIANNARAM	TATTIANNARAM	11KV	SAROORNAGAR	13.50	14.50	01.00	EL	TREE BRACHANS FALL ON 11KV LINE AT TATTIANNARAM
3		BAGASING NAGAR	BANK COLONY	11KV	SAROORNAGAR	19.20	21.27	02.07	EL	DTR POST OFFICE INSULATER FAIL AT TNR APPT
4		Vasanthapuri	Venkateshwara Nagar	11KV	Sainikpuri	18.17	18.57	00.40		T/F Heavy Spark at BJR Nagar (L Insp Venkateshwarlu)
5		Moula-Ali	Mirzalaguda	11KV	Sainikpuri	19.05	21.20	02.15		Tree fallen on 11Kv line at near Traffic Police Station due to Heavy Rain (AE/OP)
6		Keesara	Kadevi	11KV	Habsiguda	11.40	13.00	01.20		CTPT Outgoing cable failed at Anki Reddy Pally
7		Narapally	Narapally	11KV	Habsiguda	01.20	03.50	02.30		11KV Disc failed near Delhi Publi School
8		Narapally	Narapally	11KV	Habsiguda	18.26	21.15	02.49		Line Patrolling but no visible fault
1	HYD N	Gymkhana	Balaji Enclave	11KV	Sec-Bad	18.10	19.20	01.10	EL,OL-R&Bph	Tree branches fallen on lines at Wahini Nagar
2		H.M.T	Sri Sai Colony	11KV	Bowenpally	18.50	20.05	01.15	EL	No Visible Fault
3		Pragatools	Pragathi Pack	11KV	Bowenpally	19.08	20.28	01.20	EL,OL-Rph	Pin Insulator flash over at R.R Nagar
1	HYD S	Kandikal Gate	G.M.Chowni	11KV	Charminar	02.10	05.05	02.55	EL,OL-Rph	Cable fault
2		Salarjung	Madina	11KV	Charminar	13.45	15.45	02.00	All Indication	CT blasted at SS
3		Attapur	Asad Baba Nagar	11KV	Charminar	13.55	16.04	02.09	EL,OL-R&Bph	No Visible Fault
4		Karwan	Jiyaguda OH	11KV	Begumbazar	15.35	16.50	01.15	All Indication	Jumper cut at Sana Hotel
5		Arundhathi Colony	Neelam Centre	11KV	Charminar	15.50	17.05	01.15	EL,OL	Tree branches fallen on lines at Neelam Centre

-
-
-
-
-
-
-
-
-
-
-
-
-
-
-
-
-
-
-
-
-
Partial fdr charged at 04:10Hrs & remaining loads added on 11KV Chatrinaka fdr
Arranged B/F on 11KV Darulshifa fdr
Arranged B/F on 11KV N.M.Guda OH feeder
-
-