

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	4	1	4	1	4			
3	MDK	107	933									
4	SDPT				13		13		13			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>17</b>	<b>1</b>	<b>17</b>	<b>1</b>	<b>17</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>19</b>	<b>1</b>	<b>19</b>	<b>1</b>	<b>19</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 14.06.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Marrigudam	Shivanagudam	33KV	Devarakonda	12.50	13.40	00.50		33 KV Conductor Snapped & 33 KV Insulator Failed	Shivanagudam	-

## TSSPDCL - LMRC / Corporate office

Date: 14.06.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kodur	Loyapally	11KV	Suryapet	06.15	08.20	02.05	E/L	Insulator failed	-
2		Gaddipaly	Gaddipally	11KV	Huzurnagar	04.30	09.00	04.30	E/L	Due to 11Kv Jumper cutted near Gaddipally village	-
3		Garidepally	L B Nagar	11KV	Huzurnagar	07.50	12.10	04.20	E/L	Due to 11Kv Line cutted near L B Nagar village	-
4		Akaram	Shanthinagar	11KV	Nalgonda	10.30	14.55	04.25	E/L	11 KV Line Cut	-
1	SDP	Husnabad	Husnabad town I	11KV	Siddipet	11.45	11.55	00.10		Break down	-
2		Gouravelli	Gubbadi	11KV	Siddipet	07.20	14.00	06.40		Jumper cutting	-
3		Dharmram	Pothram	11KV	Siddipet	17.50	20.25	02.35		Break down(3Ph)	-
4		Begumpet	Begumpet rural	11KV	Siddipet	18.10	19.00	00.50		Jumper Cutting	-
5		Shanigaram	Shanigaram rural	11KV	Siddipet	00.00	06.00	06.00		Break down(3Ph)	-
6		Shanigaram	Thangallapally	11KV	Siddipet	09.10	10.30	01.20		Break down(3Ph)	-
7		Samudrala	samudrala rural	11KV	Siddipet	18.45	21.10	02.25		Break down(3Ph)	-
8		Baswapur	Baswapur rural	11KV	Siddipet	13.25	13.40	00.15		Break down	-
9		Chityala	Chityala	11KV	Siddipet	08.30	10.25	01.55		Disk failure	-
10		Chityala	Chityala	11KV	Siddipet	10.30	16.20	05.50		Disk failure	-
11		Chityala	Dommata	11KV	Siddipet	08.55	09.20	00.25		Break down	-
12		Chityala	Dommata	11KV	Siddipet	09.25	14.20	04.55		Break down	-
13		Chityala	Thadoor	11KV	Siddipet	12.00	13.05	01.05		Break down	-
1	RR N	JDMSS-I	phase-I	11KV	Jeedimetla	06.10	07.15	01.05	EL&OL	11kv line Spark near Hyderabad Busbody	-
1	RR E	Mallapur	Standard Tiles	11KV	Habsiguda	12.45	15.35	02.50		33KV line cut and line fallen on 11kv line near Manikchand Chourastha	-