

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	



## TSSPDCL - LMRC / Corporate office

Date: 15.06.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Elikicherla	11KV	Jadcherla	06.10	09.25	03.15		B.D. 11 Kv wire Cut Near Battupally( Vi).	-
1	NLG	Athmakur(s)	Gottimukkalagugdem	11KV	Suryapeta	12.10	14.30	02.20	E/L	Jumper cut	-
2		Mamidala	Godavarigudem	11KV	Nalgonda	10.55	11.55	01.00	E/L	11 KV Line Insulator Failed	-
3		Mamidala	Mamidala	11KV	Nalgonda	09.45	11.00	01.15	E/L	11 KV line cut	-
4		Kattangur	Mallaram	11KV	Nalgonda	08.35	10.00	01.25	E/L	Ht/LT line milting	-
1	RR N	Thurkapally	Thurkapally	11KV	Medchal	09.40	13.30	03.50	BD	100KVA T/F Failed at Agasya company, Thurkapally	-
1	HYD C	Durga Nagar	Chenna Reddy Nagar	11KV	Azamabad	10.05	12.55	02.50	OL-Rph	Cable fault near Strating Point	Arranged B/F on 11KV Prem Nagar feeder