

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550	1	2	1	2	1	2			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	1	10	1	10	1	10	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		3		3		3			
3	MDK	107	933	1	9	1	9	1	9			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	14	2	14	2	14	0	0	
	Grand Total	1082	6468	3	24	3	24	3	24	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.06.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Yerkaram	Dasthanda	11kv	Suryapet	11.30	13.30	02.00	EL	HT/LT Line melt	-
2		Bollepally	Surepally	11kv	Bhongir	16.30	18.10	02.40	EL	Insuleter Fallur in surepally village	-
3		Narketpally	M.Yadavally	11kv	Nalgonda	11.25	15.30	04.05	EL	11 KV Line Jumper Cutt	-
1	MDK	Thogita	Aurangabad	11kv	Medak	12.10	16.20	04.10		BREAK DOWN INSULATOR FAILED	-
2		Sardhana	Jakkannapet	11kv	Medak	09.30	10.53	01.23		B/D DUE TO LT LINE WIRE CUT	-
3		B.B.Pur	Burugupally	11kv	Medak	10.52	13.35	02.43		Brak Down Due to 3 Ph Not Standing by Supply	-
4		M. Bhupathipur	Guttakindipally	11kv	Medak	11.35	14.00	02.25		B/d due to LT line cut.	-
5		Shalipet	Chennaipally	11kv	Medak	10.00	13.10	03.10		B/D due to 11 KV line cut.	-
6		Venkatrao pet	Chevela	11kv	Medak	14.40	15.54	01.14		B/d due to 11 KV line cut.	-
7		Shankarampet	Kolapally	11kv	Medak	01.30	11.50	10.20		Brak Down Due to 3 Ph Not Standing by Supply	-
8		Shankarampet	Gotimukkula	11kv	Medak	12.52	14.00	01.08		BREAK DOWN INSULATOR FAILED	-
9		Burugupally	Burugupally	11kv	Medak	10.10	17.45	07.35		Brak Down Due to 3 Ph Not Standing by Supply	-
1	SDPT	Gouravelly	Gubbadi Ganagam	11kv	SDPT	09.30	12.30	03.00		Insulator Failed	-
2		Komuravelly	Kistampet	11kv		19.10	19.40	00.30		DTR Failure	-
3	RR S	Gandham guda	Kalimandir	11kv	RJNR	18.20	19.20	01.00	B/D	T/F Brass patti cut Replaced at kalimandir Eidgah	-
4		Puppalaguda	Alkapuri	11kv	IBGH	16.05	17.10	01.05	B/D	11kv Pininsulator Failed at Alkapur Road No -17	-
1	RR N	Bahadur Pally	Laxmi Nagar	11kv	Jedimetla	14.10	16.30	02.20	EL/OL	33/11kv , 33kv Line cut and fallen on the 11kv line at near Sub-Station	-
2		Bahadur Pally	I D A-II	11kv	Jedimetla	14.10	16.30	02.20	EL/OL	33/11kv , 33kv Line cut and fallen on the 11kv line at near Sub-Station	-
1	RR E	TATTIANNARAM	TATTIANNARAM	11kv	SAROORNAGAR	08.52	11.33	02.41	EL	Line Petroling done But No Visiable Fault	-
2		Keesara	Ankireddypallay	11kv	Keesara	11.40	13.45	02.05		Tree fallen on 11kc line at Keesara	-
3		Ramapally	Veeneguda	11kv	Keesara	04.25	05.30	01.05		Copper patti cut at BLN nagar	-
1	HYD S	C.R.P.F	Baba Nagar	11kv	Charminar	10.00	11.15	01.15	EL,OL-Bph	AB Cable fault at Baba Nagar	
2	HYD C	Narayanguda	Preventive Medicine	11kv	Azamabad	10.28	11.52	01.24	EL,OL-Rph	Banner fallen on lines at K.M.School, Jumper cut at Kishor Talkies & Line snapped at Nala	
3		S.D.Hospital	Humayun Nagar	11kv	Mehdipatnam	16.03	18.20	02.17	EL	UG Cable fault (3No. DTR's kept off)	

TSSPDCL - LMRC / Corporate office

Date: 17.06.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narwa	33KV	Mahabubnagar	19.15	21.10	01.55	EL	Not found the fault	Narwa	-
1	MDK	Sadasivpet	Manjeera	33KV	Sangareddy	13.10	13.40	00.30		BD Due to Phase to Phase	Manjeera	-
1	RR N	Shapur Nagar	DP Pally	33KV	Jeedimetla	14.15	16.38	02.23		33KV Conductor snapped at Bahadurpally SS	DP Pally	-