

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	3	1	3	1	3			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	1	9	1	9	1	9	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT				11		11		11			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	18	0	18	0	18	0	0	
	Grand Total	1082	6468	1	27	1	27	1	27	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.06.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	13:00	13:46	0:46	BD	33KV Cable End Kit failed at Narsimhareddy Thota, LGM Pet Village	LGM Pet	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Annasagar	11KV	Jadcherla	06.00	09.00	03.00		11KV Wire cut near Polkampally	No
2		Udithya	Udithya	11KV	Jadcherla	11.00	12.50	01.50		11KV Jumper cut near Veerannapally	No
1	NLG	Bhairavani Banda	Thakkella Penphad	11KV	Nalgonda	12:10	13:10	1:00	E/L	11 KV Line Cut	No
2		Nemmikal	Anubhamula	11KV	Suryapet	12.00	13.30	01.30	EL	Jumper cut	No
3		Dirsincherla	Yellapuram	11KV	Huzurnagar	08.00	09.30	01.30	EL	11KV Insulator failed near Yellapuram village	No
4		Palakaveedu	Nagireddigudam	11KV	Huzurnagar	00.00	04.30	04.30	EL	DTR damaged near Nagireddigudam village	No
5		Repala	Kalakova	11KV	Huzurnagar	8:50	13:15	4:25	OL	11Kv Insulator failed near Kalakova village	No
1	SDPT	Nangunoor	Siddannapet	11KV	Siddipet	0:00	6:35	6:35		11KV Cross patti cut	No
2		Narmetta	Venkatapur	11KV	Siddipet	12:40	16:30	3:50		HT/LT line phase to phase	No
3		Thadakapally	Thadakapally	11KV	Siddipet	9:30	11:30	2:00		Tree branches fallen on the line	No
4		Gurrakagondi	Malyal	11KV	Siddipet	8:00	11:30	3:30		Trasfarmer failed	No
5		Ramancha	Indudtries Feeder	11KV	Siddipet	10:30	13:00	2:30		11KV wire cut	No
6		Akkannapet	Pakeer Naik Thanda	11KV	Husnabad	8:50	12:00	3:10		Due to gale and wind	No
7		Akkannapet	Muthannapet & Cotton Mil	11KV	Husnabad	8:50	9:45	0:55		Due to gale and wind	No
8		Koheda	Venkateshwarapalle	11KV	Husnabad	9:00	10:00	1:00		Due to gale and wind.	No
9		Musthal	Gadithota	11KV	Husnabad	0:00	18:00	18:00		Due to gale and wind.	No
10		Gurjakuta	Vechareni	11KV	Husnabad	13:10	14:10	1:00		Due to gale and wind.	No
11		Dhulimitta	Lingapur	11KV	Husnabad	8:30	11:00	2:30		Due to gale and wind, Insulator failed	No
1	RR N	Madinaguda	Reddy lab	11KV	Kukatpally	5:20	17:20	12:00	EL/OL	11KV Line AB Cable End kit failure at Hanuman temple,Prashanthnagar	No
2		UMCC	Mahadevpuram	11KV	Medchal	17.05	17.35	00.30	BD	11KV Pin insulator failed at Mallareddy Nagar	No
3		Gowdavelly	IDA	11KV	Medchal	09.05	10.50	01.45	BD	11KV Pin insulator failed at Ram Reddy Godown, Gowdavelly	No
1	RR E	Moula-Ali	Kailasagiri	11KV	Sainikpuri	6:43	7:15	0:32		Tree branches fallen on the line	No
2		RR Court	Green Hills	11KV	Saroornagar	10.42	12.08	01.26	EL	Tree branches fallen on the line	No
3		Mohan Nagar	Mohan Nagar	11KV	Saroornagar	08.52	09.50	00.58	EL	DTR Copper patti cut at Mohan Nagar	No
4		Auto Nagar	Auto Nagar	11KV	Saroornagar	16.50	18.00	01.10	EL/OL	Stick fallen on the line at Autonagar	No
5		Auto Nagar	Mansoorabad	11KV	Saroornagar	16:00	17:04	1:04	OL	11KV Pin insulator failed at Mansoorabad	No
1	HYD C	Golnaka	Moulana Azad Nagar	11KV	Azamabad	17.16	18.30	01.14	EL,OL	Cable fault near Railway Bridge	Arranged B/F on 11KV Haraspenta feeder