

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	5	1	5	1	5			
3	MDK	107	933									
4	SDPT			4	14	4	14	4	11		3	3 No.s 11kv still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	19	5	19	5	16	0	3	
	Grand Total	1082	6468	5	23	5	23	5	20	0	3	

TSSPDCL - LMRC / Corporate office

Date: 21.06.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thungathurthy	Ganugubanda	11KV	Suryapet	07.50	10.30	02.40	E/L	11Kv Jumper cut	-
2		Ragadapa	Tripuraram	11KV	Mirylaguda	00.00	16.00	04.00	E/L	11KV Conductor Snapped	-
3		Nadigudem	Karvirala	11KV	Huzurnagar	07.15	10.05	02.50	E/L	11 kv line snapped at Karvirala (v)	-
4		Gondiryala	Gondiryala-1	11KV	Huzurnagar	19.40	20.40	01.00	E/L	25 kva DTR Failed at singaram (v)	-
5		G.Malkapuram	G.Malkapuram	11KV	Huzurnagar	14.20	17.20	03.00	E/L	HT/LT Line touching at G.Malapuram (v)	-
1	SDPT	Nangunoor	Nagarajupally	11KV	SDPT	15.20	17.00	01.40		Insular Failure	-
2		Mirdoddy	Andhey	11KV		17.00	00.00	07.00		Heavy Rains	-
3		Husnabad	Husnabad town I	11KV		16.10	16.40	00.30		Heavy gale and wind	-
4		Husnabad	Malapally	11KV		16.50	18.10	01.20		11 Kv Line cutting	-
5		Gouravelli	Gouravelli rural	11KV		21.00	21.30	00.30		Heavy gale and wind	-
6		Dharmaram	Dharmaram rural	11KV		17.00	00.00	07.00		Heavy gale and wind (3ph)	-
7		Dharmaram	Potharam	11KV		17.00	18.00	01.00		Insulator Failure	-
8		Bejjanki	Regulapally	11KV		00.00	07.00	07.00		insulator Failure	-
9		Bejjanki	Rws	11KV		17.10	00.00	07.00		Break down	-
10		Guggilla	Guggilla	11KV		14.45	16.15	01.30		Heavy gale and wind	-
11		Guggilla	Gagillapur	11KV		19.00	06.00	11.00		Due to havey Rain	-
12		Shanigaram	Gundareddypally	11KV		00.00	06.30	06.30		Jemper cutting	-
13		Regulapally	mallamchervu	11KV		21.30	06.00	08.30		Due to havey Rain	-
14		Samudrala	samudrala town	11KV		21.00	06.00	09.00		Due to havey Rain	-
1	RR N	Kistapur	Kistapur	11kv	Medchal	15.55	17.30	01.35		15KVA T/F Failed at Kistapur Village	-
2		Athiwelly	SPIC	11kv	Medchal	19.40	20.35	00.55		11KV Disc failed at at Jayadarshini	-
1	RR E	TATTIANNARAM	TATTIANNARAM	11kv	SAROOR NAGAR	03.45	05.20	01.35	EL	11KVLine Petroling Done But No Visible Fault	-
1	HYD C	Industrial Area	Azamabad I.E	11kv	Azamabad	00.10	01.20	01.10	EL	No Visible Fault	Partial feeder charged at 00:55 Hrs & Remaining fdr arranged B/F on 11KV Vidya Nagar feeder

TSSPDCL - LMRC / Corporate office

Date: 21.06.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Wadapally	A.D.Pally	33KV	Mirytaguda	16.30	19.50	03.20	E/L	33Kv Jumper cut	A.D.Pally	-
1	SDPT	Siddipet	Raghavapoor	33KV	Siddipet	13.35	17.50	04.15		Insulater Failed	Raghavapoor	-
2		Habsipur	Khajipur	33KV	Siddipet	16.35	21.15	04.40		Disk Failed	Khajipur	-
3		Gajwel	Mulugu	33KV	Gajwel	19.40	22.20	02.40		Insulater Failed	Mulugu	-
4		Husnabad	Thotapally	33KV	Husnabad	16.10	16.55	00.45		Jumper cutting	Thotapally	-