

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	7	1	7	1	7			
7	RR(E)	168	403									
8	Hyd	194	1044		10		9		9			1No 11KV Still
	Total	606	3055	1	17	1	16	1	16	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		6		6		6			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	7	2	7	2	7	0	0	
	Grand Total	1082	6468	3	24	3	23	3	23	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.06.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kothur	Aryam Steel	33KV	Jadcherla	12.30	19.45	07.15		for Conductor follen on the line at Vinayaka Company	Kothur	-
1	MDK	Bollaram	Shathawahana	33KV	Patancheru	17.55	22.00	04.05		Due to insulator fail	Bollaram	-
1	RR N	132KV Medchal	33KV Athiwelly	33KV	Medchal	19.47	21.25	01.38		Tree Fallen on 33KV Line at CMR College	132KV Medchal	-

TSSPDCL - LMRC / Corporate office

Date: 22.06.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Phanigiri	Anantharam	11KV	Suryapet	13.20	15.00	01.40	EL	Jumper cut	-
2		Gondriyala	Chimiryala	11KV	Huzurnagar	03.00	06.00	03.00	EL	Due to jumper cut near Chimiryala village	-
3		Dondapadu	Dondapadu	11KV	Huzurnagar	02.30	06.00	03.30	EL	Jumper cut	-
4		Tripuraram	Duggepally	11KV	Miryalguda	13.15	17.30	04.15	EL	Conductor snapped fallen on the line	-
5		Azeempet	Azeempet	11KV	Bhongir	06.00	08.00	02.00	EL	11kv Insulator failed	-
6		Koppole K	Koppole K	11KV	Nalgonda	19.00	21.10	02.10	EL	11 KV Insulator Failed	-
1	MDK	Bollaram	Rupa	11KV	Patancheru	19.52	00.35	04.43		due to jumper cut	-
1	RR N	Jeedimetla ss II	Phase III	11KV	Jeedimetla	19.10	20.40	01.30		11kv pin insulator failure opp Suvan Pharma at Phase III	-
2		Subash Nagar	Jeedimetla	11KV	Medchal	19.25	21.17	01.52		11KV AB Cable Failed at Dewan Dhaba	-
3		Dulapally	IDA-II	11KV	Medchal	19.22	21.02	01.40		11KV Pin Insulator Failed at Varma Industry,IDA Dulapally	-
4		GP Pally	GP Pally	11KV	Medchal	16.50	17.40	00.50		Tree fallen on the 11KV Line at Venkateshwara Pipes company	-
5		Medchal	Check Post	11KV	Medchal	17.30	18.30	01.00		11KV Line cut & replacement at Checkpost	-
6		Devarayamjal	DMC	11KV	Medchal	17.40	18.50	01.10		Tree fallen on the 11KV Line at Arukalaguda village	-
7		Medicity	Munirabad	11KV	Medchal	17.15	21.05	03.50		11KV Disc and Pin Insulator at Crusher,Munirabad	-
1	HYD N	Kalyan Nagar	Krishna Nagar	11KV	Banjarahills	18.34	20.19	01.45	EL,OL-Rph	Cable fault at Remath Nagar Kaman Galli & HT Jumper cut near SS	-
2		Chinna Thokatta	Old Bowenpally	11KV	Bowenpally	19.15	20.35	01.20	EL,OL-Yph	Big tree fallen on lines & Disc Insulator flash over at Icrisat Colony Phase-II	-
3		Chinna Thokatta	Panchavati Colony	11KV	Bowenpally	19.35	20.51	01.16	EL,OL-Rph	No Visible Fault due to Heavy Rain	-
4		R.P.Nilayam	Naga Devatha	11KV	Bowenpally	20.00	21.15	01.15	EL	Tree branches fallen on lines at Naga Devatha Temple	-
5		Gunrock	Subhash Nagar	11KV	Bowenpally	19.40	22.15	02.35	EL	2No. Pin Insulators flash over at Ravi Colony	-
6		Yellareddyguda	Savera	11KV	Banjarahills	23.05	00.00	00.55	EL	Under breakdown	-
1	HYD S	Santosh Nagar	Bhavani Nagar	11KV	Asmangadh	02.30	04.45	02.15	EL	Breaker fault at SS	Arranged B/F on 11KV Moulaka Chilla feeder
2		Falaknuma	Chatrinaka	11KV	Charminar	23.40	01.30	01.50	EL	Tree branches fallen on lines at Chatrinaka	-
1	HYD C	Golnaka	Tulasi Nagar	11KV	Azamabad	02.50	04.16	01.26	OL	No Visible Fault	Arranged B/F on 11KV Nehru Nagar feeder
2		Fever Hospital	BKP Bus Depot	11KV	Azamabad	23.58	01.28	01.30	EL	Tree branches fallen on lines at BKP Bus Depot	-