

## Status Report on Breakdowns (Urban / Rural)

**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044	1	3	1	3	1	3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	8	1	8	1	8			
2	NLG	144	988		6		6		6			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT			2	3	1	0	1		1	3	1 No.s 33kv & 3 No.s 11kv still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>4</b>	<b>19</b>	<b>3</b>	<b>16</b>	<b>3</b>	<b>16</b>	<b>1</b>	<b>3</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>5</b>	<b>28</b>	<b>4</b>	<b>25</b>	<b>4</b>	<b>25</b>	<b>1</b>	<b>3</b>	

## TSSPDCL - LMRC / Corporate office

Date: 27.06.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kethepally	T.R.Pally	11kv	Wanaparthi	20.30	08.50	12.20		Tree fallen on the 11kv line near kethepally (V).	-
2		Mahandapur	Mahandapur	11kv	Wanaparthi	19.15	10.30	15.15		11kv Insulator failed near mahandapur	-
3		Gopalpeta	Polikepad(Agl)	11kv	Wanaparthi	17.00	11.02	18.02		11kv Insulator failed near Bangaramma gadda at Gopalpeta.	-
4		Chennaram	Chennaram	11kv	Wanaparthi	20.13	10.50	14.37		11kv jumper opened at MSR Cut point at chennaram Agl.	-
5		Pebbair	Y.Shagapur	11kv	Wanaparthi	21.30	09.00	11.30		11kv disc failed near at Y.shagapur agl.	-
6		Peddmandadi	Alwal	11kv	Wanaparthi	15.00	06.10	15.10		No Visible fault.	-
7		Atmakur	Pinnamcherla	11kv	Wanaparthi	17.00	06.00	13.00		No Visible fault.	-
8		Kalwarala	Pulgarcherla	11kv	Wanaparthi	21.00	09.45	12.45		11kv disc failed near at Busireddypally V.	-
1	NLG	Athmakur(s)	Athmakur AGL	11kv	Suryapeta	15.45	17.10	01.25	E/L	Insulator failure	-
2		Thurkapally	Thurkapally	11kv	Nalgonda	10.35	12.30	01.55	E/L	11KV Line jumper cut	-
3		Arlagaddagudem	N.R.Gudem	11kv	Nalgonda	07.45	09.00	01.15	E/L	HT/LT Line melting	-
4		Mkundapuram	Somaram	11kv	Huzurnagar	05.00	07.30	02.30	E/L	11KV Line jumper cut	-
5		Mattampally	Ramachandrapuram	11kv	Huzurnagar	06.30	08.30	02.00	E/L	11KV Line Snapped	-
6		Ananthagiri	Shanthinagar	11kv	Huzurnagar	09.00	10.10	01.10	E/L	Insulator failure	-
1	MDK	Cheryal	Turbovent	11kv	Sangareddy	00.00	13.30	13.30		B/D Due to Insulators failed near Cheryal Village	-
2		Kistareddypet	Sulthanpur Idl.	11kv	Patancheru	16.10	19.10	03.00		BD due to Conductor snapped	-
1	SDPT	Regulapally	Mallam cheruvu	11kv	Husnabad	17.40	00.00	06.20		Due to gale & wind	-
2		Mustyal	Cheriyal	11kv	Husnabad	18.00	00.00	06.00		Due to gale & wind	-
3		Akunur	Rudraipally	11kv	Husnabad	18.20	00.00	05.40		Due to gale & wind	-
1	RR N	ICICI	Adama	11kv	Medchal	17.10	18.12	01.02	BD	11KV Pin Insulator failed at Due Point Company	-
2		Shameerpet	Shameerpet	11kv	Medchal	18.20	19.00	00.40	BD	No Fault	-
3		Nuthankal	Nuthankal	11kv	Medchal	17.50	18.45	00.55	BD	11KV Pin Insulator failed at Nuthankal Village	-
4		Medicity	Munirabad	11kv	Medchal	18.45	19.27	00.42	BD	Tree fallen on the 11KV Line at Law College	-
1	RR E	Kushaiguda	Kushaiguda	11kv	Sainikpuri	14.15	15.40	01.25		Tree fallen on 11Kv line at North Kamala Nagar (LM Srinivas)	-
2		Moula-Ali	FBP	11kv	Sainikpuri	16.40	17.40	01.00		Tree fallen on 11Kv line at Railway Compound (AE)	-
1	HYD N	I.D.P.L	V.E	11kv	Bowenpally	04.45	06.02	01.17	All Indication	Cable fault	5:30 Hrs Partial loads arranged B/F on 11KV Lokesh Mechines for
2	HYD S	Kanchan Bagh	I.S.Sadan	11kv	Charminar	09.45	11.12	01.27	EL,OL-Rph	Jumper cut at Yadagiri Theatre	-----
3		Salarjung	Madina	11kv	Charminar	13.50	15.45	01.55	EL,OL-Rph	RMU Cable fault at Charminar FOC (3No. DTR's kept off)	-----

## TSSPDCL - LMRC / Corporate office

Date: 27.06.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Jaklair	33KV	Mahabubnagar	18.25	20.15	01.50	EL	Insulator damaged	Jaklair	-
1	MDK	Kowdipally	CH Ganpur	33KV	Medak	15.34	17.37	02.03		Bd due to Disk failed	CH Ganpur	-
1	SDPT	Mustyal	Komuravelly	33KV	Husnabad	22.55	06.15	07.20		Due to gale & wind	Komuravelly	-
2			Cherial	33KV	Husnabad	22.45	00.00	01.15		Due to gale & wind	Cherial	-
1	HYD N	132KV Jubilee Hills	Sundew	33KV	Jubilee Hills	13.18	13.30	00.12	EL	Tripped on EL	Sundew	Loads transferred onto 132KV J'Hills SS via 33KV Intime Properties fdr