

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358		9		9		9			
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	3	1	3	1	3			
	Total	606	3055	1	13	1	13	1	13	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988									
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	0	1	0	1	0	0	0	
	Grand Total	1082	6468	2	13	2	13	2	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.06.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Midjil	Madaram	33KV	Wanaparthi	19.30	23.00	03.30	O/L	Phase to Phase near 132KV Midjil SS	Madaram	No
1	HYD N	132KV Madhapur	Deva Bhoomi-3 (Cable -2)	33KV	Kalyan Ngr	09.00	10.40	01.40	EL,OL-Bph	Cable-2 fault, Charged Cable-1	Deva Bhoomi-3 (Cable -2)	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Koppole (K)	Koppole (K)	11KV	Nalgonda	8:40	10:45	2:05	E/L	11 KV Line Jumper Cut	No
2		Palivela	Palivela	11KV	Nalgonda	10.00	13.00	03.00	E/L	11 KV Line Insulator failed	No
3		Madugulapally SS-10	Kukkadam	11KV	Nalgonda	02.10	08.07	05.57	E/L	11 KV Line Insulator failed	No
4		Indugula	Malaparaju Gudem	11KV	Nalgonda	02.30	06.30	04.00	E/L	11 KV Line Insulator failed	No
5		Thoragal	Thangallavari Gudem	11KV	Nalgonda	03.00	07.00	04.00	E/L	HT/LT Melt	No
6		Chedella	Chedella	11KV	Suryapet	07.25	10.00	02.35	E/L	Jumper cut	No
7		Dirsincherla	Yellapuram	11KV	Huzurnagar	03.00	06.30	03.30	E/L	11KV Jumper cut	No
8		Gaddipaly	Gaddipaly Town	11KV	Huzurnagar	03.15	05.50	02.35	E/L	11KV Jumper cut	No
9		N.B.Gudem	Redlakunta	11KV	Huzurnagar	11:50	13:30	1:40	E/L	11KV Line snapped	No
1	RR E	Yadgarapally	Thimaipally	11KV	Keesara	17:35	18:45	1:10		No visible fault	No
1	HYD N	Chinna Thokatta	Old Bowenpally	11KV	Bowenpally	15.20	16.45	01.25	OL	Cable fault near SS	Arranged B/F on 11KV Central Excise & 11KV Hasmathpet feeders
1	HYD S	Petlaburz	Maternity Hospital	11KV	Charminar	00.52	02.40	01.48	EL,OL	Suspected Cable fault	Arranged B/F on 11KV High Court feeder
1	HYD C	Vittalwadi	Y.M.C.A	11KV	Azamabad	01.05	02.30	01.25	EL,OL-R&Bph	No Visible Fault	No