

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		2		2		2			
3	MDK	87	828		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	4	0	4	0	4	0	0	
	Grand Total	908	6149	0	8	0	8	0	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.03.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Narsingbatla	Chennugudem	11KV	Nalgonda	01.25	06.00	04.35	EL	11KV Insulator failed	-
2		Rajavaram	Thirumalgiri	11KV	Mirylaguda	05.30	07.30	02.00	EL	11KV conductor snapped at Kompally	-
1	MDK	Shalipet	Podchanpally	11KV	Medak	07.30	09.30	02.00		B/D due to Jumpercut	-
2		Khajapur	Podchanpally-I	11KV	Medak	02.57	07.57	05.00		B/D due to DTR problem	-
1	RR N	Suraram	Matrix	11KV	Jeedimetla	14.45	15.50	01.05	EL/OL	11kv Endy Kit Failure At GLR Company Phase IV	-
2		Ravalkole	Ravalkole	11KV	Medchal	04.01	04.41	00.40	BD	Bird fallen on the 11KV Line at Mallanna Temple	-
1	RR E	Narapally	Narapally	11KV	Habsiguda	17.30	19.30	02.00		Pin Insulator fallen on Cross aram at back side of MC downales	-
1	HYD C	Golnaka	Kamala Nagar	11KV	Azamabad	13.35	15.45	02.10	EL,OL	Snapped 11KV Conductor & flash over Pin Insulator at Mammu-Ka-Mandi	-

