

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948		2		2		2			
3	MDK	87	828		4		4		4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 05.03.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Burgupally	11KV	Jadcherla	08.15	09.50	01.35		11kv wire cut near Burgupally	-
1	NLG	Arvapally	J.R.Gudem AGL	11KV	Suryapet	06.00	08.30	02.30	EL	Jumper cut	-
2		Munagala	Tadvai	11KV	Huzurnagar	17.05	18.15	01.10	EL	11 kv line snapped at Tadvai village	-
1	MDK	Cheryal	Indrakaran	11KV	Sangareddy	05.00	10.00	05.00		B/D Due 11KV Conductor Snapped	-
2		Cheryal	Kalivemula	11KV	Sangareddy	10.00	11.50	01.50		B/D Due to Jumper Cut And AB Switch Failure	-
3		Shalipet	Khajapur	11KV	Medak	01.00	07.00	06.00		B/D Due to Insulator failure	-
4		Rajpet	Muthrajpally	11KV	Medak	03.40	09.30	05.50		B/D Due to Jumper Cut	-
1	RR E	Narapally	Narapally	11KV	Habsiguda	17.30	19.30	02.00		Pin Insulator fallen on Cross arm at back side of MC downales	-
1	HYD N	Malakpet	Prabhath	11KV	Asmangadh	16.55	18.42	01.47	EL	Suspected Cable fault	Arranged B/F on 11KV Moulana Azad Nagar feeder

TSSPDCL - LMRC / Corporate office

Date: 05.03.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBN				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RR S				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD N				NIL							-
8	HYD S				NIL							-
9	HYD C				NIL							-