

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014	1	2	1	2	1	2			
	Total	504	2929	1	4	1	4	1	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	4	0	4	0	4	0	0	
	Grand Total	908	6149	1	8	1	8	1	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 06.03.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD N	132KV J' Hills	Hitech	33KV	Kalyan Ngr	05.45	07.00	01.15	OL-R&Yph	Cable End Kit failed of 33KV Wipro fdr at 4th Pole Structure	Hitech	Loads transferred onto 132KV Madhapur SS

TSSPDCL - LMRC / Corporate office

Date: 06.03.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kopple	Uppalapahad	11KV	Nalgonda	09.22	12.10	02.48	EL	11 KV Line Insulator Failed	-
2		N.B.Gudem	Redlakunta	11KV	Huzurnagar	05.00	06.30	01.30	EL	Due to 11Kv line jumper cutted near Redlakunta village	-
3		Repala	Narsimhulagudem	11KV	Huzurnagar	12.40	14.45	02.05	EL	Due to 11Kv line jumper cutted near Narsimhulagudem village	-
4		Gudimalkapuram	Chintalapalem	11KV	Huzurnagar	18.10	19.50	01.40	EL	Due to 11Kv line snapped near Chintalapalem village	-
1	RR E	KOTHAPET	KAMALA NAGAR	11KV	SAROORNAGAR	13.54	14.55	01.01	EL	11KV DISK FAIL AT DENTAL COLLEGE KAMALA NAGAR	-
2		PEDDAMBERPET	KUNTLOOR	11KV	SAROORNAGAR	11.00	12.10	01.10	EL	HT/LT LINE CUT AT KUNTLOOR	-
1	HYD N	H.M.T	A.O.L	11KV	VI	23.30	01.20	01.50	EL	Arranged B/F on 11KV Caption Gas feeder	-
2		H.M.T	Sri Sai Colony	11KV	VI	23.30	01.10	01.40	EL	AB Cable fault at Nanda Nagar (4No. DTR's Kept Off)	Arranged B/F on 11KV Giri Nagar feeder