

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		3		3		3			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	4	1	4	1	4	0	0	
	Grand Total	908	6149	1	6	1	6	1	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 07.03.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	RWS	33KV	Gadwal	16.10	17.05	00.55	E/L&O/L	Bird (Crane) fallen on the Line Near Kothapally(V)	RWS	-

TSSPDCL - LMRC / Corporate office

Date: 07.03.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kourampet	Bandameedipally	11KV	Jadcherla	08.04	10.04	02.00		11KV Insulator failed near Bandameedipally(V)	-
1	NLG	GT Giri	Gunjaloor	11KV	Suryapet	11.30	13.40	02.10	EL	Jumper cut near SS-6	-
2		Ganapuram	Polkampally	11KV	Devarakonda	08.10	12.00	03.50	E/L	11KV Insulater Fail	-
3		Teldhevarapally	Bollaram	11KV	Devarakonda	07.00	11.00	04.00	E/L	11KV Line Cut	-
1	RR N	HMT	Ganesh Nagar	11KV	Medchal	11.20	12.56	01.36	BD	11KV AB Cable Failed at Ambethkar Nagar	-
1	HYD C	Nizam College	Little Flower	11KV	I	13.56	15.30	01.34	EL,OL	Breaker fault & relay problem at SS	-