

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014	1		1		1				
	Total	504	2929	1	0	1	0	1	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		2		2		2			
2	NLG	150	948		3		3		3			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	5	0	5	0	5	0	0	
	Grand Total	908	6149	1	5	1	5	1	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.03.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Edira	Divitipally	11KV	Mahabubnagar	08.00	09.50	01.50		11KV Phase to Phase Near Ambatpally (Vi)	-
2		Sanginonipally	Vinjamoor	11KV	Mahabubnagar	19.00	20.15	01.15		11KV Jumper cut at Sanginonipally (vi)	-
1	NLG	Pamanagundla	Pamanagundla	11KV	Nalgonda	04.00	06.00	02.00	E/L	11KV Line Jumper Cut	-
2		Y.Singaram	Magdum Nagar	11KV	Huzurnagar	03.00	07.00	04.00	E/L	11Kv Inslater failed at Magdumnagar (v)	-
3		Yerkaram	Yerkaram	11KV	Suryapet	06.00	08.50	02.50	E/L	Jumper cut	-

TSSPDCL - LMRC / Corporate office

Date: 10.03.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD S	220KV Shivarampally - Ch' Baradari UG	Ch' Baradari	ST	Malakpet	05.39	05.55	00.16	EL,OL	Cable fault near Polytechnic College Nala	220KV Shivarampally - Ch' Baradari UG	Loads transferred onto 220KV Sh' Pally Ch' Baradari-OH fdr but feeder not hold & Loads transferred onto 132KV Imlibun - Khilwath