

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360									
7	Hyd	186	1014									
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		3		3		3			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 14.03.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220/132KV SS Palkonda	Kothamolgera	33KV	Mahabubnagar	16.50	20.03	03.13	OL	33KV Insulator failed	Kothamolgera	Attending Break Down Alternate Supply Arranged from 132KV Ghanapur at 20:03Hrs

TSSPDCL - LMRC / Corporate office

Date: 14.03.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Bhoothpur	Bhoothpur®	11KV	Jadcherla	06.40	10.00	03.20		Single Phase Dtr Failure Near Kothur Tanda Side.	-
1	NLG	Penpahad	Dubbathanda	11KV	Suryapet	03.00	06.00	03.00	EL	Jumper cut	-
2		Keethavarigudem	Veldanda	11KV	Huzurnagar	05.30	09.20	03.50	EL	11 Disk failed at Veldanda village	-
3		Kandibanda	Kandibanda	11KV	Huzurnagar	15.55	16.55	01.00	EL	11 KV inslater failed at Kandibanda village	-
1	RR N	Kompally	Kompally	11KV	Medchal	06.15	06.30	00.15	BD	11KV Cable Failed at Grampanchayathi,Kompally	-
2		Laxmapur	Narayanapur	11KV	Medchal	16.28	17.23	00.55	BD	No fault	-