

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234									
5	RR(N)	54	550		3		3		3			
6	RR(E)	168	403		3		3		3			
7	Hyd	194	1044		6		6		6			
	Total	606	3055	0	12	0	12	0	12	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4		4		3		1		1 No. 33KV Still
2	NLG	144	988		4		4		4			
3	MDK	107	933	1		1		1				
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	5	4	5	4	4	4	1	0	
	Grand Total	1082	6468	5	16	5	16	4	16	1	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Marroor	Marroor	11KV	Nalgonda	13:50	15:10	1:20	EL	11KV Jumper cut at SS-2	No
2		Kasarabadha	Ruplathanda	11KV	Suryapet	08.45	11.00	02.15	EL	Jumper cut	No
3		Raghunadapalem	Nakkagudem	11KV	Huzurnagar	05.30	08.30	03.00	EL	11KV Jumper at Nakkagudem villag	No
4		Gondiryala-2	Chimiryala	11KV	Huzurnagar	11.11	14.08	02.50	EL	11KV Line snapped at Chimiryala village	No
1	RR N	Jeedimetla-I	JETEL	11KV	Jeedimetla	5:40	6:40	1:00	EL&OL	11KV AB Cable failed near Sagar Hotel	No
2		Medicity	IDA-I	11KV	Medchal	15.20	17.00	01.40	BD	11KV Cable end kit failed at near by SS	No
3		Laxmapur	Narayanapur	11KV	Medchal	11.14	12.14	01.00	BD	11KV Pin insulator failed at Durgamma Temple, Narayanpur	No
1	RR E	Autonagar	Siris	11KV	Sarooranagar	18:50	19:45	0:55	EL/OL	Tree branches fallen on 11KV line at Ganesh Nagar	No
2		Mother Dairy	Ganeshnagar	11KV	Sarooranagar	09.23	10.30	01.07	OL	Tree branches fallen on 11KV line at Venkateshwara Colony	No
3		IDA Uppal	Devender Nagar	11KV	Habsiguda	19.33	20.12	00.39		Construction of House Stick Bamboos fallen on 11KV line due to heavy wind and gale near Noble Hotel	No
1	HYD N	Hakimpet	Risala Bazar	11KV	Bowenpally	23.45	01.10	01.25	EL,OL-Rph	No visible fault	Arranged B/F on 11KV Bollaram PS feeder
2		Zamisthanpur	S.P.College	11KV	Sec'bad	23:54	1:30	1:36	EL,OL-R,Y&Bph	Tree branches fallen on lines at Skandagiri Temple	Arranged B/F on 11KV Sanjeeva Puram fdr
1	HYD S	Yakuthpura	Murthuza Nagar	11KV	Asmangadh	09.24	11.37	02.13	EL	UG Cable fault at Murthuza Nagar (5No DTR's kept off)	Arranged B/F on 11KV Moulaka Chilla feeder
2		Santosh Nagar	Rain Bazar	11KV	Asmangadh	19:30	21:05	1:35	EL	HT Line snapped at Rain Bazar	No
3		Santosh Nagar	New Bhavani Nagar	11KV	Asmangadh	19:33	21:02	1:29	EL	Foreign material fallen on lines at Bhavani Nagar	No
4		Chanchalguda	A.C.P.Office	11KV	Asmangadh	19:36	21:31	1:55	EL,OL-Rph	33KV Santosh Nagar fdr cable end kit sparking at SS	Arranged B/F on 11KV Ekalavya Nagar fdr

TSSPDCL - LMRC / Corporate office

Date: 16.03.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Alampur	33KV	Gadwal	19.58	21.14	01.16	E/L	Due to Line Problem, Jumpers Opened towards Panchalingal SS Supply OK	Alampur	No
2		Balanagar	G.R Cable	33KV	Jadcherla	17.50	18.45	00.55	E/L	Due to Heavy Wind & Rain Isolator Opened at Rangareddy Guda	G.R Cable	No
3		Kalwakurthy	Jajala	33KV	Jadcherla	18.20	Still		E/L	Insulator failed & Tree fallen on the line	Jajala	No
4		Achampet	Veltoor	33KV	Nagarkurnool	16:40	19:45	3:05	E/L	Due to Heavy Wind & Rain	Veltoor	Alternate Supply Arranged from Uppununthala at 19:45Hrs
1	MDK	Narayankhed	Poosalpad	33KV	Jogipet	18:35	20:15	1:40		Jumper cut	Poosalpad	No