

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	RR(S)	53	234	1	3	1	3	1	3			
5	RR(N)	54	550	5	18	5	18	5	18			
6	RR(E)	168	403		6		6		6			
7	Hyd	194	1044	1	33	1	33	1	33			
	Total	606	3055	7	60	7	60	7	60	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	11	23	11	23	11	23			
2	NLG	144	988	17	126	17	126	17	126			
3	MDK	107	933	18	5	18	5	18	5			
4	RR(S)	58	396									
5	RR(N)	38	114									
6	RR(E)	22	133									
	Total	476	3413	46	154	46	154	46	154	0	0	
	Grand Total	1082	6468	53	214	53	214	53	214	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.03.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Baswaipally	Laxmipally	11KV	Mahabubnagar	03.00	10.00	07.00		Due to Heavy Rain	-
2		Baswaipally	Baswaipally	11KV	Mahabubnagar	03.00	10.00	07.00		Due to Heavy Rain	
3		Baswaipally	Chowderpally	11KV	Mahabubnagar	03.00	10.00	07.00		Due to Heavy Rain	
4		Marikal	Marikal Town	11KV	Mahabubnagar	01.15	02.50	01.35		11KV Insulator Damage near Higway	
5		Marikal	Theelair	11KV	Mahabubnagar	01.38	13.26	11.48		11KV Insulator Damage near Ibhrampatnam	
6		Marikal	Madwar	11KV	Mahabubnagar	04.10	12.45	08.35		Tree Fallen on the Line	
7		Dhanwada	Dhanwada	11KV	Mahabubnagar	02.00	06.00	04.00		11KV Insulator Damage near Temple	
8		Dhanwada	Kamsanpally	11KV	Mahabubnagar	02.00	06.00	04.00		3 Phase supply failed Due to Heavy Rain&Wind	
9		Kanukurthy	Damargidda	11KV	Mahabubnagar	01.45	02.20	00.35		Tree Fallen on theLine Near Lingareddypally	
10		Kanukurthy	Lokurthy	11KV	Mahabubnagar	04.50	07.00	02.10		Due to Heavy Rain	
11		Jaklair	Satysai	11KV	Mahabubnagar	02.00	07.00	05.00		11KV Insulator Damage near Jaklair Tower	
12		Weepanagandla	Velgonda	11KV	Wanaparthi	08.50	12.10	03.20		11KV Jumper Cut at Gopaldeny village	
13		Ghanapur	Allamaipally	11KV	Wanaparthi	03.45	16.30	12.45		11KV Jumper Cut at Alamaipally AGL	
14		Janampet	Annasagar	11KV	Jadcherla	05.15	08.45	03.30		11KV Insulator Damaged near Gajulapet	
15		Janampet	Polkampally	11KV	Jadcherla	08.00	10.20	02.20		11KV Jumper cut near Thimmapur	
16		Kaverammamet	Bandamidipally	11KV	Jadcherla	02.00	07.50	05.50		11KV wire cut near Macharam	
17		Balanagar	CBR Industrial	11KV	Jadcherla	02.07	06.13	04.06		Tree fallon the line near Manikanta Batter company	
18		Addakal	Gudibanda	11KV	Jadcherla	13.50	14.30	00.40		Tree fallen on the line near Gudibanda	-
19		Kothamolgara	L&T	11KV	Jadcherla	05.30	08.30	03.00		Tree Follen on The 11 Kv Line Near Kothamolgara(V)	-
20		Jajala	Agraharam	11KV	Nagarkurnool	00.00	06.00	03.00		11KV Poles Damaged Due to Heavy Wind & Rain	-
21		Vattem	Ankonpally	11KV	Nagarkurnool	03.30	07.30	04.00		11KV Poles Damaged Due to Heavy Wind & Rain	-
22		Manganoor	Gouraram	11KV	Nagarkurnool	03.30	07.30	04.00		11KV Poles Damaged Due to Heavy Wind & Rain	-
23		Sirsangandla	Chintapally	11KV	Nagarkurnool	23.30	03.30	04.00		11KV Poles Damaged Due to Heavy Wind & Rain	-
1		A.D.Pally	Satrasala	11KV	Miryalaguda	04.50	09.30	04.40	EL	11KV pin insulator failed	-
2		A.D.Pally	Veerlapalem Agl	11KV	Miryalaguda	05.40	12.10	06.30	EL	Tree branch fallen	-
3		Damarcherla	Narsapur	11KV	Miryalaguda	05.35	09.30	03.55	EL	Conductor Phase to phase fault	-
4		K.N.Konda	K.N.Konda	11KV	Miryalaguda	05.30	11.30	06.00	EL	11KV jumper cut	-
5		K.N.Konda	Mulkacherla	11KV	Miryalaguda	04.30	12.00	07.30	EL	11KV pin insulator flash over	-
6		Pulimamidi	Pulimamidi	11KV	Miryalaguda	06.00	16.45	10.45	EL	11KV Conductor snapped	-
7		Pulimamidi	Sreenadapuram	11KV	Miryalaguda	05.10	09.00	03.50	EL	Tree branch fallen	-
8		Rajavaram	J.C.Thanda	11KV	Miryalaguda	05.25	09.00	03.35	EL	11KV Conductor snapped	-

9	Rajavaram	Thirumalgi	11KV	Miryalaguda	04.30	10.20	05.50	EL	Tree branch fallen	-
10	Haliya	Annaram	11KV	Miryalaguda	05.30	09.00	03.30	EL	11 KV Conductor snapped	-
11	Haliya	Marepally	11KV	Miryalaguda	05.30	09.00	03.30	EL	11KV pin insulator flash over	-
12	Avanthipuram	Avanthipuram	11KV	Miryalaguda	05.45	11.00	05.15	EL	11KV pin insulator flash over	-
13	Avanthipuram	Badalapuram	11KV	Miryalaguda	06.10	11.10	05.00	EL	11KV Jumper cut	-
14	Avanthipuram	Indl-I	11KV	Miryalaguda	06.20	09.44	03.24	EL	Tree branch fallen	-
15	Avanthipuram	Indl-II	11KV	Miryalaguda	06.35	09.44	03.09	EL	11KV pin insulator failed	-
16	Thadakamalla	Thadakamalla	11KV	Miryalaguda	04.55	09.30	04.35	EL	11KV Conductor snapped	-
17	B.Annaram	B.Annaram	11KV	Miryalaguda	06.10	12.10	06.00	EL	11KV pin insulator failed	-
18	B.Annaram	Dilawarpur	11KV	Miryalaguda	04.20	12.30	08.10	EL	11KV pin insulator flash over	-
19	Nandipadu	Iyalapuram	11KV	Miryalaguda	05.40	02.40	14.40	EL	Sper line DTR;s (4Nos) Jumper cut	-
20	Kothagudem	Laxmipuram	11KV	Miryalaguda	04.45	11.20	06.35	EL	11KV pin insulator flash over	-
21	Kothagudem	Gudur	11KV	Miryalaguda	05.00	12.10	07.10	EL	11KV pin insulator flash over	-
22	Utlapaly	Kalwapally	11KV	Miryalaguda	05.20	09.50	04.30	EL	11KV Jumper Cut	-
23	Utlapaly	Yadgarpally	11KV	Miryalaguda	05.40	10.40	05.00	EL	11KV pin insulator failed	-
24	V.K.Palem	Thungapadu	11KV	Miryalaguda	05.00	15.00	10.00	EL	11KV Conductor snapped	-
25	Edulagudem	Indl. Feeder	11KV	Miryalaguda	05.45	10.20	04.35	EL	11KV pin insulator flash over	-
26	Miryalaguda FCI	Hanumanpeta	11KV	Miryalaguda	04.50	09.50	05.00	EL	11KV insulator flash over near flyover	-
27	220/11KV N.Sagar	11KV APSEB	11KV	Miryalaguda	03.30	08.30	05.00	EL	11KV Disc failed	-
28	Nellikal	Nellikal	11KV	Miryalaguda	05.45	12.20	06.35	EL	11KV insulator flash over near flyover and AB switch brass jumpers touched the cross arm	-
29	Nellikal	Chinthalapalem	11KV	Miryalaguda	05.50		18.10	EL		-
30	Nellikal	Lift feeder	11KV	Miryalaguda	04.40	16.55	12.15	EL	11KV Conductor snapped	-
31	Mupparam	Utkur	11KV	Miryalaguda	05.10	15.30	10.20	EL	11KV Conductor snapped	-
32	Mupparam	Yerrabelli	11KV	Miryalaguda	06.00	15.30	09.30	EL	11KV pin insulator flash over	-
33	Thummadam	Thummadam	11KV	Miryalaguda	04.35	12.10	07.35	EL	11KV Conductor snapped	-
34	Thummadam	Narammagudem	11KV	Miryalaguda	05.50	11.45	05.55	EL	11KV jumper cut	-
35	Peddavoor	Battugudem	11KV	Miryalaguda	04.35	15.20	10.45	EL	11 KV Disc insulator failed and conductor snapped near Waagu	-
36	Peddavoor	Thungathurty	11KV	Miryalaguda	04.35	11.30	06.55	EL	2 Nos poles damaged	-
37	Peddavoor	Basireddypally	11KV	Miryalaguda	05.45	11.30	05.45	EL	1 No pole damaged	-
38	Peddavoor	Chalukurthy	11KV	Miryalaguda	05.30	11.30	06.00	EL	11KV Conductor snapped	-
39	Pulicharla	Vootlapally	11KV	Miryalaguda	05.20	11.30	06.10	EL	11KV Conductor snapped	-
40	Velmagudem	Basireddypally	11KV	Miryalaguda	04.35	12.30	07.55	EL	11KV Disc failed	-
41	Pottichalma	Chalukurthy	11KV	Miryalaguda	05.30	12.30	07.00	EL	11KV Jumper cut	-
42	Tripuraram	11KV Duggepally	11KV	Miryalaguda	05.15	12.10	06.55	EL	11KV pin insulator failed	-
43	Tripuraram	11KV Mukundapuram	11KV	Miryalaguda	05.00	12.30	07.30	EL	11KV Conductor snapped	-
44	Tripuraram	Gajalapuram	11KV	Miryalaguda	05.10	12.25	07.15	EL	11KV Conductor snapped	-
45	Tripuraram	S.N.Puram	11KV	Miryalaguda	05.05	12.30	07.25	EL	11KV insulator flash over near flyover	-
46	Matoor	Ragadapa	11KV	Miryalaguda	04.00	12.10	08.10	EL	11KV Disc failed	-
47	Matoor	Lift	11KV	Miryalaguda	05.30	12.30	07.00	EL	11KV insulator flash over near flyover	-
48	Matoor	Gantarao Camp	11KV	Miryalaguda	05.45	12.30	06.45	EL	11KV Disc failed	-

49		P.D.Pally	P.D.Pally	11KV	Miryalaguda	04.30	12.25	07.55	EL	11KV Conductor snapped	-
50		P.D.Pally	Industrial	11KV	Miryalaguda	05.00	12.30	07.30	EL	11KV insulator flash over near flyover	-
51		Kamareddygudem	Pusalapadu	11KV	Miryalaguda	05.40	12.30	06.50	EL	11KV insulator flash over near flyover	-
52		Settipalem	Settipalem-I	11KV	Miryalaguda	05.30	08.40	03.10	EL	11KV Jumper cut	-
53		Settipalem	Settipalem-II	11KV	Miryalaguda	04.15	08.30	04.15	EL	11KV pin insulator failed	-
54		Settipalem	A.R.Gudem	11KV	Miryalaguda	04.25	08.20	03.55	EL	11KV Conductor snapped	-
55		Settipalem	Industrial-I	11KV	Miryalaguda	05.10	08.25	03.15	EL	CT PT problem in Aditya Rice mill	-
56		Settipalem	Industrial-II	11KV	Miryalaguda	05.25	08.35	03.10	EL	Tree branch fallen	-
57		Settipalem	Vemulapally	11KV	Miryalaguda	05.05	08.40	03.35	EL	11KV Conductor snapped	-
58		Buggabaigudem	Buggabaigudem	11KV	Miryalaguda	05.50	11.50	06.00	EL	11 KV Jumper cut	-
59		Buggabaigudem	Thimmareddygudem	11KV	Miryalaguda	05.25	12.10	06.45	EL	2Nos insulators failed and Conductor snapped	-
60		Buggabaigudem	Kukkadam	11KV	Miryalaguda	05.45	12.10	06.25	EL	11KV pin insulator failed	-
61		Buggabaigudem	Lift	11KV	Miryalaguda	05.30	11.30	06.00	EL	11KV pin insulator failed in lift SS yard	-
62		Seethya Thanda	Seethya Thanda	11KV	Miryalaguda	05.20	12.20	07.00	EL	11 KV Jumper cut	-
63	NLG	Seethya Thanda	Mangapuram	11KV	Miryalaguda	05.10	11.50	06.40	EL	11 KV Jumper cut	-
64		Seethya Thanda	Thopucharla	11KV	Miryalaguda	04.40	11.50	07.10	EL	Tree branch fallen	-
65		Agamothkur	Agamothkur	11KV	Miryalaguda	04.30	11.40	07.10	EL	Tree branch fallen	-
66		Agamothkur	Bommakal	11KV	Miryalaguda	04.50	13.20	08.30	EL	11KV Jumper cut	-
67		Laxmidevigudem	Ravulapenta	11KV	Miryalaguda	05.10	16.30	11.20	EL	11KV pin insulators puncter	-
68		Aregudem	Chinnakaparthu	11KV	Nalgonda	04.05	11.20	07.15	EL	11 KV Line Insulator Failed	-
69		Arlagaddagudem	N.R.Gudem	11KV	Nalgonda	06.00	11.00	05.00	EL	HT/LT Line Melet due to Tree Branches fallen on Line	-
70		Akkenapally	Akkenapally	11KV	Nalgonda	05.00	09.00	04.00	EL	11 KV Jumper Cut	-
71		Anneparthu	Anneparthu	11KV	Nalgonda	05.00	06.55	01.55	EL	11 KV Jumper Cut	-
72		Gundrampally	Gundrampally	11KV	Nalgonda	04.00	07.50	03.50	EL	11 KV Jumper Cut and Insulator Failed	-
73	Indoor	Old City	11KV	Nalgonda	02.10	03.20	01.10	EL	11 KV Jumper Cut	-	
74	Indoor	DVK Road	11KV	Nalgonda	03.20	04.20	01.00	EL	AB Switch Cable Damaged	-	
75	Madgulapally	Kukkadam	11KV	Nalgonda	04.45	09.30	04.45	EL	11 KV Line Jumper and Insulator Failed	-	
76	Nakrekal	Chandampally	11KV	Nalgonda	22.45	08.00	09.15	EL	Heavy Gale and Wind HT/LT Line Melt.	-	
77	Nemmani	Merlakunta	11KV	Nalgonda	04.30	09.00	04.30	EL	HT/LT Line Melting	-	
78	Palem	Bopparam	11KV	Nalgonda	04.50	10.20	05.30	EL	11 KV Jumper Cut	-	
79	Pole Center	T.Exchange	11KV	Nalgonda	04.10	05.50	01.40	EL	HT/LT Heavy Gale and Wind	-	
80	Rajupeta	Rajupeta	11KV	Nalgonda	04.30	10.40	06.10	EL	11 KV Line Insulator Failed	-	
81	Thimmanagudem	T.K.Gudem	11KV	Nalgonda	04.15	08.00	03.45	EL	11 KV Disc Failed	-	
82	Thoragal	Thangellavarigudem	11KV	Nalgonda	04.15	12.00	07.45	EL	11 KV Disc Failed	-	
83	Chandur	Thummalapally	11KV	Nalgonda	21.00	11.30	14.30	EL	Moment Flalt	-	
84	Kattangur	Dugunelly	11KV	Nalgonda	04.30	11.50	07.20	EL	Dick faild	-	
85	P.D.Pally	P.D.Pally	11KV	Nalgonda	04.10	11.10	07.00	EL	Moment Flalt	-	
86	Devarkaonda	K.B.Pally	11KV	Devarakonda	22.40	15.30	16.50	E/L	11kV LINE CUTT	-	
87	Devarkaonda	Mynampally	11KV	Devarakonda	05.00	10.00	05.00	E/L	Wind & Gale (Rectify)	-	
88	Konda Mallepally	Inudtrial feeder	11KV	Devarakonda	04.30	06.00	01.30	E/L	Wind & Gale (Rectify)	-	
89	Chandampeta	Siddhapuram	11KV	Devarakonda	06.20	08.20	02.00	E/L	11kV LINE CUTT	-	
90	Chandampeta	Gagilapur	11KV	Devarakonda	08.00	08.30	00.30	E/L	Jumper Cut	-	

91		Teldevarpally	Teldevarpally	11KV	Devarakonda	17.00	21.00	04.00	E/L	Wind & Gale (Rectify)	-
92		Kambalapally	Kambalapally	11KV	Devarakonda	20.00	07.00	09.00	E/L	Wind & Gale (Rectify)	-
93		Buggathanda	Kasurajpally	11KV	Devarakonda	17.00	18.03	01.03	E/L	Wind & Gale (Rectify)	-
94		Buggathanda	Buggathanda	11KV	Devarakonda	17.00	19.30	02.30	E/L	Wind & Gale (Rectify)	-
95		Teldevarpally	Bollaram	11KV	Devarakonda	17.32	19.15	01.43	E/L	Wind & Gale (Rectify)	-
96		Neregugomma	Neregugomma	11KV	Devarakonda	17.00	17.30	00.30	E/L	Wind & Gale (Rectify)	-
97		Cherukupally	Cherukupally	11KV	Devarakonda	17.15	20.00	02.45	E/L	Inusulator fail (Rectify)	-
98		Angadipeta	Gudipally	11KV	Devarakonda	04.00	13.00	09.00	E/L	11KV line Conductor Snapped (Rectify)	-
99		Ghanpur	G.Bhemmanpally	11KV	Devarakonda	21.00	15.45	18.45	E/L	11KV Line Melt	-
100		Teededu	K.Gowararam	11KV	Devarakonda	17.45	08.45	09.00	E/L	Inusulator fail & Wire Cut	-
101		Madnapur	Umanthlapally	11KV	Devarakonda	07.00	10.00	03.00	E/L	Insulator failed (Rectify)	-
102		Tedded	Tedded	11KV	Devarakonda	09.00	13.30	04.30	E/L	Tree fallen on line (Rectify)	-
103		Marrigudam	Y.G.Pally	11KV	Devarakonda	20.00	06.30	10.30	E/L	11kv LINE CUTT	-
104		Marriguda	T.M.Pally	11KV	Devarakonda	04.30	07.00	02.30	E/L	E/L,O/L (Rectify)	-
105		Marriguda	Vattipally	11KV	Devarakonda	04.00	09.00	05.00	E/L	E/L,O/L (Rectify)	-
106		D.B.Pally	S.P.Thanda	11KV	Devarakonda	23.00	06.00	07.00	E/L	E/L,O/L (Rectify)	-
107		D.B.Pally	Naralapally	11KV	Devarakonda	23.30	08.30	09.00	E/L	E/L,O/L (Rectify)	-
108		Nampally	Peddapuram	11KV	Devarakonda	19.00	11.45	07.15	E/L	11KV Conductor Sanpped (Rectify)	-
109		Nampally	Mandhapuram	11KV	Devarakonda	19.00	13.30	05.30	E/L	Inusulator Fail & Wire Cut (Rectify)	-
110		Kopple	Bollaram	11KV	Devarakonda	07.30	10.00	02.30	E/L	Tree fallen on line (Rectify)	-
111		Pittalagudam	Vattikode	11KV	Devarakonda	07.30	15.20	07.50	E/L	Tree fallen on line (Rectify)	-
112		Jununthala	Palapahad	11KV	Devarakonda	07.30	09.40	02.10	E/L	11KV Conductor Sanpped (Rectify)	-
113		G T Giri	Namavaram	11KV	Suryapet	03.45	09.00	05.15	EL	Dick faild	-
114		Bibigudem	Munyaanaik thanda	11KV	Suryapet	06.35	09.20	02.45	EL	11KV Line cut	-
115		Indl Estate	Estate	11KV	Suryapet	06.10	10.15	04.05	EL	CT PT Cable faild	-
116		Indl Estate	Durajpally	11KV	Suryapet	05.15	08.45	03.30	EL	Tree branch fallen on the line	-
117		Chedella	Gajulamalkapuram	11KV	Suryapet	07.30	10.00	02.30		Conductor Snapped	-
118		Annaram	Sangem	11KV	Suryapet	05.45	10.50	05.05	EL	insulator flashover	-
119		Palakeedu	Palakeedu	11KV	Huzurnagar	05.00	08.35	03.35	EL	Due to 11 Disk failed	-
120		Amaravaram	Yathavakilla	11KV	Huzurnagar	05.00	07.30	02.30	EL	Due to Tree Fallen 11 Kv line Snapped at Yathavakilla village	-
121		Mattampally	Choutapally	11KV	Huzurnagar	02.00	05.00	03.00	EL	Due to jumper cut	-
122		Mellacheruvu	Hemlathanda	11KV	Huzurnagar	03.00	06.30	03.30	EL	Due to 11 kv jumper cut at Hemal thanda village	-
123		Akupamula	Singaram	11KV	Huzurnagar	03.10	07.00	03.50	EL	Due to 11 kv jumper cut	-
124		Siripuram	Siripuram	11KV	Huzurnagar	03.30	07.00	03.30	EL	Due to Tree fallen	-
125		N.G Bandlu	V.R Pally	11KV	Bhongiri	05.00	08.30	03.30	EL	11KV pin insulator failed	-
126		pallerla	siddapuram	11KV	Bhongiri	04.00	07.00	03.00	EL	11kv disk failed at siddapuram	-
1	MDK	Nizampur	Nizampur	11KV	Sangareddy	02.20	08.40	06.20		B/d due to 11kv Jumper cut at machadapally vg	-
2		Aroor	Aroor	11KV	Sangareddy	03.40	07.35	03.55		B/d due to Jumper cut at milgirpet vg	-
3		Athmakur	Athmakur	11KV	Sangareddy	00.20	09.50	09.30		B/D due to Insulator failed at bobbiligama VG	-
4		Cheryal	kandi	11KV	Sangareddy	00.30	04.00	03.30		B/D due to Jumper cut at Mamidipally vg	-
5		H GHANPUR AGL	H GHANPUR	11KV	Medak	01.30	09.20	07.50		B/D due to 11KV insulator failed	-

1	RR S	MD Pally	MD Pally (V)	11KV	RJNR	03.35	04.45	01.10	B/D	11KV Insulator failed Ragavendra Hospital	-
2		MD Pally	Brundavan colony	11KV	RJNR	03.40	05.20	01.40	B/D	Tree branches Fallen on 11kv Line at Brundavan colony	-
3		Kattedan-I	Feeder-VI	11KV	RJNR	03.20	05.10	01.50	B/D	11KV Insulator failed at Gouri plastic	-
1	RR N	Jeedimetla-II	N R S A	11KV	Jeedimetla	12.06	14.40	02.34	BD	11kv Jumper Cut & Endy Kit Failure At phase-4	-
2		Chinthal	Surya Nagar	11KV	Medchal	03.55	05.20	01.25	BD	11KV Cable failed at Ganesh Temple, Surya Nagar	
3		Chinthal	Dwaraka Nagar	11KV	Medchal	03.55	05.20	01.25	BD	Tree Branch fallen on the 11KV Line near Prasunna Nagar, Ramalayam	
4		Subash Nagar	Padma Nagar	11KV	Medchal	04.30	05.50	01.20	BD	Line AB Switch Jumper cut & replacement at Padma nagar & Cable Jumper cut in SS	
5		Kompally	Kompally	11KV	Medchal	01.50	02.55	01.05	BD	11KV Cable end kit Failed at Kompally	
6		Kompally	Kompally	11KV	Medchal	03.55	05.00	01.05	BD	11KV Cable failed at Fish Godam	
7		Town Medchal	Contry Club	11KV	Medchal	05.10	07.25	02.15	BD	11KV Pin Insulator failed at SaiBaba nagar colony	
8		Medchal	IDA Kandlakoya	11KV	Medchal	01.02	05.50	04.48	BD	11KV Pin Insulator failed & 11KV Disc failed near Steel Mill company	
9		Medicity	IDA-I	11KV	Medchal	03.30	08.50	05.20	BD	11KV Cable end kit Failed near SS(2 Nos)	
10		Athiwelly	PHI	11KV	Medchal	05.15	09.15	04.00	BD	11KV Cable end kit Failed in SS	
11		Nuthankal	Bharathi	11KV	Medchal	09.50	11.05	01.15	BD	Bird Fallen on 11KV Line at Peerla Bhavi, Nuthankal Village	
12		Bandamadaram	Srirangavaram	11KV	Medchal	05.10	09.10	04.00	BD	Tree Branch fallen on the 11KV Line at Bandamadaram Village	
13		Kandlakoya	Kandlakoya	11KV	Medchal	08.00	11.55	03.55	BD	11KV Jumper Opened at Uma Venkata Reddy T/F	
14		Keshavaram	Adraspally	11KV	Medchal	05.30	06.50	01.20	BD	11KV Disc failed at Adraspally	
15		Laxmapur	IDA-I	11KV	Medchal	03.40	05.10	01.30	BD	11KV Pin Insulator failed at Laxmapur	
16		Shameerpet	Alakritha	11KV	Medchal	03.00	09.30	06.30	BD	11KV Cable Burnt at Janaki Seeds, ORR	
17		Devarayamjal	Kottapet	11KV	Medchal	08.00	09.15	01.15	BD	Tree Branch & Pin Insulaltor Failed at DMC, Devarayamjal	
18		Devarayamjal	Pothaipally	11KV	Medchal	05.00	06.30	01.30	BD	Tree Branch fallen on the 11KV Line at DMC, Devarayamjal	-
1	RR E	Moula-Ali	Meerpet	11KV	Sainikpuri	03.45	04.17	00.32		Telephone wire toched on 11Kv line at Thirumala Nagar (Foc Raju)	-
2		Polytechnic	PS Colony	11KV	Habsiguda	04.36	05.28	00.52		11KV Pin Insulator failed at Srinivasa Puram St.no.08	-
3		St.No.08	Green Hills	11KV	Habsiguda	13.50	15.55	02.05		11KV AB Cable failed at Green Hills Colony	-
4		Nagole	Samanthpuri	11KV	Saroor Nagar	04.45	07.10	02.25		11KV Insulater Failed Nagole X-Road	-
5		Keesara	Kadevi	11KV	Keesara	03.45	06.10	02.25		Tree branches fallen on 11KV line at Keesara Gutta	-
6		Rampally Dayara	Vanneguda Indl	11KV	Keesara	04.40	08.20	03.40		11KV Disc failed near Holymerry College	-
1		I.D.P.L	H.P.Road	11KV	Erragadda	19.30	21.00	01.30	EL,OL	Breaker problem at SS	Arranged B/F on 11KV Janapriya fdr
2		Chinna Thokatta	Old Bowenpally	11KV	Bowenpally	03.15	05.05	01.50	EL,OL-R&Yph	Jumper cut on 1st Line AB Switch	-

3		I.D.P.L	Shivalayam	11KV	Bowenpally	03.15	04.35	01.20	EL,OL-Bph	No Visible Fault	-
4		I.D.P.L	Vijaya Electrical	11KV	Bowenpally	03.20	04.35	01.15	EL	No Visible Fault	-
5		I.D.P.L	Bala Nagar	11KV	Bowenpally	03.20	05.00	01.40	EL	No Visible Fault	-
6		Bowenpally	Ferozguda	11KV	Bowenpally	03.25	05.05	01.40	EL	No Visible Fault	-
7	HYD N	Macha Bollarum	Father Balaiah Nagar	11KV	Bowenpally	04.00	05.05	01.05	EL	No Visible Fault	Arranged B/F on 11KV Sai Reddy Nagar & 11KV Krishna Nagar feeders
8		Road No.12	Kanaka Durga	11KV	Banjarahills	04.05	05.10	01.05	EL	No Visible Fault	-
9		Road No.12	N.B.T Nagar	11KV	Banjarahills	04.08	05.30	01.22	EL	R.M.U Limb fault at Mithila Nagar (6No. DTR's Kept Off)	-
10		Road No.2	Lumbini Mall	11KV	Banjarahills	04.10	05.25	01.15	OL-Rph	No Visible Fault	-
11		Toli Chowki	Hanuman Temple	11KV	Banjarahills	04.40	05.48	01.08	EL,OL-Bph	Tree branches fallen on lines at Vijaya Shanthi House	-
12		Road No.22	UCO Bank	11KV	Banjarahills	05.05	06.30	01.25	All Indication	AB Cable fault at Plot No.447	-
1		Aliyabad	Boys Town	11KV	Charminar	02.43	03.45	01.02	EL	No Visible Fault	-
2		Aliyabad	Police Quarters	11KV	Charminar	02.43	04.48	02.05	EL	No Visible Fault	-
3		Kanchanbagh	Riyasath Nagar	11KV	Charminar	02.51	04.50	01.59	EL	Foreign material fallen on lines at Modern Function Hall	-
4		Panjesha	Bibi Bazar	11KV	Charminar	02.57	04.48	01.51	EL	HT Jumper cut at Bibi Bazar	-
5		Kandikalgate	G.M Chowni	11KV	Charminar	04.30	05.50	01.20	EL,OL	No Visible Fault	-
6		Kanchanbagh	Kanchanbagh	11KV	Asmangadh	02.51	04.14	01.23	EL	No Visible Fault	-
7	HYD S	Santosh Nagar	Jahangir Nagar	11KV	Asmangadh	02.56	05.20	02.24	EL,OL-Bph	HT Jumper cut at SS	-
8		Teegalaguda	Shanker Nagar	11KV	Asmangadh	04.39	06.00	01.21	EL,OL-R&Yph	DTR fault near Moosi River	-
9		Teegalaguda	Teegalaguda	11KV	Asmangadh	04.40	06.00	01.20	EL,OL-Rph	No Visible Fault	-
10		Sultan Bazar	Sultan Bazar	11KV	Begumbazar	04.25	05.30	01.05	EL,OL-Bph	No Visible Fault	-
11		E.N.T	E.N.T	11KV	Begumbazar	04.31	05.35	01.04	EL,OL	No Visible Fault	-
12		Gosha Mahal	M.J Market	11KV	Begumbazar	04.40	06.03	01.23	EL,OL-Rph	Insulator flash over at Malakunta	-
1		Lumbini Park	Avanthi Nagar	11KV	Saifabad	04.26	06.34	02.08	OL-Bph	Disc Insulator flash over at Basheerbagh Fly Over	-
2		Bathkammakunta	D.D Colony	11KV	Azamabad	04.30	06.10	01.40	EL	No Visible Fault	-
3		Fever Hospital	Nallakunta	11KV	Azamabad	04.30	06.50	02.20	EL,OL-Bph	Kite Sticks fallen on lines at Fever Hospital back side	-
4		Fever Hospital	C.C Shroff Hospital	11KV	Azamabad	04.34	05.55	01.21	All Indication	No Visible Fault	-
5	HYD C	Industrial Area	Shankermutt	11KV	Azamabad	04.40	06.20	01.40	EL	Cable End Kit failed at Shankermutt (3No. DTR's Kept Off)	-
6		Industrial Area	Azamabad I.E	11KV	Azamabad	04.40	06.30	01.50	EL	Kite Sticks fallen on lines at KLR Residency	-
7		Toli Chowki	Hakeemsha	11KV	Mehdipatanam	04.12	06.31	02.19	EL	Tree branches fallen on DTR at Hakeemsha Colony	-
8		Toli Chowki	B.S.N.L	11KV	Mehdipatanam	04.15	05.32	01.17	EL	No Visible Fault	-
9		Golconda	Q.Q Toombs	11KV	Mehdipatanam	04.22	05.40	01.18	All Indication	No Visible Fault	-

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Nawabpet	33KV	Mahabubnagar	02.50	07.40	04.50	E/L&O/L	Tree Fallen on the Line near Thimsanpally (V)	Mahabubnagar	-
2		Mahabubnagar	Machanpally	33KV	Mahabubnagar	01.24	08.35	07.11	E/L&O/L	Tree Branches Fallen on the Line at Palamur University	Mahabubnagar	-
3		Makthal	Narva	33KV	Mahabubnagar	03.55	04.30	00.35	E/L	3 No's Pin Insulators Failed near Raikod (V)	Makthal	Alternate Supply Arranged From Eklaspur at 4:30Hrs
4		Kodangal	Hamsanpally	33KV	Mahabubnagar	00.55	07.55	07.00	E/L	AB Switch Open at Hamsanpally toward Sajakhanpet SS Line Petroling and No Visabul Fault Due to Rian	Kodangal	-
5		Kodangal	Korhur	33KV	Mahabubnagar	01.20	08.35	07.15	E/L	Tree Fallen on the Line near Regadimailwar (V)	Kodangal	-
6		Marikal	Koukuntla	33KV	Mahabubnagar	04.05	10.05	06.00	E/L	No Visible Fault Due to Rain	Marikal	Alternate Supply Arranged From 33KV Devarkadra at 10:05Hrs
7		Marikal	Koilkonda Water Grid	33KV	Mahabubnagar	02.45	07.15	04.30	E/L	No Visible Fault Due to Rain	Marikal	-
8		Thirumalaipally	Veltoor	33KV	Wanaparthi	05.30	09.08	03.38	E/L	Pin Insulator Damaged near Addkal (V)	Thirumalaipally	-
9		Polepally	Polepally	33KV	Jadcherla	06.45	09.33	02.48	E/L	33Kv Pin Insulator Damaged near Polepally SS	Polepally	-
10		Nagarkurnool	Tadoor	33KV	Nagarkurnool	07.27	09.50	02.23	E/L	No Visible Fault Due to Rain&Wind	Nagarkurnool	-
11		Achampet	Uppununthala	33KV	Nagarkurnool	04.15	08.25	04.10	E/L	33KV Insulator Failed near Achampet	Achampet	-
1	NLG	Nalgonda	Chikatimamidi	33KV	Nalgonda	05.10	06.30	01.20		Jumper Cut	Nalgonda	-
2		Kanagal	Kopol	33KV	Nalgonda	20.10	08.45	12.35		Line Flalt	Kanagal	-
3		Kanagal	Kanagal	33KV	Nalgonda	07.10	09.10	02.00		33KV SS Ligt Erested	Kanagal	-
4		K.M.Pally	Neredugumu	33KV	Devarakonda	05.05	09.05	04.00		Heavy Rain	K.M.Pally	-
5		Darshincherla	Kethavariugda	33KV	Miryalaguda	05.30	10.00	04.30		Tree Fallen tha Line	Darshincherla	-
6		Miryalaguda	V.K.Palem	33KV	Miryalaguda	18.00	11.10	17.10		Jumper Cut	Miryalaguda	-
7		Mattampally	B.N.Thanda	33KV	Miryalaguda	20.20	09.35	13.15		Jumet Cut	Mattampally	-
8		Guntipally	Singarjpally	33KV	Devarakonda	15.40	13.40	22.00		Disk Failed	Guntipally	-
9		Haliya	Rajavaram	33KV	Miryalaguda	04.00	11.15	07.15		33KV insulator flash over, insulator failure and line touched the cross arm at Haryaganithanda	Haliya	-
10		Suryapet	Penpahad	33KV	Suryapet	05.00	12.00	07.00		Altarenate supply arenged from 33KV Gaddipally feeder	Suryapet	-
11		Suryapet	Nemmikal	33KV	Suryapet	05.10	08.00	02.50		AB Swithch open in Athmakur(S) SS	Suryapet	-
12		S.Gowraram	Arvapally	33KV	Suryapet	03.55	10.10	06.15		Lighting arrestores blost	S.Gowraram	-
13		Thungathurthy	Phanigiri	33KV	Suryapet	04.00	11.10	07.10		Altarenate supply arenged from 33KV tty feeder	Thungathurthy	-
14		Wadapally	Janpahad	33KV	Huzurnagar	06.00	10.05	04.05		33 kv jumper cut at Ganespahad	Wadapally	-
15		Dirincherla	Keethavargudem	33KV	Huzurnagar	05.30	10.00	04.30		Tree branch fall on 33Kv line	Dirincherla	-
16		Suryapet	Tirumalagiri	33KV	Huzurnagar	06.10	09.50	03.40		33 kv line snapped near Tirumalagiri village	Suryapet	-
17		Kolanupaka	Kolanupaka	33KV	Bhongiri	04.15	06.20	02.05		33kv insulator failed near kolanupaka	Kolanupaka	-

1		Kandhi	BDL	33KV	Sangareddy	06.00	12.50	06.50		B/D due to Jumper cut	Kandhi	-
2		Kandhi	IIT Kandi	33KV	Sangareddy	03.55	11.15	07.20		B/D due to Jumper cut	Kandhi	-
3		Sadashivapet	Jogipet	33KV	Sangareddy	00.15	02.55	02.40		B/D due to AB switch problem	Sadashivapet	-
4		Pashamailaram	Suven life	33KV	Sangareddy	23.20	07.00	07.40		B/D due to no problem at found	Pashamailaram	-
5		Gummadidala	GPSS I	33KV	Patancheru	00.30	09.55	09.25		B/D due to 33KV Conductor snapped	Gummadidala	-
6		Gummadidala	GPSS II	33KV	Patancheru	03.12	09.55	06.43		B/D due to 33KV Conductor snapped	Gummadidala	-
7		Gummadidala	AFA	33KV	Patancheru	03.05	09.55	06.50		B/D due to 33KV Conductor snapped	Gummadidala	-
8		Narayanakhed	Wasar	33KV	Jogipet	23.20	04.15	04.55		B/D due to Heavy rain & wind	Narayanakhed	-
9		Narayanakhed	Kalher	33KV	Jogipet	23.20	08.45	09.25		B/D due to Insulators failed	Narayanakhed	-
10		Kowdipally	Venkatraopet	33KV	Medak	01.50	09.15	07.25		B/D due to Pin Insulator failed	Kowdipally	-
11		Kowdipally	Amsanpally	33KV	Medak	02.45	07.25	04.40		B/D due to Pin Binding failed	Kowdipally	-
12		Peddashankarampet	Alladurg	33KV	Medak	23.34	11.30	11.54		BD Contine Loads tag on Burugupally feeder	Peddashankarampet	-
13		Peddashankarampet	Regode	33KV	Medak	23.44	11.45	12.00		B/D due to Pin Insulator failed	Peddashankarampet	-
14		Narsapur	Chippalthurthy	33KV	Medak	00.10	12.40	12.30		B/D due to Pin Insulator failed	Narsapur	-
15		Narsapur	Arobindow	33KV	Medak	00.05	04.00	03.55		B/D due to Heavy Gail & wind	Narsapur	-
16		Narsapur	Kakazmaddur	33KV	Medak	00.20	07.00	06.40		B/D due to Heavy Gail & wind	Narsapur	-
17		Ramayampet	Konapur	33KV	Medak	02.17	08.17	06.00		B/D due to Pin Insulator failed	Ramayampet	-
18		Manoharabad	Masaipet	33KV	Medak	02.00	09.00	07.00		B/D due to Heavy Gail & wind	Manoharabad	-
1	RR S	132kv Pargi	Mothkur	33KV	Vikarabad	01.15	03.20	02.05		tree falinon 33kv line near by Antharm.vg		-
1		132KV LGM Pet	33KV BE Pharma	33KV	Medchal	02.31	08.45	06.14	BD	33KV Pin Insulator failed at BE Pharma		-
2		132KV Medchal	33KV Athiwelly	33KV	Medchal	01.38	05.10	03.32	BD	33KV Disc failed & replacement at Medchal		-
3	RR N	132KV Medchal	33KV Medchal-I	33KV	Medchal	02.36	07.00	04.24	BD	33KV Line Cut & replacement near 33/11KV Medchal SS(Breakar Problam)		-
4		132KV LGM Pet	33KV LGM Pet	33KV	Medchal	04.33	09.52	05.19	BD	33KV Pin Insulator failed at LGM Pet		-
5		132KV LGM Pet	33KV Aliabad	33KV	Medchal	11.20	13.30	02.10	BD	33KV Y Phase Lighting Arrester failed in SS		-
1	HYD N	132KV Gunrock	Jamestreet (Idle)	NT	Nehru Ngr	07.35	18.40	00.00	EL	End Kit failed at 33KV Gymkhana SS		-